

Operations Assessment Task Force 2021-22 Winter Study

Todd Bickel
Sr. Engineer I, Transmission Operations
Operating Committee
November 4, 2021

www.pjm.com | Public PJM © 2021




2021-22 Winter Preliminary Capacity Overview

- OATF Study
 - Case Parameters
 - Significant Facility Changes
 - 50/50 Non-diversified peak load study results
 - Sensitivity Study Results



Winter 2021-22 Extreme Scenario Overview (Preliminary)



www.pjm.com | Public 9JM © 2021



50/50 Non-diversified Peak Load Base Case		
LAS Load Forecast	137,866 MW	
Preliminary RTO Net Interchange	5,750 MW** (Exporting)	
PJM RTO Installed Capacity	188,709 MW (preliminary)	
Discrete Generator Outages	17,696 MW	


^{** 5,750} MW of net interchange is modeled in the OATF base case and accounts for historical and forecasted Pseudo Tie data.

PEAK LOAD ANALYSIS

No reliability issues identified.



Topology Changes





- No reliability issues identified for base case and N-1 analysis.
- Re-dispatch and switching required to control local thermal or voltage violations in some areas.
- All networked transmission voltage violations were controlled by capacitors. All other voltage violations were caused by radial load.



2021-22 Winter OATF Study

Sensitivity Studies	Impact	
External contingencies that could impact PJM reliability	No reliability concerns	
N-1-1 Relay trip conditions	No cascading outage concerns identified • All networked transmission overloads were controlled pre-contingency	
Max-Cred Contingency Analysis	No reliability concerns	
Transfer Interface Analysis	No reliability concerns	
BGE/PEPCO Import Capability	No reliability concerns	
90/10 Load Forecast study (143,065 MW)	No uncontrollable or unexpected issues observed at the elevated load levels.	
Solar and Wind Generation Sensitivity Study	No reliability concerns	
Gas Pipeline Disruption Study	No reliability concerns	

www.pjm.com | Public 7 PJM © 2021



Reactive Interface Transfer Analysis

Interface	Winter 2021-22 Limit (MW)	Typical Back-off (MW)
Eastern	7174	300
Central	2088	200
Western	5326	200
Bed-Blackoak	1635	50
AP South	4793	100
AEP-DOM	5226	100
Cleveland	3537	200
CE-EAST	3463	200
5004/5005	2997	50



- Loss of each Local Distribution Company (LDC)
 - No issues observed.

EMS Gas Contingencies

- Analysis based on potentially more credible segment and compressor station contingencies with definitions in PJM EMS.
- No issues observed.



Presenter:

Todd Bickel, todd.bickel@pjm.com

OATF 2021-22 Winter Study



Member Hotline

(610) 666 - 8980

(866) 400 - 8980

custsvc@pjm.com