

Demonstration of PFR Improvement September 2017

ERCOT
Operations Planning

Agenda

- Overview
- BAL-001-TRE-1 Standard
- Applicability to Alternative Resources
- Ancillary Service Products & Dispatch

2

- Improvements & Changes
 - Frequency Profile Comparison
- Lessons Learned
- Questions



Overview

- ERCOT has implemented NERC Regional Standard BAL-001-TRE-1
 - Effective April 1st, 2015
 - Implemented governor dead-band and droop setting requirements for Generation Resources (GRs)
 - Implemented enforcement mechanisms for evaluating quality of Primary Frequency Response (PFR) from GRs
- Fast Responding Regulation Service (FRRS) being provided from storage resources (i.e. batteries).
- Improvements made to Generation to be Dispatched (GTBD) (load balance equation) and Regulation Deployment (LFC).



BAL-001-TRE-1

Requirements of Note

- 1: Identify Frequency Events as Frequency Measurable Events (FMEs)
- 2 & 3: Calculate Initial & Sustained PFR for each FME and include into a Rolling Average for each GR of each GO

6: Generation Resource governor dead-band and droop setting

requirements:

| Generator Type | Max. Deadband |
|-------------------------------|---------------|
| Steam and Hydro Turbines with | +/- 0.034 Hz |
| Mechanical Governors | |
| All Other Generating | +/- 0.017 Hz |
| Units/Generating Facilities | |

Combined Cycle facilities get evaluated using a 5.78% droop setting to account for lack of PFR coming from Steam Turbine.



| Generator Type | % Setting |
|--------------------------------------|-----------|
| Hydro | 5% |
| Nuclear | 5% |
| Coal and Lignite | 5% |
| Combustion Turbine (Simple Cycle and | 5% |
| Single-Shaft Combined Cycle) | |
| Combustion Turbine (Combined Cycle) | 4% |
| Steam Turbine (Simple Cycle) | 5% |
| Steam Turbine (Combined Cycle)* | 5% |
| Diesel | 5% |
| Wind Powered Generator | 5% |
| DC Tie Providing Ancillary Services | 5% |
| Renewable (Non-Hydro) | 5% |

BAL-001-TRE-1

- Requirements of Note (cont'd.)
 - 7 & 8: Each GO must operate each GR with settings in R6 when it is online and available for dispatch, unless the GO has a valid reason not to. GO must inform ERCOT within 30mins if a governor is to be out of service.
 - 9 & 10: Each GO must maintain a 12-month rolling average PFR score of 0.75 (75%) or higher.
 - Opportunities for exemptions/re-evaluations



BAL-001-TRE-1

- Increases amount of governor action from GRs.
 - Improves frequency control performance (CPS1)
- Improves PFR during frequency events
 - Faster recovery times
 - Dampens initial excursion (governor dead-bands tighter)
 - Better Interconnection Combined Frequency Response Performance (R4 & R5)
- All GRs required to provide PFR with defined governor dead-band and droop settings.
 - Changed requirement from 36mHz to 17mHz on most GRs
 - Regardless if they are in Responsive Reserve (RRS) (contingency reserves) market
 - No current PFR market (no payment for providing PFR)





Alternative Resources & PFR

- Storage Resources
 - Subject to BAL-001-TRE-1
 - Participate in FRRS market
- Wind & Solar Resources
 - Subject to BAL-001-TRE-1
 - Have required governor dead-band and droop settings.
 - Have had requirement since 2010. BAL-001-TRE-1 changed dead-band requirement from 36mHz to 17mHz.
 - All Resources only expected to provide PFR when they have enough headroom for low frequency events.
 - Wind & Solar typically dispatched to their Pmax (HSL), typically do not have headroom.
 - No headroom = not evaluated for PFR during FMEs.
 - PFR performance from Wind & Solar has thus far been satisfactory.



Alternative Resources & PFR







8

Ancillary Service Products & Dispatch

- Regulation (AGC)
 - Annually/seasonally tune AGC parameters for regulation deployment.

FRRS

- Typically carried by storage resources (batteries.)
- Deployed on a step scale based on frequency.
- Maximum deployment time typically around 5-minutes.

Energy Dispatch

- Include ACE Integral in load balance equation
 - Dispatches energy to recent frequency trends
- Include regulation deployment in load balance equation
 - Helps recover regulation deployment




Improvements & Changes

Frequency Profile Comparison, etc.

2008 - 2017




Comparing 2009 vs 2008 Frequency Profile in 5 mHz Bins






Comparing 2010 vs 2008 Frequency Profile in 5 mHz Bins






Comparing 2011 vs 2008 Frequency Profile in 5 mHz Bins






Comparing 2012 vs 2008 Frequency Profile in 5 mHz Bins






Comparing 2013 vs 2008 Frequency Profile in 5 mHz Bins






Comparing 2014 vs 2008 Frequency Profile in 5 mHz Bins






Comparing 2015 vs 2008 Frequency Profile in 5 mHz Bins






Comparing 2016 vs 2008 Frequency Profile in 5 mHz Bins






Comparing 2017 vs 2008 Frequency Profile in 5 mHz Bins






Rolling Average CPS1






Interconnection Minimum Frequency Response (IMFR) Performance






MW Loss vs. Frequency Recovery Time





Percent Beyond Dead-band – 17mHz




Significant improvement after March 2015

| Percent Beyond Dead-band | | | | | |
|--------------------------|---------|---------|---------|---------|--|
| | 2013 | 2014 | 2015 | 2016 | |
| Jan | 41.051% | 48.102% | 42.429% | 31.995% | |
| Feb | 44.427% | 50.586% | 44.148% | 33.458% | |
| Mar | 45.921% | 52.290% | 36.276% | 33.128% | |
| Apr | 43.779% | 52.026% | 33.607% | 33.334% | |
| May | 41.289% | 51.019% | 33.985% | 32.685% | |
| Jun | 45.053% | 44.369% | 32.814% | 29.301% | |
| Jul | 41.170% | 45.723% | 28.677% | 27.393% | |
| Aug | 40.682% | 42.703% | 29.639% | 24.815% | |
| Sep | 43.564% | 47.292% | 29.652% | 27.573% | |
| Oct | 47.753% | 43.855% | 31.120% | - | |
| Nov | 46.212% | 42.698% | 29.067% | - | |
| Dec | 41.306% | 46.615% | 29.385% | - | |

^{*}Any interval outside deadband is counted.




17 mHz Below & Above Deadband Comparison





Percent Beyond Dead-band – 34mHz




Significant improvement after March 2015

| Percent Beyond Dead-band | | | | |
|--------------------------|--------|--------|--------|--------|
| | 2013 | 2014 | 2015 | 2016 |
| Jan | 1.661% | 1.868% | 1.121% | 0.310% |
| Feb | 1.598% | 2.324% | 1.187% | 0.313% |
| Mar | 1.742% | 2.739% | 0.931% | 0.526% |
| Apr | 1.652% | 2.359% | 0.819% | 0.481% |
| May | 1.303% | 2.329% | 0.619% | 0.332% |
| Jun | 1.450% | 0.986% | 0.422% | 0.278% |
| Jul | 1.190% | 1.193% | 0.253% | 0.188% |
| Aug | 1.006% | 0.986% | 0.307% | 0.117% |
| Sep | 1.611% | 1.737% | 0.366% | 0.167% |
| Oct | 2.068% | 1.137% | 0.319% | - |
| Nov | 2.036% | 0.959% | 0.301% | - |
| Dec | 1.756% | 1.460% | 0.225% | - |

^{*}Any interval outside deadband is counted.




34 mHz Below & Above Deadband Comparison






Daily RMS1 of ERCOT Frequency by Year






Daily RMS1 of ERCOT Frequency by Month





Daily RMS1 of ERCOT Frequency by Month





Improvements & Changes

- Improved CPS1 scores
- Improved frequency response during frequency events
 - Better IMFR performance
- Increased governor action
 - Can be burdensome on certain Generation Resources
- Distribution of frequency leans towards 60.017
 - More resources able to respond to frequency deviations of +0.017Hz (wind, base loaded resources, etc.)



Lessons Learned

- Requires a lot of coordination with GOs
- Data quality from GRs is very important
- Evaluation of PFR scores per GR can be a strenuous process



Questions?


Thank you!!



Appendix




Total Energy






Total Energy from Wind Generation





% Energy from Wind Generation





Daily Minimum System Inertia

