



Performance Assessment for Primary Frequency Response Update

PFRSTF

January 24, 2018



- Summary of changes from previous material
 - Changed Eco Min/Eco Max to Eco Min+ 5%/Eco Max – 5%
- Details on event selection
- Rolling Average Scoring
- Operating Priorities
- Tool Overview
- High level performance examples
- Examples of performance assessment

- When we will evaluate a resource to provide PFR:
 - Unit is operating between **EcoMin+5%** and **EcoMax-5%**
 - **Example: a unit with a Eco Min of 50MW and Eco Max of 300MW would be evaluated for PFR performance between 52.5MW and 285MW**
 - And Unit is online providing energy and has available headroom (for low frequency periods) or foot room (for high frequency periods)
 - And / Or Unit is assigned reserves

- PJM will reserve the right to perform performance assessment between **20-30** times a year
 - **PJM will aim to find 2-3 frequency events per month for performance assessments, however system conditions may provide less opportunities – no set number of events will be prescribed**
 - Events selected will be ‘clean’ frequency excursions where frequency went outside the dead band and engaged governors
 - Frequency outside $\pm 40\text{mHz}$
 - Frequency stays outside of dead band for 60 seconds
 - PJM will aim to select events in both directions
 - Events with high frequency (above 60.04) and events with low frequency (below 59.96)



- Events selected will be 'clean' frequency excursions where frequency went outside the dead band and engaged governors
 - Frequency outside $\pm 40\text{mHz}$
 - Frequency stays outside of dead band for 60 seconds
- PJM will evaluate all events over a monthly period and select the best 2 or 3 events from the month
 - The best events will be evaluated on how far outside the dead bands frequency went and how long frequency deviated.
 - Events could be caused by unit/load loss or just frequency drift.

- Threshold will be set to determine Pass/Fail assessment
 - Unit will need to provide 50% of expected response to Pass (in MW)
 - Pass/Fail assessment will be down on a quarterly basis looks at a 12 month rolling window
 - Response measured within 20-52 seconds (alignment with BAL-003-1)
 - Sustain frequency response out to 60 seconds or duration of event
- Pass/Fail assessment due to some data quality
 - 10 second scan rates
 - Data dead band storage in historian
- Assessments will be performed on market units
 - Further breakdown assessments will be available upon request

- Quarterly assessments looking at 12-month rolling window
 - Assessment performed in Jan will look at all events selected from Jan of the previous year through Dec of the previous year
 - April evaluation will used April of the previous year through March of current year
 - July evaluation will used July of the previous year through June of current year
 - Oct evaluation will used Oct of the previous year through Sept of current year

- Scoring will be evaluated as average performance over 12 month window
 - Each event will be evaluated separately and then performance will be average for pass/fail determination
 - 50% or greater average performance will be considered passing
- Units can be evaluated on 20+ events over the 12 month period or just a few
 - Events will be determined on if the unit was expected to respond during the selected events
 - Headroom, Online, Regulation status, etc.

- If a unit is providing Energy with set basepoint
 - Provide PFR based on droop characteristics
- If a unit is providing Energy and Ramping Up
 - If LOW frequency event, continue ramping at ramp rate
 - If HIGH frequency event, stop ramping for duration of freq. event
- If a unit is providing Energy and Ramping Down
 - If LOW frequency event, stop ramping for duration of freq. event
 - If HIGH frequency event, continue ramping at ramp rate
- If a unit is providing Regulation
 - Continue providing Regulation, can also provide PFR but will not undergo performance assessment for this event



- Initial Data need to set up performance assessment
 - Additional data for awareness (ex. fuel type, unit zone, etc.)
- Eco Max/Spin Max data coming from Markets Gateway
 - Important this data is accurate
- Droop/Dead band will be set to PJM requirements (5%/36mHz) unless exception documented

Unit Name	Test Unit	
Frequency:	\\DOR\ca_rt_fq\pjmc:freq-agc freq:hz	} Pi Tags for telemetry Data used in performance evaluation
Unit MW:		
Spin Max:		
Econ. BP:		
Governor Settings		
Mode of Operation:	Droop	} Unit's Droop and Deadband settings
Droop (%):	5%	
Deadband (Hz):	0.036	
Econ. Max		
Resource ID:		
Unit Zone:		
Regulation:		■ If the unit is on for Reg
Current Econ. Max		} Used to calculate headroom
Current Spin Max		
RPM Installed Capacity:		
Status:	Available	■ Unit Status
Fuel Type		

- Data is collected from 1 minute before the event T0 to 5 minutes after the event
 - Frequency, Unit Output, Spin Max, and Eco BP are all collected data
 - FR Capacity is a headroom calculation (Eco Max – Unit Output) for low frequency and (Unit Output – Eco Min) for high frequency
 - Droop Coefficient and Expect Response is the calculated response
 - Regulation and Output Before Event used for situational awareness to make sure the performance assessment is done correctly

	Date/Time	Frequency	Unit Output	Spin Max	FR Capacity	Droop Coefficient	Expected Response	EcoBP	Regulation	OUTPUT BEFORE EVENT
17:30:37	05-Dec-15 17:30:37	60.00350189	178.6999969	605	426.300003	1.33%	178.6999969	179	0	178.1999969
17:30:39	05-Dec-15 17:30:39	60.00422668	178.6999969	605	426.300003	1.36%	178.6999969	179		178.1999969
17:30:41	05-Dec-15 17:30:41	60.00427628	178.6999969	605	426.300003	1.36%	178.6999969	179		178.226944
17:30:43	05-Dec-15 17:30:43	60.00301743	178.6999969	605	426.300003	1.32%	178.6999969	179		178.3999939
17:30:45	05-Dec-15 17:30:45	60.00273895	178.6999969	605	426.300003	1.31%	178.6999969	179		178.3999939
17:30:47	05-Dec-15 17:30:47	60.00299835	178.6999969	605	426.300003	1.32%	178.6999969	179		178.3999939


- Two points within the data are calculated to be used in the performance evaluation
 - Expected and Actual response at Point A, measured from -16 to 0sec before the event
 - Expected and Actual response at Point B, measured from 20 to 52 sec after the event

Time	Date	Time	Value 1	Value 2	Value 3	Value 4	Value 5	Value 6
17:31:23	05-Dec-15	17:31:23	59.99150085	178.8999939	605	426.100006	0.93%	
17:31:25	05-Dec-15	17:31:25	59.99150085	178.8999939	605	426.100006	0.93%	
17:31:27	05-Dec-15	17:31:27	59.9910202	178.8999939	605	426.100006	0.91%	
17:31:29	05-Dec-15	17:31:29	59.99001694	178.8999939	605	426.100006	0.88%	
17:31:31	05-Dec-15	17:31:31	59.98925781	178.8999939	605	426.100006	0.85%	
17:31:33	05-Dec-15	17:31:33	59.98851776	178.8999939	605	426.100006	0.83%	
17:31:35	05-Dec-15	17:31:35	59.98727417	178.8999939	605	426.100006	0.79%	
17:31:37	05-Dec-15	17:31:37	59.98625946	178.8999939	605	426.100006	0.75%	
17:31:39	05-Dec-15	17:31:39	59.98551178	178.8999939	605	426.100006	0.73%	
17:31:41	05-Dec-15	17:31:41	59.9801445	178.8999939	605	426.100006	0.54%	
17:31:43	05-Dec-15	17:31:43	59.97330856	178.8999939	605	426.100006	0.31%	
17:31:45	05-Dec-15	17:31:45	59.96741867	178.8999939	605	426.100006	0.12%	
17:31:47	05-Dec-15	17:31:47	59.95941925	178.8999939	605	426.100006	-0.15%	
17:31:49	05-Dec-15	17:31:49	59.95429611	178.8999939	605	426.100006	-0.33%	
17:31:51	05-Dec-15	17:31:51	59.95155334	178.8999939	605	426.100006	-0.42%	
17:31:53	05-Dec-15	17:31:53	59.9495163	178.8999939	605	426.100006	-0.49%	
17:31:55	05-Dec-15	17:31:55	59.94900131	178.8999939	605	426.100006	-0.51%	
17:31:57	05-Dec-15	17:31:57	59.94875717	178.8999939	605	426.100006	-0.51%	
17:31:59	05-Dec-15	17:31:59	59.94825745	178.8999939	605	426.100006	-0.53%	
17:32:01	05-Dec-15	17:32:01	59.94653702	178.8999939	605	426.100006	-0.59%	
17:32:03	05-Dec-15	17:32:03	59.94524384	178.8999939	605	426.100006	-0.63%	
17:32:05	05-Dec-15	17:32:05	59.94477463	178.8999939	605	426.100006	-0.65%	
17:32:07	05-Dec-15	17:32:07	59.9444809	178.8999939	605	426.100006	-0.66%	
17:32:09	05-Dec-15	17:32:09	59.94475937	178.8999939	605	426.100006	-0.65%	
17:32:11	05-Dec-15	17:32:11	59.9440155	178.8999939	605	426.100006	-0.67%	
17:32:13	05-Dec-15	17:32:13	59.94350052	178.8999939	605	426.100006	-0.69%	
17:32:15	05-Dec-15	17:32:15	59.94350052	178.8999939	605	426.100006	-0.69%	
17:32:17	05-Dec-15	17:32:17	59.94470978	178.8999939	605	426.100006	-0.65%	
17:32:19	05-Dec-15	17:32:19	59.945755	178.8999939	605	426.100006	-0.62%	
17:32:21	05-Dec-15	17:32:21	59.94549942	178.8999939	605	426.100006	-0.62%	
17:32:23	05-Dec-15	17:32:23	59.94525909	178.8999939	605	426.100006	-0.63%	
17:32:25	05-Dec-15	17:32:25	59.94548416	178.8999939	605	426.100006	-0.62%	
17:32:27	05-Dec-15	17:32:27	59.94599915	178.8999939	605	426.100006	-0.61%	
17:32:29	05-Dec-15	17:32:29	59.94527054	178.8999939	605	426.100006	-0.63%	


Expected Actual Point A
178.9 178.9

Point B
181.6 178.9


- The full set of data is graphed
 - Event Data: Frequency Profile and Point A and Point B of the event
 - Unit Data: Unit output and Expected response



- The addition data is also graphed
 - Unit Output 10min before the event shows the unit behavior before the event (ramping, etc.)
 - Regulation graph shows if the unit was providing regulation during the event time period




- Example Data
- Low Frequency Event
- No requested ramping, unit will be evaluated on droop characteristics
- Evaluation done on average actual output at 20-52 sec AFTER frequency event compared to average expected output 20-52 sec AFTER frequency event
 - **Expected response= average MW of green dotted curve in purple band**





- Point A
 - Starting MW = 55.1
- Point B
 - Expected MW= 59.3
 - Actual MW= 59.0
- Response
 - Expected: $59.3 - 55.1 = 4.2\text{MW}$
 - Actual: $59.0 - 55.1 = 3.9\text{MW}$
- Performance Assessment
 - $1 - (\text{Expected MW} - \text{Actual MW}) / (\text{Expected MW})$
 - $1 - (4.2 - 3.9) / 4.2 = 93\%$
 - **PASS**

- Eco Max = 325MW
- Small Eco BP change during this period





- Point A
 - Starting MW = 329.1
- Point B
 - Expected MW=331.2
 - Actual MW= 329.5
- Response
 - Expected: $331.2 - 329.1 = 2.1\text{MW}$
 - Actual: $329.5 - 329.1 = 0.4\text{MW}$
- Performance Assessment
 - $1 - (\text{Expected MW} - \text{Actual MW}) / (\text{Expected MW})$
 - $1 - (2.1 - 0.4) / 2.1 = 19.1\%$
 - **FAIL**

- Eco Max = 650MW
- No change in Eco BP during this period



- Eco Max = 550MW
- No change in Eco BP during this period



- Point A
 - Starting MW = 150.5
- Point B
 - Expected MW= 152.4
 - Actual MW= 150.3
- Response
 - Expected: $152.4 - 150.5 = 1.9\text{MW}$
 - Actual: $150.3 - 150.5 = -0.2\text{MW}$
- Performance Assessment
 - $1 - (\text{Expected MW} - \text{Actual MW}) / (\text{Expected MW})$
 - $1 - ((1.9 - -0.2) / 1.9) = -11\%$
 - **FAIL**

Performance Assessment for Primary Frequency Response

PFRSTF

December 1, 2017



- Resources expected performance will be calculated with the primary frequency control calculation

- Frequency below governor dead band

$$MW_{PrimaryControl} = \left[\frac{(HZ_{actual} - 60 + DB)}{(60 * Droop - DB)} \right] * (FrequencyResponsiveCapacity) * (-1)$$

- Frequency above governor dead band

$$MW_{PrimaryControl} = \left[\frac{(HZ_{actual} - 60 - DB)}{(60 * Droop - DB)} \right] * (FrequencyResponsiveCapacity) * (-1)$$

- 36mHz deadband (or less), 5% droop (or less)

- Calculation will be performed with 36mHz and 5% droop unless different settings are communicated to PJM

- Threshold will be set to determine Pass/Fail assessment
 - Unit will need to provide 50% of expected response to Pass (in MW)
 - Pass/Fail assessment will be down on a quarterly basis looks at a 12 month rolling window
 - Response measured within 20-52 seconds (alignment with BAL-003-1)
 - Sustain frequency response out to 60 seconds or duration of event
- Pass/Fail assessment due to some data quality
 - 10 second scan rates
 - Data dead band storage in historian
- Assessments will be performed on market units
 - Further breakdown assessments will be available upon request

- PJM will reserve the right to perform performance assessment between 25-35 times a year
 - PJM will aim to find 2 frequency events per month for performance assessments, however system conditions may provide less opportunities – no set number of events will be prescribed
 - Events selected will be ‘clean’ frequency excursions where frequency went outside the dead band and engaged governors
 - Frequency outside $\pm 40\text{mHz}$
 - Frequency stays outside of dead band for 60 seconds
 - PJM will aim to select events in both directions
 - Events with high frequency (above 60.04) and events with low frequency (below 59.96)

- Process for non-performance
 - PJM will review first failed PFR assessment with stakeholder to discuss details of failed response
 - This is to ensure that failed attempt is not due to data issues, maintenance issues, etc.
 - This is a one-time review for PJM and the participant to work through any issues that are uncovered
 - Subsequent failed PFR assessment will be referred to IMM/FERC for follow-up
 - Participants will have the opportunity to provide data to document performance before referral if data issues are assumed for the failure
 - No monthly payments for cost of service until demonstrated successful performance (TBD based on compensation discussion)

- When we will evaluate a resource to provide PFR:
 - Unit is operating between **Eco Min+5%** and **Eco Max-5%**
 - Example a unit with a Eco Min of 50MW and Eco Max of 300MW would be evaluated for PFR performance between 52.5MW and 285MW
 - And Unit is online providing energy and has available headroom (for low frequency periods) or foot room (for high frequency periods)
 - And/Or Unit is assigned reserves

- When we will not evaluate a resource to provide PFR:
 - Unit is not currently providing real-time energy/reserves
 - Or Unit is not operating between Eco Min and Eco Max
 - Or Unit has an exception
 - Long-term exception developed through the exception process
 - Short-term exception based on current operating parameters
 - Documented in EDART – max 30 day exception
 - Or Unit is providing regulation

