

4.5.8 Performance Scores for Regulation Resources During a Synchronized Reserve Event

Regulation Resources choosing to respond to a Synchronized Reserve event will receive synchronized reserve compensation based on Manual 11, Section 4.2.11.

Resources that choose to respond to a reserve event for their reserve zone in an hour when they are cleared or assigned regulation are expected to return to their regulating band within 10 minutes of the end of the Synchronized Reserve event. From the start of the event, through the event, and for the 10 minutes after the end of the event, the performance scores for all regulating resources in the reserve zone where the Synchronized Reserve Event takes place will be null.

PJM Actions:

- PJM logs the time of the start and end of a Synchronized Reserve event.
- PJM will score performance for all regulating resources as null for the period during the Synchronized Reserve event and 10 minutes after the end of the event for those resources in that reserve zone.

PJM Member Actions:

- If the resource owner chooses to respond to an event the resource will return to the regulating band as soon as possible after the end of the reserve event.

4.1.2 Loading Reserves

PJM Member Actions:

~~The r~~Resource owners that elect to use their assets to respond to an event shall, without regard to price and as quickly as possible, load the requested percentage of Synchronized Reserve and Non-Synchronized Reserve. PJM Members *responding to the event* will continue to load resources until directed by PJM dispatcher to discontinue. Resources providing regulation service should only provide Synchronized Reserves to the extent that they can quickly resume accurate regulation control following the event.