



Manual 13, Revision 85

Emergency Operations

Chris Piong
Operations Planning
Markets & Reliability Committee
February 24, 2022

- To address concerns with fuel and emissions that emerged in recent months, PJM made a temporary change to M-13 Section 6.4 in the ‘Note’ to modify the remaining hours under which a resource may be offered as Maximum Emergency Generation.
- This ‘Note’ has an expiration date of 4/1 but needs to be extended to allow PJM and stakeholders additional time to work on a more permanent solution.
 - The additional work is being requested to take place under a new Issue Charge titled “Max Emergency Changes for Resource Limitations”

Note:

- Steam Units: During the interim period expiring no later than **the completion of the key work activities associated with the “Max Emergency Changes for Resource Limitations” Issue Charge are completed, April 1, 2022** PJM may request the resource owner to move fuel or emissions limited steam units into the Maximum Emergency category if the resource’s remaining run hours fall below 240 hours (10 days). Unless needed for reliability, the units would remain in Maximum Emergency status until their inventory rose above 21 days (504 hours). This would only be implemented to address concerns with local or regional reliability.
- CT Units: During the interim period expiring no later than **the completion of the key work activities associated with the “Max Emergency Changes for Resource Limitations” Issue Charge are completed, April 1, 2022** PJM may request the resource owner to move emissions limited CT units into the Maximum Emergency category if the resource’s remaining run hours on all fuel types fall or are expected to fall below 24 hours. Unless needed for reliability, the units would remain in Maximum Emergency status until the run hours increased above 24hrs.

SME/Presenter:

Chris Piong,
Christopher.piong@pjm.com

SME:

Donnie Bielak,
Donnie.bielak@pjm.com

Manual 13, Rev 83



Member Hotline

(610) 666 – 8980

(866) 400 – 8980

custsvc@pjm.com

**PROTECT THE
POWER GRID
THINK BEFORE
YOU CLICK!**



Be alert to
malicious
phishing emails.

Report suspicious email activity to PJM.
(610) 666-2244 / it_ops_ctr_shift@pjm.com

