

# Subregional RTEP Committee – Mid-Atlantic FirstEnergy (Penelec) Supplemental Projects

April 14, 2021

# Solutions

Stakeholders must submit any comments within 10 days of this meeting in order to provide time necessary to consider these comments prior to the next phase of the M-3 process

**Need Number:** PN-2020-014

**Process Stage:** Solution Meeting 04/14/2021

**Previously Presented:** Need Meeting 05/22/2020

**Project Driver:**

*Equipment Material Condition, Performance and Risk  
Operational Flexibility and Efficiency*

**Specific Assumption Reference:**

System Condition Projects

- Line Condition Rebuild/Replacement
  - Transmission Line Switches

System Performance Projects

- Substation/line equipment limits
- Load at risk in planning and operational scenarios


**Problem Statement:**

The Raystown – McConnellstown 46 kV line has three in-line switches (A-136, A-137, and A-139) that are in degraded condition and have limited availability of spare parts. The existing switches have operational limitations. The motor control units are no longer supported by the manufacturer. Inability to sectionalize this line results in loss of approximately 9MW of load and approximately 1,136 customers, including a REA.

Transmission line ratings are limited by terminal equipment.

- Allegheny Hydro Tap – Allegheny Hydro 46 kV line rating is limited by the transmission line conductor 52 / 62 MVA (SN/SE).
- Allegheny Hydro Tap – RAM Junction 46 kV line rating is 55 / 69 MVA (SN/SE) and the transmission line conductor rating is 59 / 71 MVA (SN/SE). (disconnect switch)
- RAM Junction – Piney Ridge 46 kV line rating is 55 / 69 MVA (SN/SE) and the transmission line conductor rating is 59 / 71 MVA (SN/SE). (disconnect switch)

**Model:** 2020 RTEP model for 2025 Summer (50/50)





# Penelec Transmission Zone M-3 Process Raystown – McConnellstown 46 kV Switch Replacements

**Need Number:** PN-2020-014

**Process Stage:** Solution Meeting 04/14/2021

**Proposed Solution:**

**Raystown – McConnellstown 46 kV Switch Replacements**

- Replace in-line switches A-136, A-137, and A-139

**Transmission Line Ratings:**

- Allegheny Hydro Tap – Allegheny Hydro 46 kV Line
  - Before Proposed Solution: 52 / 62 MVA (SN/SE)
  - After Proposed Solution: 52 / 62 MVA (SN/SE)
- Allegheny Hydro Tap – RAM Junction 46 kV Line
  - Before Proposed Solution: 55 / 69 MVA (SN/SE)
  - After Proposed Solution: 59 / 71 MVA (SN/SE)
- RAM Junction – Piney Ridge 46 kV Line
  - Before Proposed Solution: 55 / 69 MVA (SN/SE)
  - After Proposed Solution: 59 / 71 MVA (SN/SE)

**Alternatives Considered:**


- Maintain existing condition

**Estimated Project Cost:** \$1.5M

**Projected In-Service:** 12/31/2022

**Project Status:** Conceptual

**Model:** 2020 Series 2025 Summer RTEP 50/50



Legend	
500 kV	
345 kV	
230 kV	
138 kV	
115 kV	
69 kV	
46 kV	
34.5 kV	
23 kV	
New	



**Need Number:** PN-2021-002

**Process State:** Solution Meeting 4/14/2021

**Previously Presented:** Need Meeting 3/18/2021

**Project Driver:**


*Customer Service*

**Specific Assumption Reference:**

New customer connection requests will be evaluated per FirstEnergy’s “Requirements for Transmission Connected Facilities” document and “Transmission Planning Criteria” document.

**Problem Statement:**

New Customer Connection - A customer requested 46 kV service for load of approximately 12 MW near the Greenwood – Tipton 49 kV line. Requested in-service date is 7/2021.



**Need Number:** PN-2021-002

**Process State:** Solutions Meeting 4/14/2021

**Proposed Solution:**

Provide 46 kV Service:

- Tap the Greenwood – Tipton 46 kV line (Gardner Denver Tap – Gardner Denver 46 kV line segment)
- Construct one span of 46 kV line
- Install one 46 kV revenue metering package
- Install two 1200 A SCADA controlled disconnect switches
- Add SCADA to one existing switch

**Alternatives Considered:**


- None

**Estimated Project Cost:** \$1.4M

**Projected In-Service:** 7/1/2021

**Project Status:** Engineering

**Model:** 2020 RTEP model for 2025 Summer (50/50)



Legend	
500 kV	
345 kV	
230 kV	
138 kV	
115 kV	
69 kV	
46 kV	
34.5 kV	
23 kV	
New	

# Questions?



# Appendix



# High level M-3 Meeting Schedule

Assumptions	Activity	Timing
	Posting of TO Assumptions Meeting information	20 days before Assumptions Meeting
	Stakeholder comments	10 days after Assumptions Meeting
Needs	Activity	Timing
	TOs and Stakeholders Post Needs Meeting slides	10 days before Needs Meeting
	Stakeholder comments	10 days after Needs Meeting
Solutions	Activity	Timing
	TOs and Stakeholders Post Solutions Meeting slides	10 days before Solutions Meeting
	Stakeholder comments	10 days after Solutions Meeting
Submission of Supplemental Projects & Local Plan	Activity	Timing
	Do No Harm (DNH) analysis for selected solution	Prior to posting selected solution
	Post selected solution(s)	Following completion of DNH analysis
	Stakeholder comments	10 days prior to Local Plan Submission for integration into RTEP
	Local Plan submitted to PJM for integration into RTEP	Following review and consideration of comments received after posting of selected solutions

# Revision History

4/2/2021 – V1 – Original version posted to pjm.com