

# Subregional RTEP Committee – Western FirstEnergy Supplemental Projects

August 16, 2021

# Needs

Stakeholders must submit any comments within 10 days of this meeting in order to provide time necessary to consider these comments prior to the next phase of the M-3 process

**Need Number:** APS-2021-007

**Process Stage:** Need Meeting 08/16/2021

**Project Driver:**

*Equipment Material Condition, Performance and Risk*


**Specific Assumption Reference:**

*Global Factors*

- System reliability and performance
- Substation and line equipment limits
- Upgrade Relay Schemes
  - Relay schemes that have a history of misoperation
  - Obsolete and difficult to repair communication equipment (DTT, Blocking, etc.)
  - Communication technology upgrades
  - Bus protection schemes

**Problem Statement:**

- FirstEnergy has identified protection schemes using a certain vintage of relays and communication equipment that have a history of misoperation.
  - Proper operation of the protection scheme requires all the separate components perform properly together during a fault
  - The identified protection equipment cannot be effectively repaired for reasons such as lack of replacement parts and available expertise in the outdated technology.
  - Newer equipment provides better monitoring, enhances capability of system event analysis, and performs more reliably
- Transmission line ratings are limited by terminal equipment
- Oak Grove – Parkersburg 638 138 kV Line (substation conductor)
- Existing line rating: : 225 / 287 MVA (SN / SE)
  - Existing Transmission conductor rating: 309 / 376 MVA (SN / SE)



**Need Number:** APS-2021-008

**Process Stage:** Need Meeting 08/16/2021

**Project Driver:**

*Equipment Material Condition, Performance and Risk*


**Specific Assumption Reference:**

*Global Factors*

- System reliability and performance
- Substation and line equipment limits
- Upgrade Relay Schemes
  - Relay schemes that have a history of misoperation
  - Obsolete and difficult to repair communication equipment (DTT, Blocking, etc.)
  - Communication technology upgrades
  - Bus protection schemes

**Problem Statement:**

- FirstEnergy has identified protection schemes using a certain vintage of relays and communication equipment that have a history of misoperation.
- Proper operation of the protection scheme requires all the separate components perform properly together during a fault
- The identified protection equipment cannot be effectively repaired for reasons such as lack of replacement parts and available expertise in the outdated technology.
- Newer equipment provides better monitoring, enhances capability of system event analysis, and performs more reliably
  
- Transmission line ratings are limited by terminal equipment Belmont - Trissler 648 138 kV Line(substation conductor)
  - Existing line rating: 293 / 342 MVA (SN / SE)
  - Existing Transmission conductor rating: 309 / 376 MVA (SN / SE)



**Need Number:** APS-2021-009

**Process Stage:** Need Meeting 08/16/2021

**Project Driver:**

*Equipment Material Condition, Performance and Risk*


**Specific Assumption Reference:**

*Global Factors*

- System reliability and performance
- Substation and line equipment limits
- Upgrade Relay Schemes
  - Relay schemes that have a history of misoperation
  - Obsolete and difficult to repair communication equipment (DTT, Blocking, etc.)
  - Communication technology upgrades
  - Bus protection schemes

**Problem Statement:**

- FirstEnergy has identified protection schemes using a certain vintage of relays and communication equipment that have a history of misoperation.
- Proper operation of the protection scheme requires all the separate components perform properly together during a fault
- The identified protection equipment cannot be effectively repaired for reasons such as lack of replacement parts and available expertise in the outdated technology.
- Newer equipment provides better monitoring, enhances capability of system event analysis, and performs more reliably
  
- Transmission line ratings are limited by terminal equipment  
French Creek - Pickens 56 138 kV Line (substation conductor)
  - Existing line rating: 293 / 306 MVA (SN / SE)
  - Existing Transmission conductor rating: 308 / 376 MVA (SN / SE)



# APS Transmission Zone M-3 Process Buckhannon - Pruntytown 138 kV Line

**Need Number:** APS-2021-010

**Process Stage:** Need Meeting 08/16/2021

**Project Driver:**

*Equipment Material Condition, Performance and Risk*


**Specific Assumption Reference:**

*Global Factors*

- System reliability and performance
- Substation and line equipment limits
- Upgrade Relay Schemes
  - Relay schemes that have a history of misoperation
  - Obsolete and difficult to repair communication equipment (DTT, Blocking, etc.)
  - Communication technology upgrades
  - Bus protection schemes

**Problem Statement:**

- FirstEnergy has identified protection schemes using a certain vintage of relays and communication equipment that have a history of misoperation.
- Proper operation of the protection scheme requires all the separate components perform properly together during a fault
- The identified protection equipment cannot be effectively repaired for reasons such as lack of replacement parts and available expertise in the outdated technology.
- Newer equipment provides better monitoring, enhances capability of system event analysis, and performs more reliably
  
- Transmission line ratings are limited by terminal equipment  
Buckhannon - Pruntytown 12 138 kV Line(substation conductor)
  - Existing line rating: 164 / 206 MVA (SN / SE)
  - Existing Transmission conductor rating: 221 / 268 MVA (SN / SE)



**Need Number:** APS-2021-012

**Process Stage:** Need Meeting 08/16/2021

**Project Driver(s):**

*Customer Service*


**Specific Assumption Reference(s)**

New customer connection request will be evaluated per FirstEnergy’s “Requirements for Transmission Connected Facilities” document and “Transmission Planning Criteria” document.

**Problem Statement**

New Customer Connection – A customer requested 138 kV service. Anticipated load is 40 MVA. Location is approximately seven miles from the Arch Coal Wolf Run (Leer South) Tap and approximately four miles from the Pruntytown 138 kV Substation on the Buckhannon – Pruntytown (PR-BKH-12) 138 kV Line.

Requested in-service date is September 1, 2022.



# High Level M-3 Meeting Schedule

Assumptions	Activity	Timing
	Posting of TO Assumptions Meeting information	20 days before Assumptions Meeting
	Stakeholder comments	10 days after Assumptions Meeting
Needs	Activity	Timing
	TOs and Stakeholders Post Needs Meeting slides	10 days before Needs Meeting
	Stakeholder comments	10 days after Needs Meeting
Solutions	Activity	Timing
	TOs and Stakeholders Post Solutions Meeting slides	10 days before Solutions Meeting
	Stakeholder comments	10 days after Solutions Meeting
Submission of Supplemental Projects & Local Plan	Activity	Timing
	Do No Harm (DNH) analysis for selected solution	Prior to posting selected solution
	Post selected solution(s)	Following completion of DNH analysis
	Stakeholder comments	10 days prior to Local Plan Submission for integration into RTEP
	Local Plan submitted to PJM for integration into RTEP	Following review and consideration of comments received after posting of selected solutions



# Revision History

08/05/2021 – V1 – Original version posted to pjm.com