

Transmission Expansion Advisory Committee (TEAC)

Recommendations to the PJM Board

PJM Staff Whitepaper
December 2017



EXECUTIVE SUMMARY

On October 18, 2017 the PJM Board of Managers approved changes to the Regional Transmission Expansion Plan (RTEP), totaling \$1,019.41 million, primarily to resolve baseline reliability criteria violations.

Since that time PJM identified additional baseline reliability criteria violations within the planning horizon as part of the 2017 RTEP. Transmission upgrades have been identified to resolve these reliability criteria violations. The increase in the RTEP to include the upgrades to resolve the new baseline reliability criteria violations is \$348.85 million. PJM has also identified a market efficiency upgrade to address capacity market congestion. The increase in the RTEP to include the market efficiency upgrade is \$0.6 million.

PJM staff is, for the first time, recommended several interregional projects with MISO under the recently approved Targeted Market Efficiency Project (TMEP) type. PJM and MISO recommended five projects with a total estimated cost of \$19.92 million and an estimated market efficiency benefit of \$99.6 million. Four of the projects are in MISO. One project in the ATSI zone of PJM has an estimated cost of \$1 million.

In addition, a number of previously approved baseline projects have been cancelled or the cost and scope has changed resulting in a net increase of \$77.07 million. The net impact due to baseline reliability changes is an increase of \$427.52 million.

PJM staff has also completed 252 new interconnection queue impact studies and 257 projects have withdrawn from the interconnection queue. The net impact of these changes to the interconnection queue is a net increase in the RTEP of \$ 2,404.24 million.

The total change in the RTEP to include these baseline RTEP changes and interconnection queue changes is a net increase of \$2,831.76 million.

With these changes, the RTEP will include over \$35,110.50 million of transmission additions and upgrades since the first plan was approved by the Board in 2000.

The projects are summarized in the following paper and were presented for the Board Reliability Committee's consideration and for recommendation to the Board for approval.



Summary of Results

2017 Baseline Transmission Upgrades Changes and Additions

One aspect of the development of the Regional Transmission Expansion Plan is an evaluation of the “baseline” system, i.e. the transmission system without any of the generation interconnection requests included in the current planning cycle. This baseline analysis determines the compliance of the existing system with reliability criteria and standards. Transmission upgrades required to maintain a reliable system are identified and reviewed with stakeholders through the Transmission Expansion Advisory Committee (TEAC) and Subregional RTEP Committees. The cost of transmission upgrades to mitigate such baseline reliability criteria violations are the responsibility of the PJM load customers.

2017 RTEP Proposal Window #1

On July 11 of this year PJM opened a 45-day proposal window, which closed on August 25. This window solicited proposals for PJM reliability criteria violations based on forecast 2022 summer, winter and light load conditions. PJM reliability criteria violations included Baseline N-1 (thermal and voltage), Generation Deliverability, Common Mode Outage, N-1-1 (thermal and voltage), and Load Deliverability (thermal and voltage) violations. PJM staff identified potential reliability criteria violations associated with 190 flowgates (monitored transmission facility and contingency/outage pairs). Of the 190 flowgates, 150 flowgates were excluded from the proposal window. The exclusion were based on immediate need criteria (needs to resolve a violation within the next 3 years) and, for the first time, below the 200kV threshold criteria (per PJM OA 1.5.8(n)). The remaining 40 flowgates formed the substance of the proposal window.

A total of 51 proposals were received from 10 entities, including incumbent transmission owners and non-incumbent transmission developers. 29 of the proposals represented greenfield construction and 22 were transmission owner upgrades.

The locations of the violations associated with Proposal Window #1 are shown below in Figure 1, while Figure 2 identifies the location of the proposals that were submitted for Proposal Window #1.




Figure 1. Location of violations for Proposal Window #1




Figure 2. Location of submitted proposals for Window #1

PJM staff reviewed details of all proposals, including an evaluation of the effectiveness of each of the proposals, with stakeholders through the Transmission Expansion Advisory Committee (TEAC). PJM completed evaluation of most of the proposals, and is recommending eight projects at this time: four in the APS zone, two in the AEP zone and two in Dominion. Each of these projects is an upgrade submitted by the incumbent transmission owner. The work includes re-conductoring, upgrading terminal equipment, and reconfiguring existing lines.

The immediate need baseline reliability projects include transmission enhancements with a need date of 3 years or less. Due to the critical timing of immediate need projects, PJM did not have time to administer a proposal window to solicit alternative solutions from PJM stakeholders for the associated reliability drivers. The immediate need projects are being driven by several main categories of criteria drivers. The project drivers include short circuit issues to which the most efficient solution is typically a Transmission Owner upgrade of the associated breaker, new block load additions, Transmission Owner local criteria, generation deliverability issues in the Rochelle Municipal Utilities (a muni within the ComEd transmission zone) due to line rating updates, stability issues in the PPL and JCPL transmission zones, and a PJM operational performance issue.

Reliability Project Summary

A summary of the more significant baseline projects with estimated costs equal to or greater than \$5 million are detailed below. A complete listing of all of the projects that are being recommended is included as Attachments A and B to this white paper. The projects with estimated costs less than \$5 million include



transmission line cut in and re-conductoring, modifications to existing protection systems, new transmission switches, circuit breaker replacements, new circuit breakers, modification to transformer, and modifications to existing substation equipment.

Mid-Atlantic Region System Upgrades

- PSEG Transmission Zone
 - VFT – Warinanco - Aldene 230 kV Line Rebuild - \$90.4M
 - Cedar Grove – Jackson Rd. 230 kV Line Re-conductor - \$80M
- AE Transmission Zone
 - BL England – Middle Tap 138 kV Line Rebuild - \$36.4M
- PenElec Transmission Zone
 - North Meshoppen 230/115 kV transformer #3 - \$6.802M

Western Regional System Upgrades

- ComEd Transmission Zone
 - Schauff Road – Rock Falls 138kV Line Construction - \$20.0M
- AEP Transmission Zone
 - Hazard – Wooten 161kV Line Rebuild - \$16.48M
 - Sand Hill 138kV Ring Bus – \$7.25M
- APS Transmission Zone
 - Convert the existing 6 wire Butler - Shanor Manor - Krendale 138 kV Line into two separate 138 kV lines, Reconductor the Yukon - Smithton - Shepler Hill Jct 138 kV Line with 795 ACSS Conductor, Reconductor the Charleroi –Allenport 138KV Line with 954 ACSR - \$17.23M
 - Install new 230 / 138 kV transformer at Catoctin substation. Convert Ringgold-Catoctin 138 kV Line to 230 kV operation - \$13.33M

Southern Region System Upgrades

- Dominion Transmission Zone
 - Fixed Series Capacitors on Line #547, 548 - \$28.9M
 - Chesterfield - Locks & Chesterfield – Poe 230kV Lines Rebuild - \$9.5M

Following is a more detailed description of the larger scope upgrades that are being recommended to the PJM Board for their consideration. A description of the criteria driving the need for the upgrade as well as the required in-service date is provided.

Baseline Project b2955 – VFT – Warinanco - Aldene 230 kV Line Rebuild

Generation Deliverability analysis identified a number of overloads on lines around Warinanco and Linden areas. Due to the immediacy of the need, the work will be allocated to the incumbent transmission operator. The recommended solution is the rebuild the VFT – Warinanco – Aldene 230kV line using a dual conductor construction to increase ampacity of the line. The estimated cost of the project is \$90.4M and the project schedule is still being developed.

The map in Figure 3 shows the location of the recommended project.




Figure 3. Location of PJM baseline b2955



Baseline Project b2956 – Cedar Grove – Jackson Rd. 230 kV Line Re-conductor

Generation deliverability analysis identified an overload of the Cedar Grove – Jackson Rd 230kV line. Flows on this line have increased due to the ending of the NYISO wheel agreement and the retirement of the Hudson generation station. The existing line is underground and conductor is a HPFF type conductor with an internal circulating cooling fluid. Due uncertainty of continued manufacturer support of the system replacement in kind is not preferred. Converting the line to overhead construction is prohibitive as obtaining ROW would be costly and time consuming. The recommended solution is to replace the existing HPFF cable with XLPE (solid dielectric) cables. The estimated cost is \$80.0M and the required in-service date is June 2018.

The map in Figure 4 shows the location of the recommended project.




Figure 4. Location of PJM baseline b2956

Baseline Project b2945 – BL England – Middle Tap 138 kV Line Rebuild

The 2017 RTEP analysis identified generation deliverability and N-1-1 thermal criteria violations on the BL England – Middle Tap 138kV line. The recommended solution is to rebuild the entire 10.1 mi. of the line to increase the line rating. Since the BL England – Merion (1.9 mi) and the Merion – Corson (8.0 mi) 138kV lines share the lattice towers with the BL England – Middle Tap line, those lines will be re-conducted as part of this project. The total cost of the project is expected to be \$36.4M and is required by June of 2022.

The map in Figure 5 shows the location of the recommended project.




Figure 5. Location of PJM baseline b2945

Baseline Project b2952 – North Meshoppen 230/115 kV transformer #3

The 2017 RTEP generation deliverability analysis revealed overloading of the North Meshoppen 230-115kV transformer #3 for two contingencies. The recommended solution is to replace the transformer with a higher capacity transformer. The solution also calls for removing an existing reactor which will no longer be needed and the installation of two circuit breakers to complete the station’s ring bus, which will enhance reliability of the station. The project is expected to cost \$6.8M and required to be in-service by June 2022.

The map in Figure 6 shows the location of the recommended project.




Figure 6. Location of PJM baseline b2952

Baseline Project b2959 – Schauff Road – Rock Falls 138kV Line Construction

Queue projects O-09 and O-29 are now active after being suspended for many years. Including these generators in the 2017 RTEP resulted in numerous base case and single contingency violations in the area of these projects. Due to the immediacy of the need, this work has been allocated to the incumbent transmission operator. The recommended solution builds a new 138kV line between Schauff Road and Rock Falls and a new breaker and half bay at the Schauff Road station. The project cost estimate is \$20M and is required in-service by November 2019.

The map in Figure 7 shows the location of the recommended project.




Figure 7. Location of PJM baseline b2959

Baseline Project b2761.3 – Hazard – Wooten 161kV Line Rebuild

Generation deliverability analysis revealed overloads of the Hazard – Wooten 161kV line under summer and winter peak loads. These overloads were identified in the 2016 RTEP study and included in Proposal Window #2. The approved action was to perform a sag study in the hope of increasing the operating temperature of the line. The sag study instead revealed that 40 of the 45 line structures needed be replaced meet clearance requirements at the higher temperature. The line also has 52 Category A open conditions. The line was originally built in 1943 so all of components of the line are aging and should be replaced. Therefore, at this time, the recommendation is to rebuild the line to current standards. The cost to rebuild the 6.5 mi. line is estimated at \$16.5M and is expected to be in-service by June 2021.

The map in Figure 8 shows the location of the recommended project.




Figure 8. Location of PJM baseline b2761.3

Baseline Project b2958 – Sand Hill 138kV Ring Bus

Due to a planned demand increase of a large customer, local planning criteria identified a number of thermal, voltage and deliverability violations in the area of the Sand Hill station. The recommended solution is to break the nearby George Washington – Tidd 138kV line and terminate each end to the Sand Hill station. The total cost of the work is estimated to be \$7.25M and is expected to be in-service by December 2018.

The map in Figure 9 shows the location of the recommended project.




Figure 9. Location of PJM baseline b2958

Baseline Projects B2965, B2966, B2967 - Convert the existing 6 wire Butler - Shanor Manor - Krendale 138 kV Line into two separate 138 kV lines, Reconductor the Yukon - Smithton - Shepler Hill Jct 138 kV Line with 795 ACSS Conductor, Reconductor the Charleroi –Allenport 138KV Line with 954 ACS

Figure 10 shows the location of these 2017 Window #1 projects.




Figure 10. Location of PJM baseline b2965, b2966, and b2967

A number of generation deliverability violations (13) were identified in the south western Pennsylvania area of the APS and Duquesne transmission zones. Thermal overloads of the Butler – Shanor Manor – Krendale, Yukon – Smithton, and Smithton – Shepler Hill Jct Tap 138kV lines were identified for a variety of contingencies.

The recommended solutions will re-conductor two 138kV lines, Charleroi – Allenport and Yukon - Smithton - Shepler Hill Jct. The 6-wire Butler - Shanor Manor - Krendale 138 kV line will be separated into two 138kV lines. The costs for the each project will be \$7.08M, \$3.19M, and \$6.96M, respectively, for a total cost of \$17.23M.

Baseline Project b2970 - Install new 230 / 138 kV transformer at Catoctin substation. Convert Ringgold-Catoctin 138 kV Line to 230 kV operation.

Figure 11 shows the location of this 2017 Window #1 project.




Figure 11. Location of PJM baseline b2970

The Ringgold 230/138kV transformers #3 and #4 are overloaded for multiple contingencies. The recommended solution is to install a new 230-138kV transformer at the Catoctin substation and convert the Ringgold-Catoctin line to 230kV operation. The total cost of the project is \$13.3M.

Baseline Project b2960 – Fixed Series Capacitors on Line #547, 548

Series capacitors on the 500kV lines into Bath County (#547 and #548) have reached local criteria for end of life. The need for the capacitors has not ended. The capacitors are no longer manufactured and spare parts have become difficult to obtain. In addition the capacitor banks are the limiting element on the line. The recommended solution is to replace the capacitors with newer models with a higher current rating. Estimated project cost is \$28.9M and the capacitors are expected to be in-service by April 2002.

The map in Figure 12 shows the location of the recommended project.




Figure 12. Location of PJM baseline b2960

Baseline Project b2961 – Chesterfield - Locks & Chesterfield – Poe 230kV Lines Rebuild

A 3 mi. section (between Chesterfield and Tyler) of these double circuited lines meets local owner end-of-life criteria. This section of line was built in 1962 using “corten” weathering steel. These structures have exhibited accelerated deterioration and are in poor condition. Loss of these lines would result in 140MW permanent load loss. The recommended solution is to rebuild the line to current standards. The proposed 2-636 ACSR conductor would increase the summer emergency rating of this section of line from 478MVA to 1047MVA. The project is estimated to cost \$9.5M and should be in-service by the end of 2022.

The map in Figure 13 shows the location of the recommended project.




Figure 13. Location of PJM baseline b2961



PJM – MISO Interregional Targeted Market Efficiency Projects

PJM has conducted formal interregional planning with MISO under the Joint Operating Agreement (JOA) for many years. These activities include interconnection queue coordination, generation deactivation studies and other reliability assessments, as well as evaluation of future congestion between the RTOs. The first large joint interregional effort to examine congestion on the PJM/MISO interface was conducted in 2013 and 2014. No interregional projects were identified that satisfied the criteria specified in the JOA which limited potential interregional projects to large scope projects on the 345 kV and higher systems. A review of the actual historic congestion on the system showed that many of the constraints were on below 345 kV facilities and could be resolved with incremental upgrades to existing facilities. Since completing the study in 2014 PJM has worked closely with MISO and stakeholders to eliminate barriers in the JOA to addressing congestion along the seam.

In mid-2015, PJM and MISO began discussions of a new project type aimed at quickly addressing Market-to-Market (M2M) congestion on Reciprocally Coordinated Flowgates. Reciprocally Coordinated Flowgates are jointly controlled by PJM and MISO through coordinated dispatch to maintain flows within applicable limits. After the fact, the cost of this most efficient joint dispatch is settled between PJM and MISO based on each party's Firm Flow Entitlements and the actual use of the congested facilities.

Working with the Interregional Planning Stakeholder Advisory Committee (IPSAC), PJM and MISO developed criteria for a new project type which focus the study on developing low cost, short lead-time, high impact projects. The study is intended to be conducted annually, as part of a Coordinated System Plan study, as deemed needed by PJM and MISO, with stakeholder input. The resultant project type, called Targeted Market Efficiency Projects (TMEPs) are intended to complement, not replace, the longer term Market Efficiency Project (MEP) process.

Throughout 2016 PJM and MISO worked with stakeholders to develop and formalize the TMEP project type in the JOA. The TMEP project type can be summarized as follows:

- Limited to historically binding M2M flowgates
- Limited to M2M congestion that is not driven by temporary transmission outages
- Limited to M2M congestion that will not be remedied by already planned upgrades
- Projects must be in service by 3rd summer peak after project approval
- Projects over \$20 million not eligible (must go through MEP process)
- Benefits based on relieving projected congestion equal to the average of 2 years of historical congestion (DA + Balancing/ECF¹)
- Four years' worth of projected benefits must completely cover project's installed capital cost
- Interregional cost allocation based on the assumed average two-year historical congestion relief in each RTO – Adjusted by M2M payments
- Each TMEP must be approved as an RTEP project in PJM and an MTEP project in MISO.

¹ Excess Congestion Fund, MISO term for Balancing Congestion



PJM and MISO filed changes to the JOA in December 2016 to formalize this new project type. On October 3, 2017 PJM and MISO received conditional approval from FERC for the requested changes pending a minor compliance filing which was filed on November 2, 2017.

In parallel with the development of the final JOA language, the RTOs worked with the IPSAC to complete the first iteration of the TMEP study. PJM and MISO initially identified fifty (50) M2M flowgates which had historically significant congestion (greater than \$1 million). The 50 initial flowgates were trimmed down by eliminating congestion issues caused by outages or that would be mitigated by planned upgrades that were already included in the RTEP or MISO's MTEP. The RTOs then worked with the facility owners to identify the limiting equipment on these congested elements and determine the upgrades required to increase the facility rating. Potential feasible short term upgrades were identified for thirteen (13) facilities. PJM and MISO conducted market efficiency and power-flow based analyses to determine the efficacy of the thirteen potential upgrades in eliminating the identified congestion. If a potential upgrade produced more congestion (i.e. moved the constraint to a downstream facility) and significantly complicated the project, the proposal was referred to the long-term interregional MEP process.

As a result of this analysis, and considering the other TMEP criteria, the RTOs are recommending five (5) TMEPs for approval. These five upgrades have been discussed with the Interregional Planning Stakeholder Advisory Committee (i.e. IPSAC), PJM TEAC, and MISO PAC, and, are being recommended to both the PJM and MISO boards for approval.

PJM and MISO are jointly recommending the five projects shown in Table 1 and whose locations are shown in Figure 14. Location of five recommended TMEPs. The total estimated cost of these five projects is \$19.92 million, with a TMEP benefit of \$99.6 million, for an average B/C ratio of 5.0. Considering the interregional cost allocation, the total cost allocated to PJM for these projects will be \$13.7 million.

The projects are being separately taken to the PJM and MISO Boards. MISO's board is expected to vote on this same package of TMEPs on December 5th. If approved by both RTO's Boards, the projects will be included in each regional plan. PJM will notify ATSI of their responsibility to construct project b2972. MISO will coordinate construction responsibility with NIPSCO for the remaining projects. The RTO's will use existing interregional billing mechanisms identified in the tariff to assess and collect costs for the interregional cost splits.

Table 1. Summary of five recommended TMEPs

| Facility | Transmission Owner | TMEP Cost (Million \$) | TMEP Benefit (Million \$) | Benefit Allocation (%PJM/%MISO) |
|---------------------------------|--------------------|------------------------|---------------------------|---------------------------------|
| Burnham - Munster 345kV | CE - NIPS | 6.7 | 32 | 88/12 |
| Lallendorf - Monroe 345kV | ATSI - ITC | 1 | 17 | 89/11 |
| Michigan City – Bosserman 138kV | NIPS - AEP | 6.0 | 29.6 | 90/10 |
| Reynolds-Magnetation 138kV | NIPS | 0.12 | 14.5 | 41/59 |

| | | | | |
|------------------------|------|-----|-----|-------|
| Roxana - Praxair 138kV | NIPS | 6.1 | 6.5 | 24/76 |
|------------------------|------|-----|-----|-------|




Figure 14. Location of five recommended TMEPs

Baseline Project b2971 – Reconfigure Munster 345kV (NIPSCO) as a ring bus and replace terminal equipment.

This project increases the rating on Burnham – Munster 345kV, to address historical M2M congestion on that facility.

The estimated cost is \$6.7 million and the project will provide an estimated \$32 million in congestion relief benefits in the first 4 years of operation. 88% of the cost (\$5.9 million) will be allocated to PJM. The projected in service date is June 1, 2020. MISO will designate the local Transmission Owner, NIPSCO, to complete this work.

Baseline Project b2972 – Partial reconductor of Lallendorf – Monroe 345kV (ATSI – ITC)

This project replaces ATSI owned conductor on the span of the Lallendorf - Monroe 345kV (ATSI – ITC tie) line where it crosses the Muamee River. This increases the rating on Lallendorf - Monroe 345kV to address historical M2M congestion on that facility.



The estimated cost is \$1 million and the project will provide an estimated \$11.3 congestion relief benefit in the first 4 years of operation. 89% of the cost (\$0.9 million) will be allocated to PJM. The projected in service date is November 1, 2019. PJM will designate the local Transmission Owner, ATSI, to complete this work.

Baseline Project b2973 – Reconductor the NIPSCO owned conductor on the Michigan City – Bosserman 138kV (NIPSCO – AEP tie) line

This project increases the rating on Michigan City – Bosserman 138kV, to address historical M2M congestion on that facility.

The estimated cost is \$6.0 million and the project will provide an estimated \$29.6 million congestion relief benefit in the first 4 years of operation. 90% of the cost (\$5.4 million) will be allocated to PJM. The projected in service date is November 1, 2019. MISO will designate the local Transmission Owner, NIPSCO, to complete this work.

Baseline Project b2974 – Replace terminal equipment at the Reynolds 138kV station for the Reynolds – Magnetation 138kV (NIPSCO) circuit

This project increases the rating on Reynolds – Magnetation 138kV, to address historical M2M congestion on that facility.

The estimated cost is \$120,000 and the project will provide an estimated \$14.5 million congestion relief benefit in the first 4 years of operation. 41% of the cost (\$49,000) will be allocated to PJM. The projected in service date is June 1, 2019. MISO will designate the local Transmission Owner, NIPSCO, to complete this work.

Baseline Project b2975 – Reconductor Roxana – Praxair 138kV (NIPSCO)

This project increases the rating on Roxana – Praxair 138kV, to address historical M2M congestion on that facility.

The estimated cost is \$6.1 million and the project will provide an estimated \$6.5 million congestion relief benefits in the first 4 years of operation. 24% of the cost (\$1.5 million) will be allocated to PJM. The projected in service date is June 1, 2020. MISO will designate the local Transmission Owner, NIPSCO, to complete this work.



Baseline Market Efficiency Project

2016/17 RTEP Long Term Proposal Window Addendum 1A

PJM opened an additional proposal window to solicit proposals to address facilities expected to limit capacity imports into the DEOK LDA in RPM. Following the 2020/21 RPM Base Residual Auction (BRA) in May of 2017, imports into the DEOK LDA were limited by the Tanners Creek - Dearborn 345kV line. The Addendum Window 1A was opened from September 14, 2017 through September 28, 2017.

PJM staff solicited proposals to address constraints on the Tanners Creek – Dearborn 345 kV line. Three proposals were submitted to address DEOK LDA capacity market constraints. Proposals submitted ranged in costs from \$0.6 to \$12.7 million and included two Transmission Owner upgrades and one Greenfield project from a non-incumbent entity.

PJM staff conducted an extensive analysis on the proposals to determine which projects satisfy the Market Efficiency criteria of having a Benefit/Cost ratio >1.25, and are economically justified.

The capacity benefits associated with the proposed projects were determined using the methodologies specified in Schedule 6 of the PJM Operating Agreement. PJM’s annual capacity benefits calculation for lower voltage facilities is weighted 100 percent to zones with a decrease in net load capacity payments as a result of the proposed project. Change in net load capacity payments comprises the change in gross capacity payments offset by the change in capacity transfer rights.

PJM determined the impact of each of the three proposed projects on the DEOK LDA Capacity Emergency Transfer Limit (CETL). By increasing the capability of the LDA’s limiting element the DEOK zone and other LDAs may be able to satisfy capacity requirements at a lower overall cost. PJM simulated the RPM process for multiple study years with the updated CETL values and measured each projects capacity benefits over a 15 year period.

The total Market Efficiency benefit of a project is the summation of the energy market benefits and the capacity market benefits. The energy market benefits were derived from production cost simulations and the capacity benefits were derived from capacity market simulations.

The project shown in Table 2 provides the highest total benefits, satisfies the B/C ratio of 1.25 and is being recommended to the Board for approval for inclusion into the RTEP. This project is an upgrade to existing equipment and will be designated to the incumbent transmission owner.

Table 2. Recommended Market Efficiency RPM Project

| PJM Baseline ID | PJM Window Project ID | Project Description | Transmission Zone | Constraint Project Addresses | Project Cost (\$M) | In Service Date | B/C Ratio |
|-----------------|-----------------------|--|-------------------|---|--------------------|-----------------|-----------|
| b2976 | 201617_1A-2A | Upgrade terminal equipment at Tanners Creek 345kV station Upgrade 345kV Bus and Risers at Tanners Creek for the Dearborn circuit. | AEP | Tanners Creek - Dearborn 345 kV, RPM Benefits | \$0.6 | 2021 | 151.61 |

The recommended project will provide estimated average annual savings of \$8.2 million in load energy and capacity payments.

The map in Figure 15 shows the location of the recommended project.




Figure 15. Location of Proposal 201717_1A-2A (PJM Baseline B2976)

Interconnection Queue Projects

Throughout 2017 PJM has continued to study new service customer requests that are submitted into our interconnection queue. These studies evaluate the impact of the interconnection request and include an evaluation of new generation interconnections, increases in generation at existing stations, long-term firm transmission service requests and merchant transmission interconnection requests.

These studies were last reviewed with the Reliability Committee of the Board in December of 2016. Since that time PJM has completed 252 interconnection System Impact Studies and 257 interconnection projects have withdrawn. The changes associated with the new and withdrawn projects resulted in a net increase in the RTEP of \$2,404.24 million for the network upgrades. Figure 16 below shows the location of the new units associated with the completed interconnection System Impact Studies along with the fuel type and relative size. A listing of the projects with recently completed impact studies is provided in Attachment C to this white paper. A listing of the network upgrades associated with these projects is shown in Attachment D to this report. The cost for the network upgrades associated with these interconnection projects is the responsibility of the developer.




Figure 16. Completed Interconnection System Impact Studies



Summary of Interconnection Queue Activity (MW)

The following Table 3 shows the status of all of the generation projects in the Interconnection Queues.

Table 3. Status of Generation Interconnection Queues

| Status of Generation Interconnection Queues | | | | | | |
|---|--------|-----------|--------------------|-------------|-----------|--------------------|
| Queue | Active | Suspended | Under Construction | In-Service* | Withdrawn | Total MW Request** |
| A-U2 | 0 | 738 | 1,321 | 30,576 | 190,452 | 223,087 |
| U3 | 100 | 0 | 7 | 141 | 2,126 | 2,374 |
| U4 | 100 | 52 | 0 | 76 | 2,442 | 2,670 |
| V1 | 40 | 33 | 0 | 46 | 2,072 | 2,191 |
| V2 | 20 | 2 | 6 | 889 | 2,497 | 3,414 |
| V3 | 26 | 39 | 8 | 863 | 1,395 | 2,331 |
| V4 | 0 | 28 | 0 | 732 | 1,726 | 2,487 |
| W1 | 0 | 5 | 53 | 194 | 3,514 | 3,765 |
| W2 | 10 | 9 | 4 | 186 | 1,778 | 1,987 |
| W3 | 0 | 403 | 43 | 463 | 2,683 | 3,591 |
| W4 | 0 | 260 | 80 | 933 | 2,721 | 3,993 |
| X1 | 195 | 356 | 21 | 955 | 2,011 | 3,538 |
| X2 | 0 | 585 | 1,092 | 2,154 | 4,121 | 7,952 |
| X3 | 0 | 751 | 9 | 43 | 5,627 | 6,430 |
| X4 | 0 | 0 | 1,998 | 772 | 2,025 | 4,794 |
| Y1 | 9 | 0 | 1,412 | 880 | 4,630 | 6,931 |
| Y2 | 697 | 247 | 1,098 | 241 | 7,977 | 10,260 |
| Y3 | 90 | 20 | 1,072 | 295 | 3,886 | 5,363 |
| Z1 | 693 | 40 | 2,639 | 343 | 3,812 | 7,528 |
| Z2 | 74 | 145 | 2,326 | 218 | 2,252 | 5,015 |
| AA1 | 1,963 | 88 | 2,796 | 174 | 4,880 | 9,900 |
| AA2 | 4,791 | 1,624 | 858 | 220 | 6,660 | 14,152 |
| AB1 | 10,340 | 68 | 848 | 45 | 6,188 | 17,489 |
| AB2 | 8,520 | 11 | 137 | 7 | 3,285 | 11,961 |
| AC1 | 12,348 | 16 | 98 | 4 | 2,418 | 14,884 |
| AC2 | 3,907 | 0 | 0 | 0 | 3,232 | 7,139 |
| AD1 | 3,521 | 0 | 0 | 0 | 25 | 3,546 |
| TOTAL | 0 | 738 | 1,321 | 30,576 | 190,452 | 223,087 |

* In-service MW can and do change to account for units that are phased into commercial operation
 **Total MW Requests can change due to MW reduction in certain phases of the study process
 Data Valid as of:
 9/30/2017



Changes to Previously Approved Projects

As further described below, cost and scope of previously approved RTEP baseline projects have changed, resulting in a net increase of \$79.72M. Three projects, totaling \$2.65M, are being cancelled as they are no longer needed to satisfy reliability criteria. The net change in the RTEP to incorporate these changes to previously approved projects is \$77.07 million.

Baseline Project b2361 – New Idylwood to Tysons 230kV line and new Tyson GIS substation

An N-1-1 analysis of the 2013 base case revealed a loss of more than 300MW load. The approved solution was to build 2.4 miles of new OH 230kV line from Idylwood to the Dulles Toll Road in the ROW with Idylwood – CIA line and build 2.1 miles of new OH 230kV line from the Dulles Toll Road to a new Scott's Run substation. The section from the Dulles Toll Road to Scott's Run would be in new ROW. The approved cost this project was \$32.0M.

A number of drivers have caused the scope to change and the project cost to increase. The incumbent transmission owner has been unable to find a suitable site for the Scott's Run station in Fairfax County. The existing ROW between Idylwood and the Dulles Toll Road is very narrow. Siting a second line the ROW is not viable and expansion of the ROW very difficult due high population density along the path. The new ROW required for overhead construction between the Dulles Toll Road and the Scott's Run station is very difficult to acquire due to high population density and the close proximity of the highway and commuter rail lines.

The modified solution recommended build 4.5 miles of new underground 230kV line from Idylwood to the Tysons station. Due to lack of land available adjacent to the Tysons station, the station will be converted to GIS and rebuilt within the existing footprint. The revised construction estimate is \$111.7M and the revised in-service date is June 2022.

The maps in Figure 17 show the location of the recommended project with scope and cost changes, while the map in Figure 18 shows the alternatives to the recommended project.



| COLOR | VOLTAGE | TRANSMISSION LINE NUMBER |
|--------|---------|-------------------------------|
| Green | 500 KV. | 500 thru 599 |
| Blue | 230 KV. | 200 thru 299 & 2000 thru 2099 |
| Red | 115 KV. | 1 thru 199 |
| Orange | 138 KV. | AS NOTED |
| Cyan | 69 KV. | AS NOTED |



Figure 17. Location of PJM baseline b2361




Figure 18. Location of PJM baseline b2361 Alternatives

Review by the Transmission Expansion Advisory Committee (TEAC)

The need for the projects was reviewed with stakeholders at several meetings throughout 2017, most recently at the November and October 2017 TEAC and Sub Regional RTEP Committee meetings. Written comments were requested to be submitted to PJM. As of the writing of this report there have been no comments received on the projects presented to the TEAC.

Cost Allocation

Cost allocations for the projects are calculated in accordance with the Schedule 12 of the OATT. Baseline reliability project allocations are calculated using a distribution factor methodology that allocates the cost to the load zones that contribute to the loading on the new facility. Baseline projects required exclusively to address local transmission owner FERC Form 715 planning criteria are allocated to the local transmission owner zone. As described above, the market efficiency project is allocated to the zone that benefit from the project. The allocations will be filed at the FERC 30 days following approval by the Board.



Board Approval

The PJM Board Reliability Committee was requested to endorse the new baseline reliability projects and associated cost allocations, and recommend to the Board, approval of the baseline upgrades to the 2017 RTEP.

The baseline upgrades will be incorporated into the published RTEP after approval by the PJM Board. The RTEP will be published on the PJM Website.

Attachment A – Baseline Upgrades – Single Zone Cost Allocations

| Upgrade ID | Description | Cost Estimate (\$M) | Trans Owner | Cost Responsibility | Required IS Date |
|------------|--|---------------------|-------------|---------------------|------------------|
| b2752.8 | Replace the Conaston 230kV '2322 B5' breaker with a 63kA breaker | \$0.54 | BGE | BGE | 6/1/2020 |
| b2752.9 | Replace the Conaston 230kV '2322 B6' breaker with a 63kA breaker | \$0.54 | BGE | BGE | 6/1/2020 |
| b2761.3 | Rebuild the Hazard – Wooton 161 kV line utilizing 795 26/7 ACSR conductor (300 MVA rating). | \$16.48 | AEP | AEP | 6/1/2021 |
| b2838 | Build a new 230/69 kV substation by tapping the Montour - Susquehanna 230 kV double circuits and Berwick - Hunlock & Berwick - Colombia 69 kV circuits | \$57.00 | PPL | PPL | 6/1/2017 |
| b2945.1 | Rebuild the BL England – Middle Tap 138kV line to 2000A on double circuited steel poles and new foundations | \$22.64 | AEC | AEC | 6/1/2022 |
| b2945.2 | Re-conductor BL England – Merion 138kV (1.9miles) line | \$3.92 | AEC | AEC | 6/1/2022 |
| b2945.3 | Re-conductor Merion – Corson 138kV (8miles) line | \$9.85 | AEC | AEC | 6/1/2022 |
| b2946 | Convert existing Preston 69 kV Substation to DPL's current design standard of a 3-breaker ring bus. | \$2.64 | DPL | DPL | 6/1/2022 |
| b2947.1 | Upgrade terminal equipment at DPL's Naamans Substation (Darley-Naamans 69 kV) | \$0.15 | DPL | DPL | 6/1/2022 |
| b2947.2 | Re-conductor 0.11 mile section of Darley-Naamans 69 kV circuit | \$0.20 | DPL | DPL | 6/1/2022 |
| b2948 | Upgrade terminal equipment at DPL's Silverside Road Substation (Dupont Edge Moor –Silver R. 69 kV) | \$0.15 | DPL | DPL | 6/1/2022 |
| b2950 | Upgrade limiting 115 kV switches on the 115 kV side of the 230/115 kV Northwood substation and adjust setting on limiting ZR relay | \$0.10 | ME | ME | 6/1/2022 |
| b2951 | Seward, Blairsville East, Sheltocta work | \$1.49 | PENELEC | PENELEC | 6/1/2022 |
| b2951.1 | Upgrade Florence 115kV line terminal equipment at Seward SS | \$0.00 | PENELEC | PENELEC | 6/1/2022 |
| b2951.2 | Replace Blairsville East/Seward 115kV line tuner, coax, line relaying and carrier set at Shelocta SS | \$0.00 | PENELEC | PENELEC | 6/1/2022 |
| b2951.3 | Replace Seward/Shelocta 115kV line CVT, tuner, coax, and line relaying at Blairsville East SS | \$0.00 | PENELEC | PENELEC | 6/1/2022 |

Attachment A – Baseline Upgrades – Single Zone Cost Allocations

| Upgrade ID | Description | Cost Estimate (\$M) | Trans Owner | Cost Responsibility | Required IS Date |
|------------|--|---------------------|-------------|---------------------|------------------|
| b2952 | Replace the North Meshoppen #3 230/115kV transformer eliminating the old reactor and installing two breakers to complete a 230kV ring bus at North Meshoppen | \$6.80 | PENELEC | PENELEC | 6/1/2022 |
| b2953 | Replace the Keystone 500kV breaker "NO.14 Cabot" with 50kA breaker | \$1.24 | PENELEC | PENELEC | 6/1/2020 |
| b2954 | Replace the Keystone 500kV breaker "NO.16 Cabot" with 50kA breaker | \$1.24 | PENELEC | PENELEC | 6/1/2020 |
| b2958.1 | Cut George Washington – Tidd 138kV circuit into Sand Hill and reconfigure Brues & Warton Hill line entrances. | \$2.19 | AEP | AEP | 7/1/2017 |
| b2958.2 | Add 2 138kV 3000 A 40 kA breakers, disconnect switches, and update relaying at Sand Hill station. | \$5.06 | AEP | AEP | 7/1/2017 |
| b2959 | Install a new 138kV circuit 18702 from Schauff Road to Rock Falls and install a fourth breaker and a half run at Schauff Road. | \$20.00 | ComEd | ComEd | 11/1/2019 |
| b2960 | Replace fixed series capacitors on 500kV Line #547 at Lexington and on 500kV Line #548 at Valley | \$28.90 | Dominion | Dominion | 4/1/2020 |
| b2961 | Rebuild approximately 3 miles of Line #205 & Line #2003 from Chesterfield to Locks & Poe respectively. | \$9.50 | Dominion | Dominion | 12/31/2022 |
| b2962 | Split Line #227 (Brambleton – Beaumeade 230 kV)and terminate into existing Belmont substation | \$3.05 | Dominion | Dominion | 6/1/2022 |
| b2963 | Reconductor the Woodbridge to Occoquan 230kV line segment of Line 2001 with 1047 MVA conductor and replace line terminal equipment at Possum Point, Woodbridge, and Occoquan | \$4.49 | Dominion | Dominion | 6/1/2022 |
| b2964.1 | Replace terminal equipments at Pruntytown and Glen Falls 138 kV station. | \$0.26 | APS | APS | 6/1/2022 |
| b2964.2 | Reconductor approximately 8.3 miles of the McAlpin - White Hall Junction 138 kV circuit | \$3.79 | APS | APS | 6/1/2022 |
| b2965 | Reconductor the Charleroi – Allenport 138KV Line with 954 ACSR Conductor, Replace Breaker Risers at Charleroi and Allenport | \$7.08 | APS | DL | 6/1/2022 |
| b2966 | Reconductor the Yukon - Smithton - Shepler Hill Jct 138 kV Line with 795 ACSS Conductor, Replace Line Disconnect Switch at Yukon | \$3.19 | APS | APS | 6/1/2022 |

Attachment A – Baseline Upgrades – Single Zone Cost Allocations

| Upgrade ID | Description | Cost Estimate (\$M) | Trans Owner | Cost Responsibility | Required IS Date |
|------------|--|---------------------|-------------|---------------------|------------------|
| b2967 | Convert the existing 6 wire Butler - Shanor Manor - Krendale 138 kV Line into two separate 138 kV lines. New lines will be Butler - Keisters and Butler - Shanor Manor - Krendale 138 kV | \$6.96 | APS | APS | 6/1/2022 |
| b2968 | Upgrade existing 345kV terminal equipment at Tanner Creek station | \$1.20 | AEP | AEP | 6/1/2022 |
| b2969 | Replace terminal equipment on Maddox Creek - East Lima 345kV circuit | \$1.48 | AEP | AEP | 6/1/2022 |
| b2970 | Ringgold - Catoctin Solution | \$13.33 | APS | APS | 6/1/2020 |
| b2970.1 | Install two new 230 kV positions at Ringgold for 230/138 kV transformers. | \$0.00 | APS | APS | 6/1/2020 |
| b2970.2 | Install new 230 kV position for Ringgold – Catoctin 230 kV line. | \$0.00 | APS | APS | 6/1/2020 |
| b2970.3 | Install one new 230 kV breaker at Catoctin substation. | \$0.00 | APS | APS | 6/1/2020 |
| b2970.4 | Install new 230 / 138 kV transformer at Catoctin substation. Convert Ringgold-Catoctin 138 kV Line to 230 kV operation. | \$0.00 | APS | APS | 6/1/2020 |
| b2976 | Upgrade terminal equipment at Tanners Creek 345kV station. Upgrade 345kV Bus and Risers at Tanners Creek for the Dearborn circuit. | \$0.60 | AEP | DEOK | 6/1/2021 |

Attachment B – Baseline Upgrades – Multi-Zone Cost Allocations

| Upgrade ID | Description | Cost Estimate (\$M) | Trans Owner | Cost Responsibility | Required IS Date |
|------------|---|---------------------|-------------|--|------------------|
| b2955 | Wreck and re-build the VFT – Warinanco – Aldene 230 kV circuit with paired conductor. | \$90.40 | PSEG | ECP (1.02%) / JCPL (89.15%) / NEPTUNE (5.91%) / HTP (3.92%) | 6/1/2018 |
| b2956 | Replace existing cable on Cedar Grove-Jackson Rd. with 5000kcmil XLPE cable. | \$80.00 | PSEG | JCPL (42.91%) / NEPTUNE (4.56%) / HTP (2.07%) / PSEG (48.51%) / RE (1.95%) | 6/1/2018 |
| b2971 | Reconfigure Munster 345kV as ring bus | \$7.00 | NIPSCO | MISO (12.00%) / AEC (0.97%) / AEP (16.65%) / APS (4.94%) / ATSI (7.77%) / BGE (5.20%) / DAY (1.85%) / DEOK (2.29%) / Dominion (15.20%) / DPL (1.75%) / DLCO (1.43%) / EKPC (0.60%) / JCPL (2.16%) / ME (1.72%) / PECO (4.32%) / PENELEC (4.98%) / PEPSCO (5.80%) / PPL (4.74%) / PSEG (5.08%) / RE (0.15%) / NEPTUNE (0.33%) / ECP (0.05%) / HTP (0.01%) | 6/1/2020 |
| b2972 | Reconductor limiting span of Lallendorf - Monroe 345kV (crossing of Maumee river) | \$1.00 | ATSI | MISO (11.00%) / AEP (5.38%) / APS (4.27%) / ATSI (66.48%) / DAY (2.71%) / Dominion (5.31%) / DLCO (4.84%) | 11/1/2019 |
| b2973 | Reconductor Michigan City - Bosserman 138kV | \$4.60 | NIPSCO | MISO (10.00%) / AEC (0.93%) / AEP (26.02%) / APS (4.19%) / ATSI (5.95%) / BGE (4.38%) / DAY (1.59%) / DEOK (2.30%) / Dominion (14.70%) / DPL (1.53%) / DLCO (1.26%) / EKPC (0.98%) / JCPL (1.92%) / ME (1.39%) / PECO (4.19%) / PENELEC (4.34%) / PEPSCO (5.05%) / PPL (4.03%) / PSEG (4.48%) / RE (0.12%) / NEPTUNE (0.56%) / ECP (0.08%) / HTP (0.02%) | 12/1/2019 |

Attachment B – Baseline Upgrades – Multi-Zone Cost Allocations

| Upgrade ID | Description | Cost Estimate (\$M) | Trans Owner | Cost Responsibility | Required IS Date |
|------------|--|---------------------|-------------|--|------------------|
| b2974 | Replace terminal equipment at Reynolds on the Reynolds - Magnetation 138kV | \$0.15 | NIPSCO | MISO (59.00%) / AEC (0.01%) / AEP (40.28%) / APS (0.13%) / ATSI (0.05%) / BGE (0.08%) / DAY (0.03%) / DPL (0.01%) / ME (0.04%) / PENELEC (0.06%) / PPL (0.21%) / PSEG (0.03%) / NEPTUNE (0.04%) / HTP (0.04%) | 6/1/2019 |
| b2975 | Reconductor Roxana - Praxair 138kV | \$4.50 | NIPSCO | MISO (76.00%) / AEC (0.28%) / AEP (4.51%) / APS (1.31%) / ATSI (1.91%) / BGE (1.40%) / DAY (0.49%) / DEOK (0.70%) / Dominion (4.35%) / DPL (0.46%) / DLCO (0.38%) / EKPC (0.27%) / JCPL (0.57%) / ME (0.43%) / PECO (1.25%) / PENELEC (1.34%) / PEPSCO (1.53%) / PPL (1.23%) / PSEG (1.41%) / RE (0.04%) / NEPTUNE (0.14%) / ECP (0.01%) / HTP (0.01%) | 6/1/2020 |

Attachment C – Interconnection Queue Projects

| Queue Position | Path Name | Request Type | TO |
|----------------|---------------------------|---------------|---------|
| AB2-019 | Erie West 345kV | Merch. Trans. | PENELEC |
| AB2-021 | Keeney-Rock Springs 500kV | Merch. Trans. | DPL |

| Queue Position | Path Name | Request Type | MWs |
|----------------|--------------------|----------------|------|
| AB1-100 | NYIS-PJM | Long-Term Firm | 480 |
| AB2-005 | TVA-PJM | Long-Term Firm | 148 |
| AB2-007 | NYISJK-PJM-NYISABC | Long-Term Firm | 1000 |
| AB2-013 | AMIL-PJM | Long-Term Firm | 150 |
| AB2-075 | DUK-PJM | Long-Term Firm | 42 |
| AB2-076 | DUK-PJM | Long-Term Firm | 51 |
| AC1-002 | AMIL-PJM | Long-Term Firm | 550 |
| AC1-004 | AMIL-PJM | Long-Term Firm | 300 |
| AC1-056 | PJM-AMIL | Long-Term Firm | 100 |
| AC1-057 | PJM-MECS | Long-Term Firm | 200 |
| AC1-126 | PJM-CPLE | Long-Term Firm | 25 |
| AC1-127 | PJM-CPLE | Long-Term Firm | 25 |
| AC1-128 | PJM-CPLE | Long-Term Firm | 25 |
| AC1-129 | PJM-CPLE | Long-Term Firm | 25 |
| AC1-131 | PJM-CPLE | Long-Term Firm | 50 |
| AC1-132 | PJM-CPLE | Long-Term Firm | 50 |
| AC1-133 | PJM-CPLE | Long-Term Firm | 100 |
| AD1-021 | PJM-LINDENVFT | Long-Term Firm | 330 |

| Transmission Owner | Queue Position | Fuel Type | MW Capacity (FTIR/FTWR) | MW Energy (nFTIR/nFTWR) |
|--------------------|----------------|-------------|-------------------------|-------------------------|
| AEP | AB1-087 | Natural Gas | 550 | 575 |
| AEP | AB1-088 | Natural Gas | 550 | 575 |
| AEP | AB2-016 | Wind | 13 | 100 |
| AEP | AB2-028 | Wind | 26 | 200 |
| AEP | AB2-065 | Wind | 16 | 124.2 |
| AEP | AB2-067 | Natural Gas | 1100 | 1100 |
| AEP | AB2-083 | Solar | 27.2 | 40 |
| AEP | AB2-085 | Solar | 54.4 | 80 |
| AEP | AB2-093 | Natural Gas | 485 | 485 |
| AEP | AB2-103 | Solar | 27.2 | 40 |
| AEC | AB2-049 | Solar | 3.8 | 10 |
| AEC | AB2-102 | Natural Gas | 225 | 230 |

Attachment C – Interconnection Queue Projects

| Transmission Owner | Queue Position | Fuel Type | MW Capacity (FTIR/FTWR) | MW Energy (nFTIR/nFTWR) |
|--------------------|----------------|-------------|-------------------------|-------------------------|
| AEC | AB2-122 | Solar | 0.7 | 1.9 |
| AEP | AB2-109 | Hydro | 4 | 12.5 |
| AEP | AB2-145 | Natural Gas | 572 | 572 |
| AEP | AB2-170 | Solar | 49.4 | 130 |
| AEP | AC1-001 | Solar | 54.4 | 80 |
| AEP | AC1-012 | Solar | 0 | 5 |
| AEP | AC1-038 | Natural Gas | 13 | 13 |
| AEP | AC1-040 | Solar | 57 | 150 |
| AEP | AC1-044 | Natural Gas | 550 | 550 |
| AEP | AC1-051 | Wind | 7.8 | 60 |
| AEP | AC1-072 | Natural Gas | 20 | 20 |
| AEP | AB2-109 | Hydro | 4 | 12.5 |
| AEP | AB2-145 | Natural Gas | 572 | 572 |
| AEP | AB2-170 | Solar | 49.4 | 130 |
| AEP | AC1-001 | Solar | 54.4 | 80 |
| AEP | AC1-012 | Solar | 0 | 5 |
| AEP | AC1-038 | Natural Gas | 13 | 13 |
| AEP | AC1-040 | Solar | 57 | 150 |
| AEP | AC1-044 | Natural Gas | 550 | 550 |
| AEP | AC1-051 | Wind | 7.8 | 60 |
| AEP | AC1-072 | Natural Gas | 20 | 20 |
| AEP | AC1-082 | Solar | 29 | 48 |
| AEP | AC1-083 | Solar | 38 | 100 |
| AEP | AC1-088 | Storage | 20 | 20 |
| AEP | AC1-089 | Solar | 57 | 150 |
| AEP | AC1-100 | Natural Gas | 27.4 | 100 |
| AEP | AC1-101 | Solar | 19 | 50 |
| AEP | AC1-102 | Solar | 19 | 50 |
| AEP | AC1-103 | Natural Gas | 1026 | 1050 |
| AEP | AC1-122 | Solar | 40.7 | 60 |
| AEP | AC1-123 | Solar | 13.7 | 20 |
| AEP | AC1-141 | Natural Gas | 91 | 91 |
| AEP | AC1-144 | Solar | 57.2 | 85 |
| AEP | AC1-152 | Natural Gas | 50 | 50 |
| AEP | AC1-167 | Solar | 33.6 | 49.9 |
| AEP | AC1-172 | Natural Gas | 50 | 50 |
| AEP | AC1-173 | Wind | 9.9 | 75.9 |
| AEP | AC1-174 | Solar | 38 | 100 |
| AEP | AC1-175 | Solar | 38 | 100 |

Attachment C – Interconnection Queue Projects

| Transmission Owner | Queue Position | Fuel Type | MW Capacity (FTIR/FTWR) | MW Energy (nFTIR/nFTWR) |
|--------------------|----------------|---------------|-------------------------|-------------------------|
| AEP | AC1-176 | Wind | 7.6 | 58.7 |
| AEP | AC1-188 | Solar | 46.6 | 70 |
| AEP | AC1-194 | Solar | 47.5 | 125 |
| AEP | AC1-210 | Solar | 31 | 45 |
| AEP | AC2-038 | Solar | 12 | 20 |
| AEP | AC2-080 | Wind | 26 | 200 |
| AEP | AC2-123 | Solar | 44.6 | 75 |
| APS | AB2-041 | Wind | 3.7 | 20 |
| APS | AB2-104 | Natural Gas | 65 | 65 |
| APS | AB2-129 | Solar | 30.4 | 80 |
| APS | AC1-003 | Natural Gas | 80 | 80 |
| APS | AC1-021 | Natural Gas | 0 | 110 |
| APS | AC1-025 | Storage | 0 | 1.5 |
| APS | AC1-055 | Natural Gas | 30 | 30 |
| APS | AC1-073 | Wind; Storage | 5.8 | 16.3 |
| APS | AC1-097 | Natural Gas | 1040 | 1140 |
| APS | AC1-139 | Solar | 38.8 | 102 |
| APS | AC1-140 | Coal | 10 | 10 |
| APS | AC1-187 | Wind | 15 | 117 |
| APS | AC1-211 | Solar | 48.1 | 70 |
| APS | AC1-217 | Solar | 37.8 | 55 |
| APS | AC2-142 | Natural Gas | 129.7 | 129.7 |
| ATSI | AB1-107 | Natural Gas | 860 | 955 |
| ATSI | AB2-131 | Solar | 57 | 150 |
| ATSI | AC1-078 | Solar | 66 | 176 |
| BGE | AC1-008 | Nuclear | 19.2 | 19.2 |
| ComEd | AB1-089 | Natural Gas | 550 | 575 |
| ComEd | AB1-090 | Natural Gas | 550 | 575 |
| ComEd | AB1-091 | Natural Gas | 550 | 575 |
| ComEd | AB1-122 | Natural Gas | 1150 | 1150 |
| ComEd | AB2-047 | Wind | 32.5 | 250 |
| ComEd | AB2-070 | Wind | 26 | 200 |
| ComEd | AB2-096 | Natural Gas | 350 | 350 |
| ComEd | AB2-132 | Wind; Storage | 2.2 | 2.5 |
| ComEd | AB2-173 | Natural Gas | 28 | 16 |
| ComEd | AB2-191 | Wind | 10.6 | 20 |
| ComEd | AC1-033 | Wind | 13.1 | 100.8 |
| ComEd | AC1-053 | Wind | 26 | 200 |
| ComEd | AC1-067 | Natural Gas | 1092 | 1254 |

Attachment C – Interconnection Queue Projects

| Transmission Owner | Queue Position | Fuel Type | MW Capacity (FTIR/FTWR) | MW Energy (nFTIR/nFTWR) |
|--------------------|----------------|-------------|-------------------------|-------------------------|
| ComEd | AC1-109 | Natural Gas | 30 | 30 |
| ComEd | AC1-110 | Natural Gas | 30 | 30 |
| ComEd | AC1-111 | Natural Gas | 36 | 36 |
| ComEd | AC1-113 | Natural Gas | 20 | 20 |
| ComEd | AC1-114 | Natural Gas | 20 | 20 |
| ComEd | AC1-142A | Natural Gas | 64 | 64 |
| ComEd | AC1-204 | Natural Gas | 1115.9 | 1200.9 |
| ComEd | AC1-214 | Wind | 19 | 79.4 |
| Dayton | AB1-169 | Natural Gas | 1100 | 1150 |
| Dayton | AC1-068 | Solar | 34 | 49.9 |
| Dayton | AC1-069 | Solar | 34 | 49.9 |
| Dayton | AC1-085 | Solar | 152 | 400 |
| Dayton | AC1-165 | Solar | 33.6 | 49.9 |
| Dayton | AC1-166 | Solar | 33.6 | 49.9 |
| Dayton | AC1-212 | Storage | 17 | 19.9 |
| Dayton | AC2-020 | Solar | 7.6 | 20 |
| Dayton | AC2-067 | Solar | 18.9 | 49.9 |
| Dayton | AC2-068 | Solar | 7.6 | 20 |
| Dayton | AC2-164 | Solar | 14.4 | 0 |
| DEOK | AC1-182 | Coal | 20 | 20 |
| DEOK | AC2-066 | Solar | 28.5 | 75 |
| DEOK | AC2-085 | Solar | 10.8 | 20 |
| DEOK | AC2-088 | Solar | 38.4 | 70 |
| Dominion | AB2-015 | Solar | 50 | 91 |
| Dominion | AB2-022 | Solar | 13 | 20 |
| Dominion | AB2-031 | Solar | 13.4 | 20 |
| Dominion | AB2-035 | Solar | 2.1 | 3 |
| Dominion | AB2-040 | Solar | 44 | 80 |
| Dominion | AB2-043 | Solar | 18.9 | 49.9 |
| Dominion | AB2-050 | Natural Gas | 20 | 20 |
| Dominion | AB2-051 | Natural Gas | 765.5 | 884.5 |
| Dominion | AB2-059 | Solar | 66 | 100 |
| Dominion | AB2-060 | Solar | 54.4 | 80 |
| Dominion | AB2-062 | Solar | 0 | 20 |
| Dominion | AB2-068 | Natural Gas | 1060 | 1060 |
| Dominion | AB2-072 | Solar | 13.6 | 20 |
| Dominion | AB2-077 | Solar | 12 | 20 |
| Dominion | AB2-078 | Solar | 12 | 20 |
| Dominion | AB2-079 | Solar | 12 | 20 |

Attachment C – Interconnection Queue Projects

| Transmission Owner | Queue Position | Fuel Type | MW Capacity (FTIR/FTWR) | MW Energy (nFTIR/nFTWR) |
|--------------------|----------------|-------------|-------------------------|-------------------------|
| Dominion | AB2-087 | Solar | 3.4 | 5 |
| Dominion | AB2-088 | Solar | 2.7 | 4 |
| Dominion | AB2-089 | Solar | 13.2 | 20 |
| Dominion | AB2-090 | Solar | 23.8 | 36 |
| Dominion | AB2-098 | Solar | 3.5 | 5 |
| Dominion | AB2-099 | Solar | 3.5 | 5 |
| Dominion | AB2-100 | Solar | 67 | 100 |
| Dominion | AB2-134 | Solar | 71.8 | 142.4 |
| Dominion | AB2-158 | Solar | 61 | 88.2 |
| Dominion | AB2-160 | Solar | 30.4 | 80 |
| Dominion | AB2-161 | Solar | 19 | 50 |
| Dominion | AB2-169 | Solar | 39 | 74 |
| Dominion | AB2-174 | Solar | 42 | 80 |
| Dominion | AB2-176 | Solar | 9.8 | 14 |
| Dominion | AB2-186 | Solar | 3.5 | 5 |
| Dominion | AB2-188 | Solar | 14 | 20 |
| Dominion | AB2-190 | Solar | 112 | 160 |
| Dominion | AC1-034 | Solar | 42.75 | 75 |
| Dominion | AC1-036 | Solar | 5.7 | 15 |
| Dominion | AC1-042 | Solar | 15.96 | 42 |
| Dominion | AC1-043 | Solar | 38 | 100 |
| Dominion | AC1-054 | Solar | 44.5 | 65 |
| Dominion | AC1-065 | Solar | 19 | 50 |
| Dominion | AC1-070 | Solar | 13.3 | 20 |
| Dominion | AC1-075 | Solar | 38.3 | 60 |
| Dominion | AC1-076 | Solar | 23.8 | 62.5 |
| Dominion | AC1-080 | Solar | 12.8 | 20 |
| Dominion | AC1-086 | Solar | 123.7 | 180 |
| Dominion | AC1-098 | Solar | 37.6 | 60 |
| Dominion | AC1-099 | Solar | 12.6 | 20 |
| Dominion | AC1-105 | Solar | 34.5 | 51 |
| Dominion | AC1-107 | Natural Gas | 1600 | 1600 |
| Dominion | AC1-115 | Solar | 5.7 | 14.9 |
| Dominion | AC1-120 | Solar | 39.6 | 60 |
| Dominion | AC1-121 | Solar | 13.6 | 20 |
| Dominion | AC1-134 | Natural Gas | 50 | 0 |
| Dominion | AC1-143 | Solar | 41.2 | 60 |
| Dominion | AC1-145 | Solar | 19 | 50 |
| Dominion | AC1-158 | Solar | 347.5 | 500 |

Attachment C – Interconnection Queue Projects

| Transmission Owner | Queue Position | Fuel Type | MW Capacity (FTIR/FTWR) | MW Energy (nFTIR/nFTWR) |
|--------------------|----------------|----------------|-------------------------|-------------------------|
| Dominion | AC1-161 | Solar | 168.2 | 240 |
| Dominion | AC1-162 | Solar | 168.9 | 240 |
| Dominion | AC1-163 | Solar | 11.54 | 16.94 |
| Dominion | AC1-164 | Solar | 220.8 | 320 |
| Dominion | AC1-189 | Solar | 53.4 | 80 |
| Dominion | AC1-191 | Solar | 53.4 | 80 |
| Dominion | AC1-206 | Storage; Solar | 57.72 | 85 |
| Dominion | AC1-208 | Solar | 55.4 | 80 |
| Dominion | AC1-216 | Solar | 54.8 | 97.9 |
| Dominion | AC1-221 | Solar | 14.6 | 29.2 |
| Dominion | AC1-222 | Solar | 22.9 | 44.7 |
| Dominion | AC1-227 | Wind | 12 | 96.6 |
| DPL | AB2-030 | Storage | 0 | 4 |
| DPL | AB2-032 | Solar | 13.6 | 20 |
| DPL | AB2-036 | Solar | 34.9 | 92 |
| DPL | AB2-037 | Solar | 76.7 | 202 |
| DPL | AB2-063 | Solar | 7.6 | 20 |
| DPL | AB2-084 | Solar | 3.8 | 10 |
| DPL | AB2-120 | Solar | 38 | 100 |
| DPL | AB2-130 | Solar | 32.3 | 85 |
| DPL | AB2-133 | Solar | 24.6 | 55.8 |
| DPL | AB2-135 | Solar | 29.9 | 64 |
| DPL | AB2-136 | Solar | 24.8 | 51.1 |
| DPL | AB2-153 | Solar | 7.6 | 20 |
| DPL | AB2-166 | Solar | 2 | 5.5 |
| DPL | AB2-168 | Solar | 3.8 | 10 |
| DPL | AB2-172 | Solar | 19 | 50 |
| DPL | AB2-179 | Solar | 37.6 | 50 |
| DPL | AB2-180 | Solar | 14 | 20 |
| DPL | AB2-185 | Solar | 14 | 20 |
| DPL | AC1-009 | Solar | 7.6 | 20 |
| DPL | AC1-041 | Solar | 1.9 | 5 |
| DPL | AC1-049 | Solar | 1.5 | 4 |
| DPL | AC1-050 | Solar | 1.9 | 5 |
| DPL | AC1-052 | Solar | 6.4 | 9 |
| DPL | AC1-091 | Solar | 7.5 | 19.8 |
| DPL | AC1-092 | Solar | 7.5 | 19.8 |
| DPL | AC1-093 | Solar | 7.1 | 18.8 |
| DPL | AC1-094 | Solar | 6 | 15.9 |

Attachment C – Interconnection Queue Projects

| Transmission Owner | Queue Position | Fuel Type | MW Capacity (FTIR/FTWR) | MW Energy (nFTIR/nFTWR) |
|--------------------|----------------|-------------|-------------------------|-------------------------|
| DPL | AC1-095 | Solar | 3.8 | 9.9 |
| DPL | AC1-154 | Solar | 1.2 | 3.2 |
| DPL | AC1-177 | Biomass | 4 | 4 |
| DPL | AC1-190 | Solar | 35 | 50 |
| DPL | AC1-213 | Solar | 3.2 | 5.3 |
| DPL | AC1-220 | Solar | 15.5 | 26.5 |
| DPL | AC1-228 | Solar | 1.1 | 3 |
| DPL | AC1-229 | Solar | 3.8 | 10 |
| DPL | AC2-018 | Natural Gas | 8 | 60 |
| DPL | AC2-187 | Solar | 7.6 | 20 |
| EKPC | AC1-074 | Solar | 56 | 80 |
| ME | AB2-112 | Natural Gas | 35 | 35 |
| ME | AC1-035 | Natural Gas | 30 | 30 |
| ME | AC1-048 | Solar | 13.3 | 35 |
| ME | AC2-053 | Solar | 7.6 | 20 |
| ODEC | AB2-033 | Solar | 7.16 | 10 |
| PECO | AB2-175 | Nuclear | 44 | 44 |
| PENELEC | AC1-108 | Natural Gas | 100 | 50 |
| PENELEC | AC1-186 | Wind | 17.9 | 138 |
| PEPCO | AB2-157 | Solar | 0.8 | 2.5 |
| PPL | AB2-074 | Natural Gas | 50 | 113 |
| PPL | AC1-071 | Wind | 8.74 | 67.25 |
| PPL | AC1-087 | Solar | 3.8 | 10 |
| PPL | AC1-151 | Solar | 7.6 | 20 |
| PPL | AC2-092 | Natural Gas | 65 | 55 |
| PSEG | AB2-055 | Natural Gas | 1041.4 | 1041.4 |
| PSEG | AB2-082 | Natural Gas | 671 | 675 |
| PSEG | AB2-092 | Natural Gas | 51.1 | 51.1 |
| SMECO | AC2-101 | Solar | 12.35 | 32.5 |

Attachment D - Interconnection Network Upgrades

| Upgrade ID | Description | Transmission Owner | Cost Estimate (\$M) | Required IS Date |
|------------|---|--------------------|---------------------|------------------|
| n2115 | Construct a new switching station (U4-028), including four 138 kV circuit breakers, relays, 138 kV revenue metering, SCADA, and associated equipment | ComEd | 5.86 | 12/31/2018 |
| n3666 | Construct a new Iron Ridge 138kV Switching Station | AEP | 5.4077 | 10/31/2019 |
| n3666.1 | Install ADSS Fiber at the new Iron Ridge 138kV substation | AEP | 0.0546 | 10/31/2019 |
| n3666.2 | Construct Jubal Early – Austinville 138kV T-Line Cut In | AEP | 1.8549 | 10/31/2019 |
| n3666.3 | Install 138 kV Revenue Metering at the new Iron Ridge 138kV substation | AEP | 0.2006 | 10/31/2019 |
| n4317.1 | Install one 345 kV breaker at the Leroy Center 345 kV substation | PENELEC | 1.193 | 12/31/2017 |
| n4317.3 | Build a new Leroy Center - Erie West 345 kV line | PENELEC | 194.574 | 12/31/2017 |
| n4318 | Re-conductor Leroy Center - Spruce 138 kV line | PENELEC | 8.8986 | 12/31/2017 |
| n4319 | Install a 50 MVAR capacitor bank at the Ashtabula 138 kV substation | PENELEC | 1.0233 | 12/31/2017 |
| n4320.1 | Replace the line side disconnect risers and connectors, and revise relay settings as necessary, on the Butler line terminal at the Karns City 138 kV substation | PENELEC | 0.0132 | 12/31/2017 |
| n4320.2 | Re-conductor the Karns City 138 kV line terminal at the Butler 138 kV substation including Wave Trap, line and bus side disconnects | PENELEC | 0.0855 | 12/31/2017 |
| n4320.3 | Re-conductor 15.6 miles of Butler - Karns City 138 kV line | PENELEC | 12.8429 | 12/31/2017 |
| n4347.1 | Replace 25kA E. Towanda 230kV Hillside breaker with 50kA | AEP | 0.45 | 4/29/2019 |
| n4347.2 | Replace 25kA E. Towanda 230kV Moshannon breaker with 50kA | ComEd | 0.45 | 4/29/2019 |
| n4713.1 | Sturgis - Howe 69kV T-Line Removal for the rebuild of the 2.83 miles of existing Howe – Sturgis 69 kV line (AEP Portion) | AEP | 0.266 | 7/1/2019 |
| n4713.2 | Right Of Way for the rebuild of the 2.83 miles of existing Howe – Sturgis 69 kV line (AEP Portion) | AEP | 2.382 | 7/1/2019 |
| n4734 | Upgrade 345kV switches at TSS 155 for L15502, upgrade station conductor and adjust CT ratios at the two station terminals | ComEd | 0.35 | 6/1/2020 |

Attachment D - Interconnection Network Upgrades

| Upgrade ID | Description | Transmission Owner | Cost Estimate (\$M) | Required IS Date |
|------------|--|--------------------|---------------------|------------------|
| n4742.1 | Greentown - Dumont 765kV T-Line Circuit Cut-In for the new 765 kV switching Station | AEP | 3.06 | 7/1/2019 |
| n4742.2 | Install 765 kV Metering at the new substation | AEP | 1.284 | 7/1/2019 |
| n4742.4 | Install Telecommunications - Fiber Optic for the new substation | AEP | 0.226 | 7/1/2019 |
| N4747 | Engineering Oversight to Construct New Interconnection Substation | AEP | 1.02 | 10/1/2018 |
| n4748 | Transmission cut in work for TSS 971 Garden Prairie Road | AEP | 1.635 | 10/1/2018 |
| n4749 | Upgrade relaying and communications equipment to coordinate with cut in of TSS 971 Garden Prairie Road | AEP | 0.495 | 10/1/2018 |
| n4750 | Upgrade relaying and communications equipment to coordinate with cut in of TSS 971 Garden Prairie Road | AEP | 0.495 | 10/1/2018 |
| n4751 | Engineering Oversight to Construct New Interconnection Substation | ComEd | 1.12 | 10/1/2018 |
| n4752 | Transmission cut in work for TSS 96 King Creek | ComEd | 1.435 | 10/1/2018 |
| n4753 | Upgrade relaying and communication equipment to coordinate with cut in of TSS 96 King Creek | ComEd | 0.337 | 10/1/2018 |
| n4754 | Upgrade relaying and communication equipment to coordinate with cut in of TSS 96 King Creek | AEP | 0.446 | 10/1/2018 |
| n4755 | Upgrade relaying and communication equipment to coordinate with cut in of TSS 96 King Creek | AEP | 0.341 | 10/1/2018 |
| n4773 | Install three 345 kV breakers at Losantville substation to accommodate the connection for V3-007 | AEP | 2.6061 | 10/31/2017 |
| n4774 | Install 345 kV metering on the new line exit for the V3-007 connection | AEP | 0.3477 | 10/31/2017 |
| n4789 | Description, cost, driver Changed on 10/18/17 per Ed | AEP | 0.025 | 6/1/2019 |
| n4790 | Rebuild 9 miles of the AEP portion of the Stillwell – Dumont 345 kV line and upgrade necessary Dumont terminal equipment | AEP | 20 | 6/1/2019 |
| n4797 | Add new 138 kV breaker and electrically re-route high side of Transformer #2 to the 138 kV East Bus at West Fremont substation | ComEd | 0.5509 | 12/31/2018 |
| n5008 | Reconfigure the Kewanee 138 kV bus by | AEP | 7.5 | 12/1/2016 |

Attachment D - Interconnection Network Upgrades

| Upgrade ID | Description | Transmission Owner | Cost Estimate (\$M) | Required IS Date |
|------------|---|--------------------|---------------------|------------------|
| | swapping the Bishop Hill & Edwards line terminals | | | |
| n5015 | Replace disconnect switch, rebuild line & replace conductor for Church - New Meredith 69kV line | DPL | 11.3 | 12/31/2022 |
| n5019 | Replace bushing for Easton 138/69kV transformer | DPL | 0.08 | 12/31/2022 |
| n5045 | Construct a new switching station (Saxony) connecting to the East Leipsic – Richlands 138 kV line, including four (4) 138 kV circuit breakers, relays, SCADA, and associated equipment | AEP | 4.29 | 12/1/2017 |
| n5046 | Install Saxony 138kV Primary and back-up 138 kV revenue metering | AEP | 0.19 | 12/1/2017 |
| n5047 | Upgrade relaying at Yellow Creek substation | AEP | 0.25 | 12/1/2017 |
| n5048 | Construct Saxony 138kV Line extension | AEP | 7.24 | 12/1/2017 |
| n5049 | Relocate from its existing position, the portion of the existing East Leipsic - Richlands 138kV circuit that shares the 6 miles of double circuit towers with the E. Lima – E. Leipsic 138 kV circuit | AEP | 0.83 | 12/1/2017 |
| n5050 | Upgrade relaying at East Lima 138 kV substation | AEP | 0.12 | 12/1/2017 |
| n5051 | Upgrade relaying at East Leipsic 138 kV substation | AEP | 0.38 | 12/1/2017 |
| n5052 | Upgrade relaying at Richland 138 kV substation | AEP | 0.25 | 12/1/2017 |
| n5053 | Construct a new 138kV T-Line from Saxony to the existing East Leipsic – Richland line | AEP | 0.15 | 12/1/2017 |
| n5054 | Relocate the existing East Leipsic-Yellow Creek T-Line exit at East Leipsic Station | ATSI | 0.3 | 12/1/2017 |
| n5055 | Reconfigure the East Leipsic-East Lima 138kV circuit to provide a loop to East Leipsic and an extension to Yellow Creek | ATSI | 0.11 | 12/1/2017 |
| n5064 | Re-conductor AEP end of Stillwell – Dumont 345 kV line with 1272 dual ACSR and upgrade the Dumont risers | AEP | 2 | 5/1/2018 |
| n5065 | Re-conductor or rebuild the Eugene – Dequine 345 kV line and replace the Dequine riser | AEP | 88.3 | 5/1/2018 |
| n5067 | Upgrade the line terminal equipment on the 115 kV to Mainesburg at the Mansfield substation | PENELEC | 0.08 | 9/1/2019 |

Attachment D - Interconnection Network Upgrades

| Upgrade ID | Description | Transmission Owner | Cost Estimate (\$M) | Required IS Date |
|------------|--|--------------------|---------------------|------------------|
| n5068 | Replace Wave Trap on the 230 kV Hillside line exit | PENELEC | 0.0085 | 9/1/2019 |
| n5069 | Replace South Homer City Transformer | PENELEC | 14.7947 | 9/1/2019 |
| n5086 | Update relay settings on 345kV Mainesburg line terminal at Homer City substation | PENELEC | 0.1073 | 9/1/2019 |
| n5087 | Update relay settings and re-tune carrier equipment on 345kV Homer City line terminal at Mainesburg substation | PENELEC | 0.1073 | 9/1/2019 |
| n5093 | Construct new 69kV line along the Blooming Grove - West Damascus 69kV like to the AB2-012 Point of Interconnection | PPL | 1.9 | 6/1/2018 |
| n5094 | Install new protection equipment in the existing Blooming Grove substation to support the AB2-012 connection | PPL | 0.158 | 6/1/2018 |
| n5095 | Install new protection equipment in the existing Paupack substation to support the AB2-012 connection | PPL | 0.158 | 6/1/2018 |
| n5104 | Adjust Remote Relay and Metering Settings at Tidd and Wylie Ridge substations | APS | 0.1525 | 6/1/2020 |
| n5105 | Replace the two existing Wave Traps and potential transformers at the Rock Springs 500kV substation to increase their emergency rating from 2905 to 3014 MVA | DPL | 0.42 | 6/1/2018 |
| n5106 | Rebuild the portions of 345 kV lines between the Benton Harbor and Segreto 345 kV substations | AEP | 19 | 10/1/2016 |
| n5108 | Replace the Wayne Junction and Sexton Junction 25 kV circuit breakers at Franklin Substation | APS | 0.71 | 10/31/2019 |
| n5109 | Expand the proposed in-line switching station identified as an attachment facility for PJM project W4-004 & W4-008. Add three (3) 138 kV circuit breakers. The expanded switching station will have a configuration of a breaker and one half bus arrangement. Associated disconnect switches, bus work, SCADA and 138 kV revenue metering will also be required | AEP | 3.45 | 6/1/2019 |
| n5110 | Bring the Tanners Creek – Pendleton 138 kV circuit into the proposed W4-004 & W4-008 138 kV switching station which will require adding an additional string and three (3) new 138 kV circuit breakers, associated disconnect switches, bus work, SCADA and | AEP | 3.45 | 6/1/2019 |

Attachment D - Interconnection Network Upgrades

| Upgrade ID | Description | Transmission Owner | Cost Estimate (\$M) | Required IS Date |
|------------|---|--------------------|---------------------|------------------|
| | 138 kV revenue metering | | | |
| n5111 | Install line protection and controls at the newly expanded 138 kV switching station | AEP | 0.25 | 6/1/2019 |
| n5112 | Update relay settings at Madison 138 kV substation | AEP | 0.05 | 6/1/2019 |
| n5113 | Update relay settings at Tanners Creek 138 kV substation | AEP | 0.05 | 6/1/2019 |
| n5114 | Update line protection and controls at Pendleton 138 kV substation | AEP | 0.2 | 6/1/2019 |
| n5115 | Build a new 230 kV line terminal at the Indian River 230 kV North Substation. The new terminal will be designed and constructed off an existing breaker and a half leg with Indian River AT22 | DPL | 1.3 | 3/1/2020 |
| n5116 | Build a new 230 kV line terminal at the Indian River 230 kV North Substation. This project will require the expansion of the substation to the northwest, the extension of the end buses, and the construction of a new breaker and a half leg to add one new terminal position | DPL | 3.9 | 3/1/2020 |
| n5117 | Increase the emergency rating of the Milford to Steele 230 kV line by rebuilding the circuit, including the replacement of poles | DPL | 43.9 | 3/1/2020 |
| n5118 | Reconfigure Price 69 kV Substation to be a 4 position ring bus (with provisions to add a 5th position). This will include adding 3 new 69 kV circuit breakers, disconnect switches, CVTs, line relays, breaker relays, and associated bus equipment and support | DPL | 3.4 | 7/1/2017 |
| n5119 | Build a new 138 kV substation with a 3 position ring bus (with provisions to add a 4th position for PJM Queue Project AB2-032) | DPL | 4.6 | 11/1/2017 |
| n5128 | Adjust remote end relaying and metering settings at Potter and Niles Valley 115kV Substations | PENELEC | 0.0127 | 12/1/2017 |
| n5130 | Adjust remote end relaying and metering settings at Highland, Mansfield, and Sammis 345kV Substations | ATSI | 0.0133 | 5/1/2018 |
| n5133 | Build new 69kV transmission line from the Bear Creek tap to the Point of | PPL | 0.754 | 12/31/2016 |

Attachment D - Interconnection Network Upgrades

| Upgrade ID | Description | Transmission Owner | Cost Estimate (\$M) | Required IS Date |
|------------|--|--------------------|---------------------|------------------|
| | Interconnection | | | |
| n5134 | Modify existing protection and communication to accommodate the new AB1-182 interconnection | PPL | 0.25 | 12/31/2016 |
| n5136 | Replace the Beatty road line riser section (sub cond 2-1024.5 ACAR) to increase the ratings on the Adkins – Beatty 345 kV line | Dayton | 0.1 | 6/1/2017 |
| n5144 | Upgrade L10805 Kendall - Lockport 345 kV line conductor | ComEd | 18.2 | 6/30/2019 |
| n5145 | Reconfigure Wilton 765kV bus thereby allowing for 765kV L11216 (currently on Bus 6) to be relocated to Bus 8. Along with this line relocation, installation of 2-765kV BT CB's (6-8 & 8-2) | ComEd | 11 | 6/30/2019 |
| n5146 | Install line riser and connection hardware to accept the Interconnection Customer 2156 ACSS Bluebird conductor terminating at Gilbert 230kV substation | JCPL | 1.45 | 6/1/2020 |
| n5147 | Build new 0.05 mile interconnection of AB1-154 to accommodate reconstruction of the Gilbert 230kV yard as breaker and a half configuration | JCPL | 0.943 | 6/1/2020 |
| n5148 | Install two line terminal breakers, risers, necessary disconnects and controls for the AB1-154 terminal at Gilbert 230kV substation | JCPL | 5.171 | 6/1/2020 |
| n5149 | Install fiber optic cable from Gilbert 230kV to the AB1-154 generator | JCPL | 0.0197 | 6/1/2020 |
| n5150 | Reconstruct Gilbert 230kV yard as a breaker and a half layout | JCPL | 12.155 | 6/1/2020 |
| n5150.1 | Replace Gilbert 230 kV breaker A13 with a 63 kA breaker. Note: the cost of the replacement is lumped in the n5150 Network upgrade | JCPL | 0 | 6/1/2020 |
| n5150.2 | Replace Gilbert 230 kV breaker PV with a 63 kA breaker. Note: the cost of the replacement is lumped in the n5150 Network upgrade | JCPL | 0 | 6/1/2020 |
| n5150.3 | Replace Gilbert 230 kV breaker C11 with a 63 kA breaker. Note: the cost of the replacement is lumped in the n5150 Network upgrade | JCPL | 0 | 6/1/2020 |

Attachment D - Interconnection Network Upgrades

| Upgrade ID | Description | Transmission Owner | Cost Estimate (\$M) | Required IS Date |
|------------|--|--------------------|---------------------|------------------|
| n5150.4 | Replace Gilbert 230 kV breaker 13P with a 63 kA breaker. Note: the cost of the replacement is lumped in the n5150 Network upgrade | JCPL | 0 | 6/1/2020 |
| n5150.5 | Replace Gilbert 230 kV breaker VC with a 63 kA breaker. Note: the cost of the replacement is lumped in the n5150 Network upgrade | JCPL | 0 | 6/1/2020 |
| n5150.6 | Replace Gilbert 230 kV breaker 1216 with a 63 kA breaker. Note: the cost of the replacement is lumped in the n5150 Network upgrade. Note: the cost of the replacement is lumped in the n5150 Network upgrade | JCPL | 0 | 6/1/2020 |
| n5151 | Reconfigure the existing Gilbert - Martins Creek 230kV line (P2016) transmission exit from Gilbert to accommodate the Gilbert substation rebuild | JCPL | 0.898 | 6/1/2020 |
| n5152 | Reconfigure the existing Gilbert - Glen Gardner 230kV line (V1036) transmission exit from Gilbert to accommodate the Gilbert substation rebuild | JCPL | 0.931 | 6/1/2020 |
| n5153 | Reconfigure the existing Gilbert - Morristown 230kV line (V1036) transmission exit from Gilbert to accommodate the Gilbert substation rebuild | JCPL | 0.918 | 6/1/2020 |
| n5154 | Reconfigure the existing Gilbert - PPL Springfield 230kV line (A1015) transmission exit from Gilbert to accommodate the Gilbert substation rebuild | JCPL | 1.42 | 6/1/2020 |
| n5155 | Rebuild existing Gilbert - Bank 16 230kV transmission line at Gilbert to accommodate the Gilbert substation rebuild | JCPL | 1.131 | 6/1/2020 |
| n5156 | Rebuild existing Gilbert - Bank 13 230kV transmission line at Gilbert to accommodate the Gilbert substation rebuild | JCPL | 0.752 | 6/1/2020 |
| n5157 | Reconfigure the existing Gilbert – Flanders – Gilbert – Pequest River 115kV transmission line near the Gilbert substation to accommodate the Gilbert substation rebuild | JCPL | 0.76 | 6/1/2020 |
| n5158 | Reconfigure the existing Gilbert JC - Raubsville ME 34.5kV transmission line near the Gilbert substation to accommodate the Gilbert substation rebuild | JCPL | 0.417 | 6/1/2020 |

Attachment D - Interconnection Network Upgrades

| Upgrade ID | Description | Transmission Owner | Cost Estimate (\$M) | Required IS Date |
|------------|--|--------------------|---------------------|------------------|
| n5159 | Reconfigure the existing Gilbert - Bank 11 34.5kV transmission line near the Gilbert substation to accommodate the Gilbert substation rebuild | JCPL | 0.245 | 6/1/2020 |
| n5160 | Upgrade Gilbert - Morris Park relaying at Morris Park substation | JCPL | 0.465 | 6/1/2020 |
| n5161 | Upgrade Gilbert - Morristown relaying at Morristown substation | JCPL | 0.352 | 6/1/2020 |
| n5162 | Upgrade Gilbert - Glen Gardener relaying at Glen Gardener substation | JCPL | 0.449 | 6/1/2020 |
| n5163 | Upgrade Gilbert-Springfield relaying at Springfield substation | JCPL | 0.479 | 6/1/2020 |
| n5164 | Install fiber optic cable from Gilbert transformer 11 low side to Gilbert, from Gilbert 230kV to the Bank 13, and from Gilbert 230kV to the CT9 | JCPL | 0.0814 | 6/1/2020 |
| n5165 | Re-conductor 11.9 miles of Gilbert - Springfield 230kV circuit replacing 1590 ACSR with 1590 ACSS | JCPL | 15.325 | 6/1/2020 |
| n5166 | Re-conductor approximately 1700 feet of transmission three-phase 1590 ACSR with 1590 ACSS. Re-conductor approximately 50 feet of substation deadend downcomer three-phase 1590 ACSR with 1590 ACSS | JCPL | 0.5 | 6/1/2020 |
| n5170 | Tap Juniata - Alburtis 500 kV line to create a new DAUP 500kV station, and build 500kV line from Sunberry 500kV station to the new DAUP 500kV station | PPL | 200 | 9/30/2019 |
| n5171.1 | Replace Gang operated circuit breaker at Kewanee TSS 138 kV bus 2 (circuit 7411) with Independent Pole Operated breaker | ComEd | 0.126 | 12/31/2018 |
| n5171.2 | Replace Gang operated circuit breaker at Kewanee TSS 138 kV bus 1 with Independent Pole Operated breaker | ComEd | 0.126 | 12/31/2018 |
| n5171.3 | Replace Gang operated circuit breaker at Kewanee TSS 138 kV bus 1 (circuit 7423) with Independent Pole Operated breaker | ComEd | 0.126 | 12/31/2018 |
| n5171.4 | Replace Gang operated circuit breaker at Kewanee TSS 138 kV bus 1 (circuit 7421) with Independent Pole Operated breaker | ComEd | 0.126 | 12/31/2018 |
| n5171.5 | Replace Gang operated circuit breaker at Kewanee TSS 138 kV bus 2 (circuit 6101) with Independent Pole Operated breaker | ComEd | 0.126 | 12/31/2018 |

Attachment D - Interconnection Network Upgrades

| Upgrade ID | Description | Transmission Owner | Cost Estimate (\$M) | Required IS Date |
|------------|--|--------------------|---------------------|------------------|
| n5171.6 | Replace Gang operated circuit breaker at Kewanee TSS 138 kV bus 1 (circuit 7413) with Independent Pole Operated breaker | ComEd | 0.126 | 12/31/2018 |
| n5173 | Replace dual primary relaying at U4-027 138 kV substation | ComEd | 1 | 12/31/2018 |
| n5174 | Install new 230kV series reactor and required associated substation equipment at Erie East substation | PPL | 10 | 1/31/2019 |
| n5175 | Upgrade substation equipment to add a fourth ring bus position at Mackeys substation | Dominion | 1.5 | 11/15/2017 |
| n5178.1 | Replacement of 345kV breaker at Sta 6 Byron BT5-6 with 2-cycle IPO breaker | ComEd | 3 | 6/1/2019 |
| n5178.2 | Replacement of 345kV breaker at Sta 6 Byron BT4-5 with 2-cycle IPO breaker | ComEd | 3 | 6/1/2019 |
| n5178.3 | Replacement of 345kV breaker at Sta 6 Byron BT11-12 with 2-cycle IPO breaker | ComEd | 3 | 6/1/2019 |
| n5178.4 | Replacement of 345kV breaker at Sta 6 Byron BT12-13 with 2-cycle IPO breaker | ComEd | 3 | 6/1/2019 |
| n5179 | Installation of about 50 miles of 345kV line from AB1-089/AB1-090 to Wayne | ComEd | 100 | 6/1/2019 |
| n5179.1 | Installation of 2-345kV breakers at Wayne and 3-345kV breakers at AB1-089/AB1-090 terminal station | ComEd | 15 | 6/1/2019 |
| n5191 | Build a three breaker ring bus at Occoneechee 115kV substation | Dominion | 5.56544 | 1/1/2019 |
| n5192 | Install transmission structures on the Carolina – Jackson DP 115 kV line to split the existing line and connect new substation | Dominion | 0.49715 | 1/1/2019 |
| n5193 | Upgrade relaying on the Carolina – Earleys 115 kV line to accommodate new generation and interconnection substation | Dominion | 0.10288 | 1/1/2019 |
| n5194.1 | Replace 345kV Circuit Breaker with a 80kA Breaker B5213(GEN B) at Sammis substation | ATSI | 0.765 | 10/20/2017 |
| n5194.10 | Replace 345kV Circuit Breaker with a 80kA Breaker HIL-W.B(B280) at Sammis substation | ATSI | 0.765 | 10/20/2017 |
| n5194.11 | Replace 345kV Circuit Breaker with a 80kA Breaker HL-GEN3(B278) at Sammis substation | ATSI | 0.765 | 10/20/2017 |
| n5194.12 | Replace 345kV Circuit Breaker with a 80kA Breaker S.CAN-W(B290) at Sammis substation | ATSI | 0.765 | 10/20/2017 |
| n5194.13 | Replace 345kV Circuit Breaker with a 80kA Breaker SN-GEN5(B287) at Sammis | ATSI | 0.765 | 10/20/2017 |

Attachment D - Interconnection Network Upgrades

| Upgrade ID | Description | Transmission Owner | Cost Estimate (\$M) | Required IS Date |
|------------|---|--------------------|---------------------|------------------|
| | substation | | | |
| n5194.14 | Replace 345kV Circuit Breaker with a 80kA Breaker SR-W.BUS(B17) at Sammis substation | ATSI | 0.765 | 10/20/2017 |
| n5194.15 | Replace 345kV Circuit Breaker with a 80kA Breaker STRGEN.4(B14) at Sammis substation | ATSI | 0.765 | 10/20/2017 |
| n5194.16 | Replace 345kV Circuit Breaker with a 80kA Breaker TR-GEN6(B295) at Sammis substation | ATSI | 0.765 | 10/20/2017 |
| n5194.17 | Replace 345kV Circuit Breaker with a 80kA Breaker TRW.BUS(B298) at Sammis substation | ATSI | 0.765 | 10/20/2017 |
| n5194.2 | Replace 345kV Circuit Breaker with a 80kA BreakerB5218(GEN B) at Sammis substation | ATSI | 0.765 | 10/20/2017 |
| n5194.3 | Replace 345kV Circuit Breaker with a 80kA Breaker BVR VLY(B456) at Sammis substation | ATSI | 0.765 | 10/20/2017 |
| n5194.4 | Replace 345kV Circuit Breaker with a 80kA Breaker BVR VLY(B459) at Sammis substation | ATSI | 0.765 | 10/20/2017 |
| n5194.5 | Replace 345kV Circuit Breaker with a 80kA Breaker GEN.3-E(B279) at Sammis substation | ATSI | 0.765 | 10/20/2017 |
| n5194.6 | Replace 345kV Circuit Breaker with a 80kA Breaker GEN.4-E.(B11) at Sammis substation | ATSI | 0.765 | 10/20/2017 |
| n5194.7 | Replace 345kV Circuit Breaker with a 80kA Breaker GEN.5-E(B284) at Sammis substation | ATSI | 0.765 | 10/20/2017 |
| n5194.8 | Replace 345kV Circuit Breaker with a 80kA Breaker GEN.6-E.B(B5) at Sammis substation | ATSI | 0.765 | 10/20/2017 |
| n5194.9 | Replace 345kV Circuit Breaker with a 80kA Breaker GEN.7-E(B453) at Sammis substation | ATSI | 0.765 | 10/20/2017 |
| n5195 | Replace 138kV Circuit Breakers B16, B6, and B65 at Evergreen substation | ATSI | 0.76 | 10/20/2017 |
| n5196 | Install a new AB1-105 Interconnection substation, 345kV 3-breaker ring bus along the Hannah-Highland line | ATSI | 8.7236 | 10/20/2017 |
| n5197 | Loop the Hanna-Highland 345kV circuit into the new 345kV ring bus approximately 1.3 circuit miles southwest of Highland substation to create a new circuit from Highland substation to the new ring bus | ATSI | 0.6839 | 10/20/2017 |
| n5198 | Loop the Hanna-Highland 345kV circuit into the new 345kV ring bus approximately 1.3 circuit miles southwest of Highland substation to create a new circuit from Hanna substation to the new ring bus | ATSI | 0.6709 | 10/20/2017 |

Attachment D - Interconnection Network Upgrades

| Upgrade ID | Description | Transmission Owner | Cost Estimate (\$M) | Required IS Date |
|------------|---|--------------------|---------------------|------------------|
| n5199 | Install new line relaying for future AB1-105 Interconnect line exit at Highland substation | ATSI | 0.1609 | 10/20/2017 |
| n5200 | Install new communications equipment at existing Hanna substation for the future AB1-105 Interconnect and install new line relaying panel | ATSI | 0.2241 | 10/20/2017 |
| n5201 | Install Fiber Optic Cable from the AB1-105 Interconnection to the Highland substations and back, approximately 2.9 miles each way | ATSI | 0.5055 | 10/20/2017 |
| n5205 | Loop existing Harrison-Wylie Ridge 500 kV transmission line into proposed Strope Road substation, approximately one span (at Strope Road Loop, Harrison-Wylie Ridge 500 kV line). | APS | 2.3293 | 7/1/2019 |
| n5206 | Replace 6 345 kV breakers with 3000A, 63 kA breakers at Wylie Ridge substation. Estimate assumes foundations, risers, and control cables will be replaced. Rewire 345 kV line transducers | APS | 4.6006 | 7/1/2019 |
| n5207 | Upgrade line relaying on 500 kV Strope Road (former Harrison line) at Wylie Ridge Substation | APS | 0.4181 | 7/1/2019 |
| n5208 | Upgrade line relaying on 500 kV Strope Road (former Wylie Ridge) line at Harrison Substation | APS | 0.4181 | 7/1/2019 |
| n5209 | Install Relay for breaker failure lockout trip at South Justice substation | Dominion | 0.04858 | 6/1/2018 |
| n5210.1 | Tap the existing new Orchard – Cardiff 230kV line to install a 230kV 4 position ring bus at Minotola substation, with 4-230 kV breakers | AEC | 11.2 | 6/1/2020 |
| n5210.2 | Install 1-138kV breaker and 1-230/138kV transformer at Minotola Substation | AEC | 5.284 | 6/1/2020 |
| n5210.3 | Install 1-138kV breaker and 1-230/138kV transformer at Minotola Substation | AEC | 5.284 | 6/1/2020 |
| n5211 | Install new 345 kV bay including 2 circuit breakers at Stuart 345 kV substation | Dayton | 2.5 | 6/1/2020 |
| n5212 | Add three new 500 kV breakers and associated equipment to the existing Chickahominy 500 kV substation | Dominion | 6.5 | 3/31/2020 |
| n5215 | Adjust remote end relaying and metering settings at Greencastle 34.5 kV substation | APS | 0.0127 | 9/30/2017 |
| n5216 | Modify relay settings for AC1-039 interconnection at Catoctin substation | APS | 0.0068 | 10/31/2018 |

Attachment D - Interconnection Network Upgrades

| Upgrade ID | Description | Transmission Owner | Cost Estimate (\$M) | Required IS Date |
|------------|--|--------------------|---------------------|------------------|
| n5217 | Modify relay settings for AC1-039 interconnection at Monocacy substation | APS | 0.0068 | 10/31/2018 |
| n5218 | Adjust remote end relaying and metering settings at North Longview 500 kV substation | APS | 0.0127 | 12/31/2017 |
| n5226 | Tap the Morris Park '27051' 12 kV distribution circuit to the AC1-018 POI with a new tap pole and 100K fuses. Install metering CTs and PTs. | JCPL | 0.0865 | 7/1/2019 |
| n5231 | Tap the Englishtown-Monroe (H-34) 34.5 kV line to the AC1-207 POI through one (1) new SCADA-controlled switch | JCPL | 0.1116 | 7/2/2018 |
| n5232 | Install two (2) new SCADA-controlled switches on new poles in the Englishtown - Monroe (H-34) 34.5 kV line on either side of the tap point to the AC1-207 Customer | JCPL | 0.223 | 7/2/2018 |
| n5233 | Adjust remote relay settings on the H-34 terminal at Englishtown Substation | JCPL | 0.0163 | 7/2/2018 |
| n5234 | Adjust remote relay settings on the H-34 terminal at Monroe Substation | JCPL | 0.0163 | 7/2/2018 |
| n5235 | Install Line Terminal for Attachment Line for AA2-077 at Penrose substation | PECO | 1.5 | 5/1/2018 |
| n5236 | Modify relays for AA2-077 at Penrose substation | PECO | 0.25 | 5/1/2018 |
| n5237 | Replace #115 Circuit Breaker at Grays Ferry substation | PECO | 0.5 | 5/1/2018 |
| n5238 | Replace 138kV Circuit Breaker B16 at Crossland Substation | ATSI | 0.2085 | 3/30/2020 |
| n5239 | Adjust remote end relaying and metering settings at Yukon and Hatfield substations | APS | 0.0127 | 1/1/2019 |
| n5240 | Perform a sag study on the Twin – Argenta 345 kV line to determine if the line section can be operated above its emergency rating of 1409 MVA | AEP | 0.2 | 6/1/2020 |
| n5241 | Replace (78-B-1-J) 138kV overdutied breakers, bus work, and ground grid with 145kV 80kA breakers at Bayshore substation | ATSI | 0.8586 | 10/20/2017 |
| n5242 | Replace (78-B-1-K) 138kV overdutied breakers, bus work, and ground grid with 145kV 80kA breakers at Bayshore substation | ATSI | 0.8586 | 10/20/2017 |
| n5243 | Replace (78-B-13103) 138kV overdutied breakers, bus work, and ground grid with 145kV 80kA breakers at Bayshore substation | ATSI | 0.8586 | 10/20/2017 |

Attachment D - Interconnection Network Upgrades

| Upgrade ID | Description | Transmission Owner | Cost Estimate (\$M) | Required IS Date |
|------------|--|--------------------|---------------------|------------------|
| n5244 | Replace (78-B-13104) 138kV overdutied breakers, bus work, and ground grid with 145kV 80kA breakers at Bayshore substation | ATSI | 0.8586 | 10/20/2017 |
| n5245 | Replace (78-B-13252) 138kV overdutied breakers, bus work, and ground grid with 145kV 80kA breakers at Bayshore substation | ATSI | 0.8586 | 10/20/2017 |
| n5246 | Replace (78-B-13253) 138kV overdutied breakers, bus work, and ground grid with 145kV 80kA breakers at Bayshore substation | ATSI | 0.8586 | 10/20/2017 |
| n5247 | Replace (78-B-13254) 138kV overdutied breakers, bus work, and ground grid with 145kV 80kA breakers at Bayshore substation | ATSI | 0.8586 | 10/20/2017 |
| n5248 | Replace (78-B-1-J) 138kV overdutied breakers, bus work, and ground grid with 145kV 80kA breakers at Bayshore substation | ATSI | 0.8586 | 10/20/2017 |
| n5249 | Replace (78-B-2-K) 138kV overdutied breakers, bus work, and ground grid with 145kV 80kA breakers at Bayshore substation | ATSI | 0.8586 | 10/20/2017 |
| n5250 | Install a line tap from Catoctin – Monocacy 34.5 kV line to the Point of Interconnection including the installation of two (2) fully rated load-breaker air switches at the tap point and meter equipment inside the Interconnection Customer facilities | APS | 0.12 | 10/31/2018 |
| n5251 | Re-conductor 0.8 miles of the Casey - Breed 345 kV line | AEP | 0.0007 | 7/1/2017 |
| n5252 | Mitigate the sag on the Wilton - Dumont 765 kV line L11215 to achieve an ALDR that exceeds 6166 MVA | ComEd | 9 | 6/1/2020 |
| n5253 | Re-conductor the ComEd portion of Crete - St John 345 kV line | ComEd | 18 | 6/1/2020 |
| n5254 | Re-conductor the Lee County - Byron 345 kV line | ComEd | 6 | 10/1/2017 |
| n5255 | Adjust Remote Relay and Metering Settings at the Wylie Ridge 345 kV substation | APS | 0.0061 | 6/1/2020 |
| n5257 | Install new transmission structures, as well as 2 switches and one Wave Trap at the new Meherrin substation | Dominion | 0.7 | 3/31/2018 |
| n5258 | Install 138kV three breaker ring bus connector station for new customer generation addition along the Galion-Roberts South 138kV line | ATSI | 5.148 | 6/1/2019 |

Attachment D - Interconnection Network Upgrades

| Upgrade ID | Description | Transmission Owner | Cost Estimate (\$M) | Required IS Date |
|------------|---|--------------------|---------------------|------------------|
| n5259 | Loop the Galion-Roberts South 138kV circuit into the proposed 3-breaker ring bus near tower #3801 at Galion-Roberts South 138kV Loop | ATSI | 0.489 | 6/1/2019 |
| n5260 | Upgrade line relaying for Roberts 138kV line exit and rename for new AB2-131 PJM station at Galion substation | ATSI | 0.178 | 6/1/2019 |
| n5261 | Upgrade line relaying for Galion 138kV line exit and rename for new AB2-131 PJM station at Roberts substation | ATSI | 0.178 | 6/1/2019 |
| n5262 | Install new ADSS fiber build from the proposed ring bus to both Galion and Roberts substations | ATSI | 2.618 | 6/1/2019 |
| n5263 | Rebuild Linden - Tosco 3 230 kV line with paired 795 ACSS | PSEG | 13.65 | 6/1/2021 |
| n5264 | Rebuild TOSCO_2 - VFT 2 230 kV line with paired 1033 ACSS | PSEG | 7.5 | 6/1/2021 |
| n5265 | Rebuild VFT 1 - WARINICO_1 230 kV line with paired 795 ACSS | PSEG | 38.925 | 6/1/2021 |
| n5266 | Install a new GIS Breaker on the spare bay position and associated GIS / AIS bus work, UG cable, relaying, metering at the Bayonne 345kV substation | PSEG | 18.9 | 6/1/2021 |
| n5268 | Rebuild SEWAREN-MINUEST_R 230 kV line with paired 795 ACSS | PSEG | 30.844 | 6/1/2019 |
| n5269 | Wreck & Rebuild MINUEST_R - LINDEN 230 kV line with paired 795 ACSS | PSEG | 34.781 | 6/1/2019 |
| n5270 | Rebuild WARINICO_2 - ALDENE_4 230 kV line with 1590 ACSS | PSEG | 8.594 | 6/1/2019 |
| n5271 | Rebuild METUCHEN - NEWDOVR_H 230 kV line with paired 795 ACSS | PSEG | 51.858 | 6/1/2019 |
| n5272 | Rebuild NEWDOVR_H - FANWOOD_1 230 kV line with paired 795 ACSS | PSEG | 47.869 | 6/1/2019 |
| n5273 | Expand the existing substation yard and Install a new breaker position and associated fencing, ground grid, dead end structures, bus work, switches, relaying, and metering at the Metuchen 230 KV substation | PSEG | 10.349 | 6/1/2019 |
| n5286 | Construct a 138kV three breaker ring bus at AB1-107 GT-1 substation, interconnect | ATSI | 5.217 | 10/20/2017 |

Attachment D - Interconnection Network Upgrades

| Upgrade ID | Description | Transmission Owner | Cost Estimate (\$M) | Required IS Date |
|------------|---|--------------------|---------------------|------------------|
| | substation on the Bayshore-GM Powertrain line | | | |
| n5287 | Loop the Oregon Generation facility GT-1 to the Bayshore - GM Powertrain 138kV line at Bayshore - GM Powertrain 138kV - Loop to Interconnection Station for Oregon Gen GT-1_AB1-107 | ATSI | 2.26 | 10/20/2017 |
| n5288 | Provide a single span tap from Lallendorf substation ring bus to Oregon Generation facility Steam Turbine at Lallendorf Tap for Oregon Gen Steam Turbine_AB1-107 | ATSI | 0.34 | 10/20/2017 |
| n5289 | Replace line relaying on the Bayshore (AB1-1007 GT-1) 138kV Line at the GM Powertrain substation | ATSI | 0.208 | 10/20/2017 |
| n5290 | Upgrade 138kV line relaying to GM Powertrain (AB1-107 GT-1) 138kV Line at Bayshore substation | ATSI | 0.203 | 10/20/2017 |
| n5291 | Interconnection (GT-1) to Bayshore and GM Powertrain substations. Install Fiber Optic Cable from Interconnection (GT-1) to Bayshore substations and back, approximately 1.8 miles. Install Fiber Optic Cable from Interconnection (GT-1) to GM Powertrain substations | ATSI | 1.048 | 10/20/2017 |
| n5292 | Install a 345kV Breaker and Line terminal for the AB1-107 ST, GT2 Interconnection at Lallendorf substation | ATSI | 1.699 | 10/20/2017 |
| n5293 | Install new relaying on Ottawa line at Greenfield substation | ATSI | 0.245 | 10/20/2017 |
| n5294 | Install new breaker bay and line exit to Greenfield at Ottawa substation | ATSI | 1.58 | 10/20/2017 |
| n5295 | Engineering and Construction Oversight at TSS 92 McLean substation | ComEd | 1.36 | 12/1/2018 |
| n5296 | Transmission Line Cut In and Turning Structures at TSS 92 McLean substation | ComEd | 3.2 | 12/1/2018 |
| n5297 | Upgrade Relay, Protection, and Communication equipment at TSS80 Pontiac substation | ComEd | 0.22 | 12/1/2018 |
| n5298 | Upgrade Relay, Protection, and | ComEd | 0.025 | 12/1/2018 |

Attachment D - Interconnection Network Upgrades

| Upgrade ID | Description | Transmission Owner | Cost Estimate (\$M) | Required IS Date |
|------------|---|--------------------|---------------------|------------------|
| | Communication equipment at RP4 Brokaw substation | | | |
| n5299 | Build a new 138 kV terminal off of the new 138 kV substation created for PJM Queue Project AB1-141 | DPL | 1 | 11/1/2017 |
| n5300 | Rebuild a small section of the Middletown Tap – Mt. Pleasant 138 kV circuit, install new poles, and re-mount the 138 kV disconnect switches | DPL | 0.0008 | 11/1/2017 |
| n5301 | Rebuild a small section of the Townsend - Middletown Tap 138 kV circuit, install new poles, and re-mount the 138 kV disconnect switches | DPL | 0.0008 | 11/1/2017 |
| n5302 | Mitigate sag limits on the Wayne – Tollway ; B 345 kV line | ComEd | 3 | 6/1/2018 |
| n5303 | Rebuild/Re-conductor 40.61 miles of the AEP owned section of the Olive - University Park 345 kV ACSR/PE 1414 62/19 line section 1 and replace Olive switches and riser | ComEd | 82.6 | 6/1/2020 |
| n5304 | Re-conductor 0.08 miles of the ACSR 1590 (54/19) Falcon conductor section 2, replace the George Washington Wave Trap (2000 A) and replace the Kammer Wave Trap (2000 A) | AEP | 0.3 | 2/15/2020 |
| n5305 | Replace (78-B-3-J) 138kV overdutied breakers, bus work, and ground grid with 145kV 80kA breakers at Bayshore substation | ATSI | 0.8586 | 10/20/2017 |
| n5306 | Replace (78-B-3-K) 138kV overdutied breakers, bus work, and ground grid with 145kV 80kA breakers at Bayshore substation | ATSI | 0.8586 | 10/20/2017 |
| n5307 | Replace (78-B-J_L) 138kV overdutied breakers, bus work, and ground grid with 145kV 80kA breakers at Bayshore substation | ATSI | 0.8586 | 10/20/2017 |
| n5308 | Replace (78-B-13251) 138kV overdutied breakers, bus work, and ground grid with 145kV 80kA breakers at Bayshore | ATSI | 0.8586 | 10/20/2017 |

Attachment D - Interconnection Network Upgrades

| Upgrade ID | Description | Transmission Owner | Cost Estimate (\$M) | Required IS Date |
|------------|---|--------------------|---------------------|------------------|
| | substation | | | |
| n5309 | Replace (78-B-13261) 138kV overdutied breakers, bus work, and ground grid with 145kV 80kA breakers at Bayshore substation | ATSI | 0.8586 | 10/20/2017 |
| n5310.1 | Replace Wave Trap at the Twin Branch substation | AEP | 0.4 | 12/1/2016 |
| n5310.2 | Replace substation structure at Argenta substation to accommodate larger wire | AEP | 0.5 | 12/1/2016 |
| n5311 | Rebuild or Re-conductor approximately 30 miles of the Cook – T-094 (Segreto) 345 kV line | AEP | 60 | 12/1/2016 |
| n5312.1 | Replace the Benton 345 kV H Wave Trap | AEP | 0.4 | 6/1/2018 |
| n5312.2 | Replace the Benton 345 kV H Line Riser | AEP | 0.2 | 6/1/2018 |
| n5313 | Upgrade the Monroe – Lallendorf 345 kV line span over the Maumee River | ATSI | 1 | 6/1/2018 |
| n5315 | Re-conductor the Cherry Valley – Garden Prairie 345 kV line and upgrade terminal equipment at both ends | ComEd | 50 | 6/1/2019 |
| n5316 | Re-conductor the Cordova - Nelson 345 kV line and replace station conductor at Cordova | ComEd | 20.2 | 9/1/2015 |
| n5317 | Re-conductor the E. Frankfort – Crete 345 kV line | ComEd | 10 | 7/1/2019 |
| n5318 | Re-conductor the Garden Prairie – Silver Lake 345 kV line and station conductor at both terminals | ComEd | 50 | 6/1/2019 |
| n5319 | Re-conductor the Nelson – Lee County 345 kV line and upgrade station conductor, 2-345kV Bus Tie Circuit Breakers, and disconnect switches at Nelson | ComEd | 15 | 1/9/2017 |
| n5320 | Re-conductor the Pontiac - Dresden 345 kV line | ComEd | 22 | 9/1/2017 |
| n5321 | Re-conductor the Quad Cities – ESS H471 345 kV line and upgrade station conductor at Sterling Steel and Quad Cities | ComEd | 20.2 | 9/1/2015 |
| n5322 | Re-conductor the ESS H471 - Nelson 345 | ComEd | 20.2 | 7/1/2019 |

Attachment D - Interconnection Network Upgrades

| Upgrade ID | Description | Transmission Owner | Cost Estimate (\$M) | Required IS Date |
|------------|---|--------------------|---------------------|------------------|
| | kV line and upgrade station conductor | | | |
| n5323 | Re-conductor the Lee County – Byron 345 kV line, upgrade station conductor, and replace bus disconnect switches at Byron | ComEd | 6.5 | 9/1/2018 |
| n5324 | Re-conductor the AB1-122 Tap – Dresden 345 kV line | ComEd | 20 | 6/1/2020 |
| n5325 | Upgrade remote-end protection, communications & metering equipment at Tidd 345kV substation | APS | 0.45 | 6/1/2020 |
| n5326 | Build a 2nd Nelson - Electric Junction 345 kV line | ComEd | 300 | 9/15/2018 |
| n5327 | Construct a new nine (9) circuit breaker 138 kV switching station physically configured in a breaker and half bus arrangement at or near the existing Ormet 138 kV station site | AEP | 13 | 2/15/2020 |
| n5328 | Install associated protection and control equipment, 138 kV line risers, SCADA, and 138 kV revenue metering at the new switching station | AEP | 2 | 2/15/2020 |
| n5329 | Install revenue metering at the new switching station | AEP | 0.15 | 2/15/2020 |
| n5330 | Retire existing Ormet 138 kV Substation | AEP | 2 | 2/15/2020 |
| n5331 | Upgrade line protection and controls at the Kammer 138 kV substation to coordinate with the new 138 kV switching station | AEP | 0.5 | 2/15/2020 |
| n5332 | Install Primary and Backup RFL Relays on the 372 34.5 kV Circuit at the North Wales substation | PECO | 0.35 | 6/1/2019 |
| n5333 | Replace relaying on the Coneville 46kV line terminal at Potter Substation and install anti-islanding scheme including fiber communication cable | APS | 0.1489 | 9/30/2019 |
| n5334 | Modify remote end relaying to reflect the added 40 MW of Energy at Elderberry 345 kV substation | AEP | 0.025 | 6/1/2018 |
| n5335 | Re-conductor Cherry Valley - Garden PR 345 kV line | AEP | 25 | 6/1/2021 |

Attachment D - Interconnection Network Upgrades

| Upgrade ID | Description | Transmission Owner | Cost Estimate (\$M) | Required IS Date |
|------------|---|--------------------|---------------------|------------------|
| n5336 | Re-conductor Garden PR - Silver Lake 345 kV line | AEP | 25 | 6/1/2021 |
| n5337 | Rebuild 8.3 miles of Burroak – Plymouth 138 kV line | AEP | 10.4 | 6/1/2021 |
| n5338 | Replace Circuit Breaker 7-8 and Circuit Breaker 8-9 at Nelson 345 kV substation | AEP | 6 | 6/1/2021 |
| n5339 | Rebuild Eugene - Cayuga complete line with steel structures and larger conductor -(2)1272ACSR45X7: 3028A rating @ 100C | AEP | 18.6 | 6/1/2021 |
| n5340 | Six Wire the Kyger - Sporn 345 kV No 1 and No 2 Circuits together | AEP | 0.3 | 6/1/2021 |
| n5341 | Mitigate sag limits on 345 kV line 11212 from Loretto - Wilton Center | AEP | 30 | 6/1/2021 |
| n5342 | Re-conductor of Michigan City - Bosserman 138 kV line to 397 ACSS. Michigan City to Laporte is now Michigan City to Bosserman | AEP | 0.5 | 6/1/2021 |
| n5343 | Rebuild 24 miles of 138 kV line from Monticello – Winamac | AEP | 3 | 6/1/2021 |
| n5344 | Replace two MODs at Electric Junction | AEP | 5 | 6/1/2021 |
| n5345 | Replace terminal equipment at Pierce-Foster 345 kV line | AEP | 0.25 | 6/1/2021 |
| n5346 | Mitigate sag on the Pontiac – Loretto 345 kV line | AEP | 12 | 6/1/2021 |
| n5347 | Replace line riser at Muskingum 345 kV substation | AEP | 0.2 | 6/1/2021 |
| n5348 | Re-conductor Lee - Byron 345 kV line | AEP | 0.4 | 6/1/2021 |
| n5349 | Upgrade station conductor at ESS H471 on L0404 | AEP | 57.5 | 6/1/2021 |
| n5350.1 | Replace the Wave Trap (3000A) at Eugene substation | AEP | 0.4 | 6/1/2021 |
| n5350.2 | Build a new 345 kV line from Bunsonville – Eugene substations | AEP | 57.5 | 6/1/2021 |
| n5351 | Install substation relay for transfer trip from Carolina and Palmer Springs substations | Dominion | 0.1791 | 8/31/2018 |
| n5352 | Construct a new three (3) circuit breaker 765 kV switching station physically configured in a breaker and half bus | AEP | 25 | 6/1/2020 |

Attachment D - Interconnection Network Upgrades

| Upgrade ID | Description | Transmission Owner | Cost Estimate (\$M) | Required IS Date |
|------------|---|--------------------|---------------------|------------------|
| | arrangement but operated as a ring-bus to accommodate the interconnection on the Kammer – Vassell 765 kV circuit | | | |
| n5352 | Construct a new three (3) circuit breaker 765 kV switching station physically configured in a breaker and half bus arrangement but operated as a ring-bus to accommodate the interconnection on the Kammer – Vassell 765 kV circuit | AEP | 25 | 6/1/2020 |
| n5353 | Install 765 kV Revenue Metering at the new 765 kV switching station | AEP | 0.465 | 6/1/2020 |
| n5353 | Install 765 kV Revenue Metering at the new 765 kV switching station | AEP | 0.465 | 6/1/2020 |
| n5354 | Install line protection and controls at the new 765 kV switching station | AEP | 1 | 6/1/2020 |
| n5354 | Install line protection and controls at the new 765 kV switching station | AEP | 1 | 6/1/2020 |
| n5355 | Kammer – Vassell 765 kV T-Line Cut In for the new 765 kV switching Station | AEP | 3.1 | 6/1/2020 |
| n5355 | Kammer – Vassell 765 kV T-Line Cut In for the new 765 kV switching Station | AEP | 3.1 | 6/1/2020 |
| n5356 | Upgrade line protection and controls at the Kammer 138 kV substation to coordinate with the new 138 kV switching station | AEP | 0.6 | 6/1/2020 |
| n5357 | Upgrade line protection and controls at the Vassell 765 kV substation to coordinate with the new 765 kV switching station | AEP | 0.6 | 6/1/2020 |
| n5358 | Re-conductor 28 miles of 345kV Wempletown - Byron line and upgrade Substation Conductor at both Wempletown and Byron substations | ComEd | 56.1 | 6/1/2016 |
| n5359 | Re-conductor 40.5 miles of 345kV Silver lake – Garden Prairie (U3-021) line and upgrade Substation Conductor at Silver Lake substation | ComEd | 54.1 | 6/1/2016 |
| n5360 | Re-conductor 13.8 miles of 345kV Cherry Valley – Garden Prairie (U3-021) line | ComEd | 27 | 6/1/2016 |

Attachment D - Interconnection Network Upgrades

| Upgrade ID | Description | Transmission Owner | Cost Estimate (\$M) | Required IS Date |
|------------|---|--------------------|---------------------|------------------|
| n5361 | Re-conductor 2.8 miles of 138kV of Nelson - Rock Falls; and upgrade Substation Conductor at Nelson substation | ComEd | 2.9 | 6/1/2016 |
| n5362 | Re-conductor 40 miles of 345kV Nelson - Cordova line | ComEd | 80 | 6/1/2016 |
| n5363 | Upgrade substation conductor at Nelson substation | ComEd | 0.1 | 6/1/2016 |
| n5364 | Upgrade substation conductor at Electric junction substation | ComEd | 0.1 | 6/1/2016 |
| n5365 | Re-conductor 10.4 miles of 138kV Rock Falls line | ComEd | 10.4 | 6/1/2016 |
| n5366 | Re-conductor 0.045 miles of 138kV Kickapoo - LaSalle County line; and upgrade Substation Conductor at LaSalle County substation | ComEd | 0.145 | 6/1/2016 |
| n5367 | Perform sag study on the Byron to Cherry Valley 345 kV line | ComEd | 0.15 | 6/1/2016 |
| n5368 | Re-conductor 26.9 miles of 138 kV Normandy to Kewanee line | ComEd | 26.9 | 6/1/2016 |
| n5369 | Re-conductor 5.4 miles of 138kV Normandy line | ComEd | 5.4 | 6/1/2016 |
| n5370 | Re-conductor 13.6 miles of 345kV Electric Junction to Lombard line | ComEd | 27.2 | 6/1/2016 |
| n5371 | Re-conductor 6.7 miles of 345kV Byron to Cherry Valley line | ComEd | 13.4 | 6/1/2016 |
| n5372 | Upgrade the substation Conductor at Lasalle County 345 kV substation | ComEd | 0.1 | 6/1/2016 |
| n5373 | Re-conductor 1 mile of 138kV Plano - Plano West Line; and upgrade Substation Conductor at Plano substation | ComEd | 1.1 | 6/1/2016 |
| n5374 | Install 138kV Circuit Breaker at Cherry valley substation | ComEd | 1.5 | 6/1/2016 |
| n5375 | Replace Wave Trap at Belvidere substation | ComEd | 0.1 | 6/1/2016 |
| n5376 | Perform Sag study on the Marengo to Pleasant Valley line and update the Station Conductor at Pleasant Valley substation | ComEd | 4.5 | 6/1/2016 |
| n5377 | Replace 138kV Circuit Breaker at Cherry | ComEd | 1.5 | 6/1/2016 |

Attachment D - Interconnection Network Upgrades

| Upgrade ID | Description | Transmission Owner | Cost Estimate (\$M) | Required IS Date |
|------------|--|--------------------|---------------------|------------------|
| | Valley substation | | | |
| n5378 | Replace (2) Circuit Switches on the Belvidere to Marengo line (one at Belvidere substation and one at Marengo substation) | ComEd | 0.2 | 6/1/2016 |
| n5379 | Replace Wave Trap at Belvidere substation on the Belvidere – B465 line 15624 | ComEd | 0.1 | 6/1/2016 |
| n5380 | Re-conductor 4 miles of 138kV Belvidere to Alpine line | ComEd | 4 | 6/1/2016 |
| n5381 | Upgrade relaying at the Waterman 138 kV substation | ComEd | 0.1 | 6/1/2016 |
| n5382 | Upgrade station conductor at the Waterman substation | ComEd | 0.1 | 6/1/2016 |
| n5383 | Replace 345kV Bus Tie Breaker 1-2 at H471 substation | ComEd | 2 | 6/1/2016 |
| n5384 | Reconductor 8.8 miles of 138kV West Plano to Sandwich line | ComEd | 8.8 | 6/1/2016 |
| n5385 | Re-conductor 12.5 miles of 138kV Nelson to O-029 line | ComEd | 12.5 | 6/1/2016 |
| n5386 | Replace the Disconnect Switches on the Nelson to Rock Fall line at Rock Fall substation | ComEd | 0.05 | 6/1/2016 |
| n5387 | Re-conductor 7.9 miles of 345kV line from Nelson to ESSH471 substations | ComEd | 15.8 | 6/1/2016 |
| n5388 | Replace (2) Disconnects at Nelson – Electric Junction line at Nelson substation | ComEd | 0.1 | 6/1/2016 |
| n5389 | Replace (2) Disconnects on the Nelson – Electric Junction line at Electric-junction substation | ComEd | 0.1 | 6/1/2016 |
| n5390 | Re-conductor 11 miles of line from GardenPL - ESSH71 line | ComEd | 11 | 6/1/2016 |
| n5391 | Replace 345kV bus tie breaker 4-7 at Cherry Valley substation | ComEd | 2 | 6/1/2016 |
| n5392 | Re-conductor 19.472 miles of 345kV line from Byron – Lee County Energy Center and upgrade Substation Conductor at Byron substation | ComEd | 39.044 | 6/1/2016 |
| n5393 | Re-conductor 5.4 miles of 138kV line from O-029 to Normandy substation | ComEd | 5.4 | 6/1/2016 |

Attachment D - Interconnection Network Upgrades

| Upgrade ID | Description | Transmission Owner | Cost Estimate (\$M) | Required IS Date |
|------------|---|--------------------|---------------------|------------------|
| n5394 | Re-conductor 17.9 miles of 138kV line from Normandy to Annawan (U4-027) substation | ComEd | 17.9 | 6/1/2016 |
| n5395 | Replace Wave Trap at Kewanee substation | ComEd | 0.1 | 6/1/2016 |
| n5396 | Re-conductor 6.7 miles of 138kV line from Byron to Cherry Valley substations | ComEd | 13.4 | 6/1/2016 |
| n5397 | Replace TR. 81 138kV Circuit Breaker at Cherry Valley substation | ComEd | 1.5 | 6/1/2016 |
| n5398 | Install an additional (fourth) Auto transformer 300 MVA at Nelson substation | ComEd | 15 | 6/1/2016 |
| n5399 | Replace TR. 84 138kV Circuit Breaker at Nelson substation | ComEd | 1.5 | 6/1/2016 |
| n5400 | Replace two (2) Wave Traps at Quadcities substation | ComEd | 0.2 | 6/1/2016 |
| n5401 | Install 138 kV rated breaker, breaker disconnects, and 138 kV bus including equipment and structures necessary for the installation and operation at the Hillcrest substation | APS | 1.6825 | 10/31/2018 |
| n5402 | Re-conductor the Everts Drive – South Troy 115 kV Line with high temperature conductor | PENELEC | 5.9112 | 6/1/2020 |
| n5403 | Re-conductor ~8.8 miles of the Everts Drive – Mainesburg 115 kV Line with 795 ACSS conductor | PENELEC | 17.5237 | 6/1/2020 |
| n5404 | Update relay settings on the Homer City 345kV Line at Mainesburg substation | PENELEC | 0.0552 | 6/1/2020 |
| n5405 | Modify relaying at East Palmerton 230-69kV Substation | PPL | 0.141 | 12/1/2020 |
| n5406 | Modify relaying at Acahela 230-69kV Substation | PPL | 0.141 | 12/1/2020 |
| n5407 | Build one span of 230 kV attachment line between the AB2-158 generation station and the new AB2-158 switching substation (Desper Substation) | Dominion | 1.2 | 10/1/2018 |
| n5408 | Install metering and associated protection equipment at AB2-158 generation substation | Dominion | 0.6 | 10/1/2018 |

Attachment D - Interconnection Network Upgrades

| Upgrade ID | Description | Transmission Owner | Cost Estimate (\$M) | Required IS Date |
|------------|--|--------------------|---------------------|------------------|
| n5409 | Build the new AB2-158 Switching substation (interconnection substation) | Dominion | 6.3 | 10/1/2018 |
| n5410 | Install Transmission structure in line with South Anna - Louisa 230 kV transmission line to allow the proposed interconnection switching station to be interconnected with the transmission system | Dominion | 1 | 10/1/2018 |
| n5413 | Install a 69 kV Circuit Breaker, SCADA, bus work, metering, and disconnect switches at South Cumberland 69 kV Substation | AEP | 1.25 | 8/31/2017 |
| n5414 | Install line protection and controls at South Cumberland 69 kV Substation | AEP | 0.25 | 8/31/2017 |
| n5415 | Install a 345 kV Circuit Breaker, SCADA, bus work, metering, and disconnect switches at Maddox Creek 345 kV Substation | AEP | 2.5 | 12/31/2019 |
| n5416 | Install line protection and controls at Maddox Creek 345 kV Substation | AEP | 0.65 | 12/31/2019 |
| n5417 | Construct a new three (3) circuit breaker 345 kV switching station along the Desoto – Fall Creek 345 kV Line | AEP | 5.55 | 10/31/2018 |
| n5418 | Upgrade Line Relaying on the Desoto – Fall Creek 345 kV Line | AEP | 0.3 | 10/31/2018 |
| n5418 | Upgrade Line Relaying on the Desoto – Fall Creek 345 kV Line | AEP | 0.3 | 10/31/2018 |
| n5419 | Upgrade Line Relaying on the Desoto – Fall Creek 345 kV Line | AEP | 0.3 | 10/31/2018 |
| n5419 | Upgrade Line Relaying on the Desoto – Fall Creek 345 kV Line | AEP | 0.3 | 10/31/2018 |
| n5420 | Install a 138 kV Circuit Breaker, SCADA, bus work, metering, and disconnect switches at Delano 138 kV Substation | AEP | 0.65 | 10/31/2017 |
| n5421 | Install line protection and controls at Delano 138 kV Substation | AEP | 0.3 | 10/31/2017 |
| n5422 | Install a 138 kV Circuit Breaker, SCADA, bus work, metering, and disconnect switches at Adams 138 kV substation | AEP | 0.65 | 10/31/2017 |
| n5423 | Install line protection and controls at the Adams 138 kV substation | AEP | 0.2 | 10/31/2017 |

Attachment D - Interconnection Network Upgrades

| Upgrade ID | Description | Transmission Owner | Cost Estimate (\$M) | Required IS Date |
|------------|---|--------------------|---------------------|------------------|
| n5424 | Install a 138 kV Circuit Breaker, SCADA, bus work, metering, and disconnect switches at the Seaman 138 kV substation | AEP | 0.55 | 10/31/2017 |
| n5425 | Install line protection and controls at the Seaman 138 kV substation | AEP | 0.2 | 10/31/2017 |
| n5426 | Upgrade Line Relaying on the RP Mone – Maddox Creek 345 kV Line | AEP | 0.025 | 12/31/2019 |
| n5427 | Upgrade Line Relaying on the East Lima – Maddox Creek 345 kV Line | AEP | 0.025 | 12/31/2019 |
| n5428 | Install a 345 kV Circuit Breaker, SCADA, bus work, metering, and disconnect switches at the Hardin Switch 345 kV substation | AEP | 2 | 12/31/2018 |
| n5429 | Install line protection and controls at the Hardin Switch 345 kV substation | AEP | 0.25 | 12/31/2018 |
| n5430 | Upgrade Line Relaying on the East Lima – Marysville 345 kV Line | AEP | 0.025 | 12/31/2018 |
| n5431 | Upgrade Line Relaying on the East Lima – Marysville 345 kV Line | AEP | 0.025 | 12/31/2018 |
| n5432 | Install 1 SCADA-controlled MOAB switch on the tap to the AC2-134 Customer | JCPL | 0.1562 | 12/31/2018 |
| n5433 | Install 2 SCADA-controlled MOAB switches on the Franklin-Sussex 34.5 kV line on either side of the tap to the AC2-134 customer | JCPL | 0.2343 | 12/31/2018 |
| n5434 | Adjust Remote Relay and Metering Settings at Franklin Substation | JCPL | 0.008 | 12/31/2018 |
| n5435 | Adjust Remote Relay and Metering Settings at Branchville Substation | JCPL | 0.008 | 12/31/2018 |
| n5436 | Install 1 SCADA-controlled MOAB switch on the tap to the AC2-143 Customer | JCPL | 0.2092 | 3/1/2019 |
| n5437 | Install 1 SCADA-controlled MOAB switch on the D82 34.5 kV line (Wyckoff Street - Englishtown) adjacent to the tap to the AC2-143 customer | JCPL | 0.2023 | 3/1/2019 |
| n5438 | Revise relay settings on D82 line terminal at Wyckoff Street substation | JCPL | 0.0335 | 3/1/2019 |
| n5439 | Revise relay settings on D82 line terminal at Englishtown substation | JCPL | 0.0335 | 3/1/2019 |
| n5440 | Revise relay settings on D82 line terminal | JCPL | 0.0335 | 3/1/2019 |

Attachment D - Interconnection Network Upgrades

| Upgrade ID | Description | Transmission Owner | Cost Estimate (\$M) | Required IS Date |
|------------|--|--------------------|---------------------|------------------|
| | at Monroe substation | | | |
| n5442 | Rebuild Line #23033 from Cartanza - Mil 230 kV substations | DPL | 39.75 | 6/1/2016 |
| n5443 | Replace auto transformer 2 from Church - Church 69 substation | DPL | 2.75 | 6/1/2016 |
| n5444 | Replace disconnect switch, rebuild line 6704-1 from Church 69 – N. Meredith and replace conductor on 6701-1 line | DPL | 11.3 | 6/1/2016 |
| n5445 | Replace bushing on Auto transformer 1 at Easton 138 kV substation | DPL | 0.08 | 6/1/2016 |
| n5446 | Rebuild Line #22085 from Edgemr5 - Linwood with dual 1590 ACSR | DPL | 38.25 | 6/1/2016 |
| n5447 | Rebuild line #13773 from Farm view - MILF_138 with 954 ACSR 125 C | DPL | 2.7715 | 6/1/2016 |
| n5448 | Rebuild line #13703 from INDRV 2&3 - NELSON and replace substation bus | DPL | 31.53 | 6/1/2016 |
| n5449 | Re-conductor C & D canal crossing from Keen - Steele 23001 line | DPL | 0.32 | 6/1/2016 |
| n5450 | Replace relays on Keen - Steele 230 KV line | DPL | 0.5 | 6/1/2016 |
| n5451 | Rebuild 69 kV line 6705_1 from Laurel - AA1-142 Tap with 954 ACSR | DPL | 10.91 | 6/1/2016 |
| n5452 | Rebuild 69 kV line 6705_1 from Sharptown - AA1-142 Tap with 954 ACSR | DPL | 10.91 | 6/1/2016 |
| n5453 | Rebuild 230 kV line #23076 from Milford - Steele with 1590 ACSR 125 C | DPL | 43.965 | 6/1/2016 |
| n5454 | Rebuild 138 kV line 13707 from Nelson - Vienna with 1590 ACSR | DPL | 17.473 | 6/1/2016 |
| n5455 | Rebuild Line 6705_2 from Sharptown - Vienna 69 kV with 1590 ACSR and upgrade all substation equipment to 2000 A | DPL | 12.4698 | 6/1/2016 |
| n5456 | Replace a 1200 Amp Wave Trap at Robinson substation on the Holland - Robinson 69 kV line | Dayton | 0.04 | 12/1/2019 |
| n5457 | Re-conductor/rebuild the AEP portion of the Adkins-Beatty 345 kV line | Dayton | 26 | 12/1/2019 |
| n5458 | Install circuit breaker to create a new line terminal at Riders Creek substation | Dominion | 2.4689 | 11/15/2019 |

Attachment D - Interconnection Network Upgrades

| Upgrade ID | Description | Transmission Owner | Cost Estimate (\$M) | Required IS Date |
|------------|--|--------------------|---------------------|------------------|
| n5459 | Install Wave Trap and a line CCVT for power Line Carrier communication on the Riders Creek – Mackeys 115 kV line | Dominion | 0.1933 | 11/15/2019 |
| n5460 | Wreck and rebuild the Penniman - Waller 230 kV line | Dominion | 13 | 6/1/2020 |
| n5461 | Wreck and rebuild the Kings Mill - Penniman 230 kV line | Dominion | 6.8 | 6/1/2020 |
| n5462 | Install a third Chesapeake 230/115 kV transformer | Dominion | 7 | 6/1/2020 |
| n5463 | Wreck and rebuild 11 miles of Chesapeake-Greenwich 230 kV line | Dominion | 21.2 | 6/1/2020 |
| n5464 | Replace Wave Traps at both Chickahominy and Elmont 500 kV substations | Dominion | 0.5 | 6/1/2020 |
| n5465 | Wreck and rebuild the Skiff Creek-Kings Mill 230 kV line | Dominion | 8.4 | 6/1/2020 |
| n5466 | Replace Wave Traps at both Chickahominy and Surry 500 kV substations | Dominion | 1 | 6/1/2020 |
| n5468 | Install transfer trip transmitters for anti-islanding scheme on the Trowbridge – Mackeys – Winfall 230 kV line | Dominion | 0.0567 | 12/31/2018 |
| n5470 | Perform a sag study on the Banister - East Danville 138 kV line | AEP | 0.015 | 10/21/2017 |
| n5471 | Perform a sag study on the AC1-083 TAP - Bearskin 138 kV line | AEP | 0.015 | 10/21/2017 |
| n5472 | Perform a sag study on the Wildcat - Hillsboro 138 kV line | AEP | 0.04 | 10/1/2020 |
| n5473 | Re-conductor the Nottingham - Yager 138 kV line | AEP | 30.4495 | 10/21/2020 |
| n5474 | Replace the Wave Traps at the East Lima and Haviland substations | AEP | 0.1 | 10/21/2020 |