



Market Efficiency Update

Transmission Expansion Advisory Committee
March 8, 2018

Version 2




2016/17 Long Term Window BGE Group Analysis Conclusion

- PJM completed analysis for the BGE Group and selected proposal 5E
 - 5E passes all PROMOD sensitivity scenarios
 - Reliability Analysis has been completed and no reliability violation identified as a result of the 5E Market Efficiency proposal
 - Cost/Constructability Analysis completed
- PJM will be recommending BGE's proposal 5E for approval at the April Board meeting.
 - Highest among proposals submitted for the BGE constraints.
 - Fully addresses target congestion driver Conastone – Graceton – Bagley 230 kV
 - Addresses downstream congestion expected to be relieved on the 230 kV & 115 kV system
 - Remaining shifted congestion is within acceptable levels



Trend for Net Load Benefits of Recommended Proposal 5E



Project ID: 201617_1-5E

Proposed by: BGE

Proposed Solution:

Reconductor the Conastone to Graceton 230kV lines. Upgrade substation equipment at Conastone. Add bundled conductors to the Graceton-Bagley-Raphael Road 230kV double circuit lines. Reconductor the Raphael Road to Northeast 230 kV double circuit lines. Upgrade substation equipment at Windy Edge substation.

kV Level: 115/230 kV

In-Service Cost (\$M): \$25.40

B/C: 8.16

PJM Cost Estimate (\$M): \$39.65

B/C: 5.23


In-Service Date: 2021

Target Zone: BGE

ME Constraints:

CONASTONE - GRACETON - BAGLEY 230 kV

Notes: **To be recommended for approval at the April 2018 Board meeting.**



PPL Group Analysis Results

- PJM completed the analysis for the PPL group using the latest posted Market Efficiency base case updated to include the solution selected for the BGE group
- Sensitivity Scenarios considered:
 - No FSA Scenario
 - High/Low Gas Price Forecast (+/- 20%)
 - Low Load Forecast (- 2%)
- Descriptions of submitted proposals included in Appendix B



SUSQ – HARW Congestion Driver Decrease

- Compared to the start of the 2016/17 Window, congestion driver decreased significantly
 - lower load forecast and changes in generation expansion.
- Most of the SUSQ-HARW congestion is driven by PPL FSA units:
 - Sunbury #2 (AA2-182), 977 MW
 - Good Spring Power CC, 337 MW (withdrew October 2017)

Simulated Congestion Susquehanna – Harwood 230 kV

| <i>Susquehanna to Harwood 230 kV</i> | 2021 | 2024 | |
|--|---------------------------------|---------------------------------|--|
| Scenario | Market Congestion (\$ Millions) | Market Congestion (\$ Millions) | Notes |
| Initial Driver (posted November 2016) | \$3.98 | \$5.60 | Facilities Recommended for Proposals Criteria: \$1 million for 2021 and 2024 |
| Base Case (vintage November 2017) | \$2.94 | \$2.27 | 45% congestion decrease compared to initial driver |
| No PPL FSA Sensitivity (vintage November 2017) | \$1.34 | \$0.48 | 80% congestion decrease compared to initial driver |
| Latest Posted Base Case + 5E | \$2.46 | \$1.73 | 56 % congestion decrease compared to initial driver |
| Latest No FSA Sensitivity (5E included) | \$1.41 | \$0.60 | 79% congestion decrease compared to initial driver |

- Congestion Driver
 - Both the reconductoring proposal 2A and the new Harwood - Trexler Run 230 kV line fully solve the SUSQ-HARW congestion driver.
- B/C Ratio
 - Significant decrease in B/C ratios compared to values posted at November 2017 TEAC
 - No proposal passes the 1.25 threshold when considering a PJM wide no FSA sensitivity scenario.

| Proposal Description | Company | ID | Proposal Cost (\$ million) | New B/C Ratios (Base Case with 5E) | |
|--|---------|-----|----------------------------|------------------------------------|---------------|
| | | | | Base Case | no FSA* Units |
| Reconductor Susquehanna - Harwood 230 kV | PPL | 2A | 13.13 | 0.24 | 0.19 |
| New Siegfried 500/230 kV transformer | PPL | 2C | 18.32 | 0.51 | 0.31 |
| New Harwood - Trexler Run 230 kV line | NTD | 18Q | 33.70 | 1.73 | 0.07 |

* No FSA Sensitivity scenario removed all FSA units from PJM.

| Proposal Description | Company | ID | Proposal Cost (\$ million) | Old B/C Ratios (presented Nov 2017 TEAC) | |
|--|---------|-----|----------------------------|--|--------------------|
| | | | | Base Case | no PPL** FSA Units |
| Reconductor Susquehanna - Harwood 230 kV | PPL | 2A | 13.13 | 1.74 | 6.34 |
| New Siegfried 500/230 kV transformer | PPL | 2C | 18.32 | 0.83 | 3.02 |
| New Harwood - Trexler Run 230 kV line | NTD | 18Q | 33.70 | 2.70 | 2.34 |

** No PPL FSA Sensitivity scenario removed FSA units in PPL.

- Base Case includes monitoring of PPL Wescosville supplemental project (s0864).
- s0864 supplemental project changes operations around Wescosville transformer:
 - New Wescosville 230/138 kV transformer is projected to be operated as normally closed
 - Removes the current Wescosville 230/69 kV #2 transformer (currently operated as normally open)
- The new configuration creates a new flow path
 - from Wescosville 500 kV bus, down through Wescosville 500/138 kV transformer, back up through Wescosville 138/230 kV transformer, toward Hosensack 230 kV bus.
- The new configuration changes congestion pattern
 - Susquehanna – Harwood congestion driver is significantly diminished
 - New congestion pattern around Wescosville 500/138 kV transformer


- B/C ratios decreased
 - In the latest analysis, the B/C ratios for all proposals significantly decreased.
- Impact of FSA Units
 - Significant part of the congestion driver is FSA driven.
 - The B/C ratios for all proposals are failing when FSA units are excluded from the base case
- Congestion Pattern
 - SUSQ-HARW congestion driver decreased significantly from the initially posted values.
 - Moreover, the SUSQ-HARW congestion driver disappears with the Wescosville 230/138 kV supplemental project closed and a new congestion pattern is introduced.
 - The new congestion pattern was not evident prior to opening of the window.
- PJM is currently not recommending any proposals in the PPL area.

- PJM will be recommending BGE's proposal 5E for approval at the April Board meeting.
- PJM is not currently recommending any proposals in the PPL area for the 2016/17 Market Efficiency Long Term window.

2018/19 RTEP Long Term Window



2018/19 Market Efficiency Timeline



| Step | Timeline |
|---------------------------------------|-------------------------------|
| Develop Assumptions | March – May 2018 |
| Build Base Case | June – July 2018 |
| Identify Congestion Drivers | August – September 2018 |
| Post Base Case and Congestion Drivers | October 2018 |
| Proposal Window | November 2018 - February 2019 |
| Analysis of Proposed Solutions | March - November 2019 |
| Final TEAC Review and Board Approval | November - December 2019 |

Appendix A

PPL Group Proposals

Project ID: 201617_1-2A

Proposed by: PPL

Proposed Solution:

Reconductor the Susquehanna - Harwood and Susquehanna-Sugarloaf-Harwood 230 kV DCT lines and replace a limited number of structures as necessary to accommodate the heavier conductor.

kV Level: 230 kV

In-Service Cost (\$M): \$13.13

In-Service Date: 2021


Target Zone: PPL

ME Constraints:

SUSQUEHANNA - HARWOOD 230 kV

Notes:

- This is an upgrade.
- Due to different conductor size, 2A has higher ratings than 2B
- **This project is not currently recommended.**



Project ID: 201617_1-2B

Proposed by: PPL

Proposed Solution:

Reconductor the Susquehanna - Harwood and Susquehanna-Sugarloaf-Harwood 230 kV DCT lines and replace a limited number of structures as necessary to accommodate the heavier conductor.

kV Level: 230 kV

In-Service Cost (\$M): \$13.01

In-Service Date: 2021


Target Zone: PPL

ME Constraints:

SUSQUEHANNA - HARWOOD 230 kV

Notes:

- This is an upgrade.
- Due to different conductor size, 2B has lower ratings than 2A
- **This project is not currently recommended.**



Project ID: 201617_1-2C

Proposed by: PPL

Proposed Solution:
Tap the Susquehanna - Wescosville 500 kV line at Siegfried.
Expand Siegfried to include a 500/230 kV substation.

kV Level: 230/500 kV


In-Service Cost (\$M): \$18.32

In-Service Date: 2021

Target Zone: PPL

ME Constraints:
SUSQUEHANNA - HARWOOD 230 kV

- Notes:
- This is an upgrade of Siegfried station
 - **This project is not currently recommended.**



Project ID: 201617_1-10A

Proposed by: Nextera

Proposed Solution: Greenfield
 Tap the Susquehanna - Wescosville 500 kV line near Siegfried and build a new 500/230 kV substation (Spring Hill). Tie Spring Hill 230 kV into the existing Siegfried 230 kV substation.

kV Level: 230/500 kV

In-Service Cost (\$M): \$33.8


In-Service Date: 2021

Target Zone: PPL

ME Constraints:
 SUSQUEHANNA - HARWOOD 230 kV

Notes:

- This is a greenfield project
- This project is not currently recommended.



Project ID: 201617_1-18G

Proposed by: Northeast Transmission Development

Proposed Solution: Greenfield
 Tap the Susquehanna - Wescosville 500 kV line near Siegfried and build a new 500/230 kV substation (Fells Creek). Tie the Fells Creek 230 kV into the existing Siegfried 230 kV substation.

kV Level: 230/500 kV

In-Service Cost (\$M): \$32.9


In-Service Date: 2021

Target Zone: PPL

ME Constraints:
 SUSQUEHANNA - HARWOOD 230 kV

Notes:

- This is a greenfield project
- **This project is not currently recommended.**



Project ID: 201617_1-18Q

Proposed by: Northeast Transmission Development

Proposed Solution: Greenfield
 Tap the Catawissa - Frackville 230 kV line and build a new 230 kV switchyard (Trexler Run). Build a new Harwood - Trexler Run 230 kV line.

kV Level: 230 kV

In-Service Cost (\$M): \$33.7


In-Service Date: 2021

Target Zone: PPL

ME Constraints:
 SUSQUEHANNA - HARWOOD 230 kV

Notes:

- This is a greenfield project
- **This project is not currently recommended.**




Appendix B – PPL Supplemental Project Wescosville Transformer 230/138 kV



PPL Transmission Zone (presented at TEAC 04/09/2015)

- S0864 Supplemental Upgrade Scope Change:
- Old Scope:
Rebuild approximately 10 miles of the Hosensack-Wescosville 230 kV line to 500 kV and upgrade Wescosville 500-138 kV Substation.
- New Scope:
 - Build approximately 6 miles 500 kV 2nd circuit on the existing Alburdis – Breinigsville.
 - Reconfigure the Wescosville 500 kV station to double breaker arrangement.
 - Install a new Wescosville 230/138 kV transformer.
- Estimated Project Cost:
\$ 58.4 M
- Projected IS Date:
12/31/2017

Note: New Projected IS Date is 3/1/2019



- Revision History
 - V1 – 3/05/2018 – Original Version Posted to PJM.com
 - V2 – 3/20/2018 – Slide 5 updated with independent cost estimate and adjusted B/C ratio for project 5E reflecting the information which was presented at the March 8, 2018 meeting