

Transmission Expansion Advisory Committee – JCPL Supplemental Projects

May 9, 2023

Solutions

Stakeholders must submit any comments within 10 days of this meeting in order to provide time necessary to consider these comments prior to the next phase of the M-3 process

Need Number(s): JCPL-2019-010,012,019

Process Stage: Solution Meeting 05/09/2023

Previously Presented: Need Meeting 01/11/2019

Project Driver(s):


*Equipment Material Condition, Performance and Risk
Operational Flexibility and Efficiency*

Specific Assumption Reference(s)

System Performance Projects Global Factors

- System reliability and performance
 - Substation/line equipment limits
- Upgrade Relay Schemes
- Relay schemes that have a history of misoperation
 - Obsolete and difficult to repair communication equipment (DTT, Blocking, etc.)
 - Communication technology upgrades
 - Bus protection schemes

Continued on next slide...



Problem Statement


- FirstEnergy has identified protection schemes using a certain vintage of relays and communication equipment that have a history of misoperation.
- Proper operation of the protection scheme requires all the separate components perform adequately during a fault.
- In many cases the protection equipment cannot be repaired due to a lack of replacement parts and available expertise in the outdated technology.
- Transmission line ratings are limited by terminal equipment.

JCPL-2019-	Transmission Line / Substation Locations	Existing Line Rating (SN / SE)	Existing Conductor Rating (SN / SE)	Limiting Terminal Equipment
010	Pohatcong – West Wharton 230 kV Line	678 / 813	709 / 869	Line Relaying, Circuit Breaker, Line Trap, Substation Conductor
012	Greystone – West Wharton 230 kV Line	678 / 813	709 / 869	Substation Conductor, Current Transformer
019	Chester – Glen Gardner 230 kV Line	650 / 817	709 / 869	Substation Conductor

Need Number: JCPL-2019-010

Problem Statement


- FirstEnergy has identified protection schemes using a certain vintage of relays and communication equipment that have a history of misoperation.
- Proper operation of the protection scheme requires all the separate components perform adequately during a fault.
- In many cases the protection equipment cannot be repaired due to a lack of replacement parts and available expertise in the outdated technology.
- Transmission line ratings are limited by terminal equipment.



Need Number: JCPL-2019-012

Problem Statement


- FirstEnergy has identified protection schemes using a certain vintage of relays and communication equipment that have a history of misoperation.
- Proper operation of the protection scheme requires all the separate components perform adequately during a fault.
- In many cases the protection equipment cannot be repaired due to a lack of replacement parts and available expertise in the outdated technology.
- Transmission line ratings are limited by terminal equipment.



Need Number: JCPL-2019-019

Problem Statement

- FirstEnergy has identified protection schemes using a certain vintage of relays and communication equipment that have a history of misoperation.
- Proper operation of the protection scheme requires all the separate components perform adequately during a fault.
- In many cases the protection equipment cannot be repaired due to a lack of replacement parts and available expertise in the outdated technology.
- Transmission line ratings are limited by terminal equipment.



Need Number	Transmission Line / Substation Locations	New MVA Line Rating (SN / SE)	Scope of Work	Estimated Cost (\$ M)	Target ISD
JCPL-2019-010	Pohatcong – West Wharton 230 kV Line	709 / 869	<ul style="list-style-type: none"> At Pohatcong Mountain and West Wharton Substations, replace relaying, circuit breaker, wave trap, and substation conductor 	\$2.11 M	12/22/2023
JCPL-2019-012	Greystone – West Wharton 230 kV Line	709 / 869	<ul style="list-style-type: none"> At Greystone and West Wharton Substations, replace substation conductor and current transformer 	\$2.36 M	In-Service
JCPL-2019-019	Chester – Glen Gardner 230 kV Line	709 / 869	<ul style="list-style-type: none"> At Chester and Glen Gardner Substations, replace substation conductor 	\$1.86 M	In-Service

Alternatives Considered: Maintain existing condition

Project Status: In construction/In-Service

Model: 2019 RTEP model for 2024 Summer (50/50)

Questions?



Appendix

High level M-3 Meeting Schedule

Assumptions	Activity	Timing
	Posting of TO Assumptions Meeting information	20 days before Assumptions Meeting
	Stakeholder comments	10 days after Assumptions Meeting
Needs	Activity	Timing
	TOs and Stakeholders Post Needs Meeting slides	10 days before Needs Meeting
	Stakeholder comments	10 days after Needs Meeting
Solutions	Activity	Timing
	TOs and Stakeholders Post Solutions Meeting slides	10 days before Solutions Meeting
	Stakeholder comments	10 days after Solutions Meeting
Submission of Supplemental Projects & Local Plan	Activity	Timing
	Do No Harm (DNH) analysis for selected solution	Prior to posting selected solution
	Post selected solution(s)	Following completion of DNH analysis
	Stakeholder comments	10 days prior to Local Plan Submission for integration into RTEP
	Local Plan submitted to PJM for integration into RTEP	Following review and consideration of comments received after posting of selected solutions

Revision History

4/28/2023 - V1 – Original version posted to pjm.com

5/3/2023 – V1 – Removed need # JCPL-2019-011