

System Operations Subcommittee

PJM Operations Summary

June 2022 Operations

June Events:

2 Synchronized Reserve Event
1 Shared Reserve Events
57 PCLLRW Events
2 Non-Market PCLLRW
10 Hot Weather Alert Event
6 Load Shed Directive
3 Pre-Emergency Load Management Reduction Action
3 Emergency Load Management Reduction Action
1 Maximum Generation Emergency/Load Management Alert
1 TLR

CPS1: 134.29% CPS2: 83.80% BAAL: 99.84%

¹PJM directly measures the total number of BAAL excursions in minutes compared to the total number of minutes within a month with a target value for this performance goal at 99% on a daily and monthly basis. NERC rules limit the recovery period to no more than 30 minutes for a single event.

Synchronized Reserve (2 Event)

Effective Start Time	Effective End Time	Message	Region
06.27.2022 17:01	06.27.2022 17:10	100% Synchronized Reserve Event has been initiated for the PJM_RTO region.	PJM-RTO
06.22.2022 15:06	06.22.2022 15:13	100% Synchronized Reserve Event has been initiated for the PJM_RTO region.	PJM-RTO

Shared Reserve (1 Events)

Effective Start Time	Effective End Time	Message	Region
06.22.2022 17:38	06.22.2022 17:50	PJM provided 141 MW of NPCC Shared Reserves	NPCC

PCLLRW (57 Events)

Effective Start Time	Effective End Time	Message	Region
06.30.2022 17:10		A Post Contingency Local Load Relief Warning has been issued to maintain HEDDINGR 138 KV BB_11748 at 127.0 KV in the AEP for Transmission Contingency Control. Additional Comments: Load -No Generation or Switching available	AEP
06.27.2022 10:36	06.28.2022 02:49	A Post Contingency Local Load Relief Warning has been issued to maintain YELLOWCR 138 KV *E06 at 127.0 KV in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.27.2022 10:33	06.27.2022 21:07	A Post Contingency Local Load Relief Warning has been issued to maintain SBUFFALO 138 KV *E01 at 127.0 KV in the AEP for Transmission Contingency Control. Additional Comments: Post Contingency Switching available	AEP

System Operations Subcommittee

PJM Operations Summary

June 2022 Operations

06.22.2022 14:44	06.27.2022 10:54	A Post Contingency Local Load Relief Warning has been issued to maintain FULTON 138 KV BB_13149 at 127.0 KV in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.22.2022 14:33	06.27.2022 10:54	A Post Contingency Local Load Relief Warning has been issued to maintain HEDDINGR 138 KV BB_11748 at 127.0 KV in the AEP for Transmission Contingency Control. Additional Comments: Load -No Generation or Switching available	AEP
06.22.2022 13:00	06.23.2022 16:11	A Post Contingency Local Load Relief Warning has been issued to maintain MAGLEY 138 KV BB_20071 at 127.0 KV in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.20.2022 18:27	06.20.2022 19:52	A Post Contingency Local Load Relief Warning has been issued to maintain NWASHNTN 69 KV *H02 at 63.5 KV in the AEP for Transmission Contingency Control. Additional Comments: Post Contingency Switching available	AEP
06.16.2022 13:43	06.16.2022 14:35	A Post Contingency Local Load Relief Warning has been issued to maintain BEATTY-MCCOMB at 243.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.16.2022 13:36	06.16.2022 14:35	A Post Contingency Local Load Relief Warning has been issued to maintain BEATTY-MCCOMB at 243.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.16.2022 13:35	06.16.2022 14:35	A Post Contingency Local Load Relief Warning has been issued to maintain GREIF -HYATTCS GRE-HYA at 223.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load -No Generation or Switching available	AEP
06.16.2022 13:34	06.16.2022 14:35	A Post Contingency Local Load Relief Warning has been issued to maintain BIXBY-BUCKEYE at 243.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.16.2022 13:32	06.16.2022 14:35	A Post Contingency Local Load Relief Warning has been issued to maintain CANALAEP-MOUND at 165.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.16.2022 12:23	06.16.2022 14:35	A Post Contingency Local Load Relief Warning has been issued to maintain KENNY-ROBERTS2 at 311.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.16.2022 12:23	06.16.2022 14:35	A Post Contingency Local Load Relief Warning has been issued to maintain CLINTOCS-KARL at 146.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.16.2022 11:36	06.16.2022 14:35	A Post Contingency Local Load Relief Warning has been issued to maintain KENNY-ROBERTS2 at 311.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.16.2022 11:15	06.16.2022 14:35	A Post Contingency Local Load Relief Warning has been issued to maintain CORRIDOR-MORSE at 338.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Post Contingency Generation redispatch available	AEP

System Operations Subcommittee

PJM Operations Summary

June 2022 Operations

06.16.2022 10:35	06.17.2022 15:08	A Post Contingency Local Load Relief Warning has been issued to maintain SATURN 138 KV *E05 at 127.0 KV in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.15.2022 15:34	06.15.2022 16:42	A Post Contingency Local Load Relief Warning has been issued to maintain 02JOHNCT 138 KV *E06 at 127.0 KV in the FE(ATSI) for Transmission Contingency Control. Additional Comments: Load -No Generation or Switching available	FE-ATSI
06.15.2022 14:51	06.15.2022 23:16	A Post Contingency Local Load Relief Warning has been issued to maintain HARRISCS-ZUBER at 180.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.15.2022 13:53	06.15.2022 23:14	A Post Contingency Local Load Relief Warning has been issued to maintain GREIF -HYATTCS GRE-HYA at 223.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load -No Generation or Switching available	AEP
06.15.2022 13:10	06.15.2022 23:14	A Post Contingency Local Load Relief Warning has been issued to maintain CLINTOCS-STCLAIR2 at 180.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.15.2022 12:37	06.15.2022 23:13	A Post Contingency Local Load Relief Warning has been issued to maintain CLINTOCS-KARL at 146.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.15.2022 11:11	06.15.2022 23:13	A Post Contingency Local Load Relief Warning has been issued to maintain KENNY-ROBERTS2 at 312.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.15.2022 08:02	06.15.2022 23:12	A Post Contingency Local Load Relief Warning has been issued to maintain HARRISCS-ZUBER at 187.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.15.2022 07:57	06.15.2022 23:10	A Post Contingency Local Load Relief Warning has been issued to maintain BEXLEY-STCLAIR2 at 250.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.15.2022 06:33	06.17.2022 15:08	A Post Contingency Local Load Relief Warning has been issued to maintain MAGLEY 138 KV BB_20071 at 127.0 KV in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.15.2022 05:09	06.17.2022 15:09	A Post Contingency Local Load Relief Warning has been issued to maintain WCAMBRI2 138 KV BB_12408 at 127.0 KV in the AEP for Transmission Contingency Control. Additional Comments: Post Contingency Switching available	AEP
06.15.2022 04:24	06.15.2022 05:08	A Post Contingency Local Load Relief Warning has been issued to maintain SHARPROA 138 KV BB_7330 at 127.0 KV in the AEP for Transmission Contingency Control. Additional Comments: Post Contingency Switching available	AEP
06.14.2022 18:33	06.15.2022 05:54	A Post Contingency Local Load Relief Warning has been issued to maintain KENNY-ROBERTS2 at 311.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP

System Operations Subcommittee

PJM Operations Summary

June 2022 Operations

06.14.2022 18:31	06.15.2022 05:54	A Post Contingency Local Load Relief Warning has been issued to maintain HESS-VINE at 243.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load -No Generation or Switching available	AEP
06.14.2022 18:29	06.15.2022 05:53	A Post Contingency Local Load Relief Warning has been issued to maintain CLINTOCS-STCLAIR2 at 180.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.14.2022 18:23	06.15.2022 05:53	A Post Contingency Local Load Relief Warning has been issued to maintain WCAMPUS -ROBERTS2 ROB-WCAM at 434.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load -No Generation or Switching available	AEP
06.14.2022 18:21	06.15.2022 05:53	A Post Contingency Local Load Relief Warning has been issued to maintain WCAMPUS -OSU OSU-WCAM at 392.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load -No Generation or Switching available	AEP
06.14.2022 18:19	06.15.2022 05:53	A Post Contingency Local Load Relief Warning has been issued to maintain HESS-OSU at 240.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load -No Generation or Switching available	AEP
06.14.2022 18:17	06.15.2022 05:53	A Post Contingency Local Load Relief Warning has been issued to maintain HALL-L22 at 223.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load -No Generation or Switching available	AEP
06.14.2022 18:15	06.15.2022 05:53	A Post Contingency Local Load Relief Warning has been issued to maintain CLINTOCS-KENNY at 311.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.14.2022 18:13	06.15.2022 05:53	A Post Contingency Local Load Relief Warning has been issued to maintain FIFTHAVE-WILSONCS at 223.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.14.2022 18:13	06.15.2022 05:53	A Post Contingency Local Load Relief Warning has been issued to maintain HESS 1 CB at 183.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load -No Generation or Switching available	AEP
06.14.2022 18:08	06.15.2022 05:53	A Post Contingency Local Load Relief Warning has been issued to maintain BEATTY-WILSONCS at 223.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.14.2022 18:08	06.15.2022 05:53	A Post Contingency Local Load Relief Warning has been issued to maintain FIFTHAVE-HESS at 207.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.14.2022 18:07	06.15.2022 05:53	A Post Contingency Local Load Relief Warning has been issued to maintain BOLTON-HALL BOL-HAL at 223.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.14.2022 18:06	06.15.2022 05:52	A Post Contingency Local Load Relief Warning has been issued to maintain BEATTY-BOLTON BEA-BOL at 223.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load -No Generation or Switching available	AEP

System Operations Subcommittee

PJM Operations Summary

June 2022 Operations

06.14.2022 15:01	06.15.2022 05:53	A Post Contingency Local Load Relief Warning has been issued to maintain HARRISCS-ZUBER at 180.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.14.2022 14:59	06.15.2022 05:53	A Post Contingency Local Load Relief Warning has been issued to maintain HYATTCS-SAWMILL at 434.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.14.2022 14:57	06.15.2022 05:53	A Post Contingency Local Load Relief Warning has been issued to maintain CLINTOCS-STCLAIR2 at 180.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.14.2022 14:56	06.15.2022 05:53	A Post Contingency Local Load Relief Warning has been issued to maintain HESS-VINE at 243.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load -No Generation or Switching available	AEP
06.14.2022 14:54	06.15.2022 05:54	A Post Contingency Local Load Relief Warning has been issued to maintain KENNY-ROBERTS2 at 311.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.14.2022 14:52	06.15.2022 05:54	A Post Contingency Local Load Relief Warning has been issued to maintain CLINTOCS-KARL at 146.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.14.2022 14:51	06.15.2022 05:54	A Post Contingency Local Load Relief Warning has been issued to maintain SAWMILL -DUBLIN SAW-DUB1 at 223.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load -No Generation or Switching available	AEP
06.14.2022 12:37	06.15.2022 23:10	A Post Contingency Local Load Relief Warning has been issued to maintain EELKHART-MOTTVILL at 185.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.14.2022 11:17	06.15.2022 23:09	A Post Contingency Local Load Relief Warning has been issued to maintain WEFOSTOR-02WOODVJ TIE at 189.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Generation - slow response	AEP FE-ATSI
06.14.2022 09:43	06.15.2022 23:08	A Post Contingency Local Load Relief Warning has been issued to maintain EBERSOLE-FOSTORIA EBE-FOS2 at 211.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Generation - slow response	AEP
06.14.2022 05:46	06.15.2022 04:59	A Post Contingency Local Load Relief Warning has been issued to maintain WCAMBRI2 138 KV BB_12408 at 127.0 KV in the AEP for Transmission Contingency Control. Additional Comments: Post Contingency Switching available	AEP
06.13.2022 21:57	06.17.2022 15:10	A Post Contingency Local Load Relief Warning has been issued to maintain BUSSEYVI 138 KV BB_2443 at 127.0 KV in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP
06.13.2022 12:25	06.15.2022 12:38	A Post Contingency Local Load Relief Warning has been issued to maintain BEATTY-ZUBER at 212.0 MVA in the AEP for Transmission Contingency Control. Additional Comments: Load - No Generation or Switching available	AEP

System Operations Subcommittee

PJM Operations Summary

June 2022 Operations

06.13.2022 10:55	06.17.2022 15:09	A Post Contingency Local Load Relief Warning has been issued to maintain LOCKBOUR 138 KV *E11 at 127.0 KV in the AEP for Transmission Contingency Control. Additional Comments: Post Contingency Switching available	AEP
06.08.2022 16:49	06.08.2022 20:39	A Post Contingency Local Load Relief Warning has been issued to maintain HIGHRIDG-SANDYSPR 2314 at 929.0 MVA in the BC for Transmission Contingency Control. Additional Comments: Load -No Generation or Switching available	BGE

Non-Market PCLLRW (2 Events)

Effective Start Time	Effective End Time	Message	Region
06.15.2022 13:17	06.17.2022 23:14	A Non-Market Post Contingency Local Load Relief Warn has been issued to maintain HIGHLND2 69 KV *H03 at 63.5 KV in the AEP for Transmission Contingency Control. Additional Comments: Load -No Generation or Switching available	AEP
06.14.2022 12:11	06.17.2022 15:08	A Non-Market Post Contingency Local Load Relief Warn has been issued to maintain ADAMSIM 138 KV *E04 at 127.0 KV in the AEP for Transmission Contingency Control. Additional Comments: Post Contingency Switching available	AEP

Hot Weather Alert (10 Events)

Effective Start Time	Effective End Time	Message	Region
06.30.2022 07:00	06.30.2022 23:00	A Hot Weather Alert has been issued from 07:00 on 06.30.2022 through 23:00 on 06.30.2022	PJM-RTO
06.22.2022 07:00	06.22.2022 23:00	A Hot Weather Alert has been issued from 07:00 on 06.22.2022 through 23:00 on 06.22.2022	WESTERN
06.21.2022 07:00	06.21.2022 23:00	A Hot Weather Alert has been issued from 07:00 on 06.21.2022 through 23:00 on 06.21.2022	WESTERN
06.20.2022 07:00	06.20.2022 23:00	A Hot Weather Alert has been issued from 07:00 on 06.20.2022 through 23:00 on 06.20.2022	COMED
06.17.2022 07:00	06.17.2022 23:00	A Hot Weather Alert has been issued from 07:00 on 06.17.2022 through 23:00 on 06.17.2022	MIDATL SOUTHERN
06.16.2022 07:00	06.16.2022 23:00	A Hot Weather Alert has been issued from 07:00 on 06.16.2022 through 23:00 on 06.16.2022	WESTERN
06.14.2022 07:00	06.14.2022 23:00	A Hot Weather Alert has been issued from 07:00 on 06.14.2022 through 23:00 on 06.14.2022	WESTERN
06.15.2022 07:00	06.15.2022 23:00	A Hot Weather Alert has been issued from 07:00 on 06.15.2022 through 23:13 on 06.15.2022	WESTERN
06.13.2022 07:00	06.13.2022 23:00	A Hot Weather Alert has been issued from 07:00 on 06.13.2022 through 23:00 on 06.13.2022	EKPC
06.01.2022 07:00	06.01.2022 23:00	A Hot Weather Alert has been issued from 07:00 on 06.01.2022 through 23:00 on 06.01.2022	MIDATL SOUTHERN

System Operations Subcommittee

PJM Operations Summary

June 2022 Operations

Load Shed Directive (6 Events)

Effective Start Time	Effective End Time	Message	Region
06.15.2022 11:40	06.15.2022 22:25	A Load Shed Directive has been issued to mitigate an N-5 cascade analysis at Kenney-Roberts 138kV in AEP. Additional Comments: Additional Comments: Pre-contingency load shed of 115% load dump rating.	AEP
06.15.2022 10:41	06.15.2022 13:55	A Load Shed Directive has been issued to mitigate thermal overloads at Hap Cremean Gahanna 138 KV in AEP.	AEP
06.14.2022 19:21	06.15.2022 02:58	A Load Shed Directive has been issued to mitigate an N-5 cascade analysis at Beatty-Bolton 138kV in AEP. Additional Comments: Pre-contingency load shed of 115% load dump rating.	AEP
06.14.2022 14:35	06.15.2022 02:58	A Load Shed Directive has been issued to mitigate thermal overloads at Marion - Obetz 138 KV in AEP.	AEP
06.14.2022 14:06	06.15.2022 02:58	A Load Shed Directive has been issued to mitigate thermal overloads at Clinton - Karl 138 KV in AEP.	AEP
06.14.2022 14:02	06.15.2022 02:58	A Load Shed Directive has been issued to mitigate thermal overloads at Kenny-Roberts 138 KV in AEP.	AEP

Pre-Emergency Load Management Reduction Action (3 Events)

Effective Start Time	Effective End Time	Message	Region
06.16.2022 12:30	06.16.2022 17:00	A Pre-Emergency Load Mgmt Reduction Action has been issued. Load reduction start times can be found by clicking on the hyperlink(s) in the Regions column. Load reductions should continue until released by PJM. Reductions are mandatory based on product requirements. CSPs should review DR Hub for specific registration details. Lead Time(s) dispatched: Short_60,Quick_30,Long_120 . Product(s) dispatched: Capacity Performance DR Additional Comments: SZ_AEP_MARION_1269364670	AEP_MARION
06.15.2022 10:50	06.15.2022 22:00	A Pre-Emergency Load Mgmt Reduction Action has been issued. Load reduction start times can be found by clicking on the hyperlink(s) in the Regions column. Load reductions should continue until released by PJM. Reductions are mandatory based on product requirements. CSPs should review DR Hub for specific registration details. Lead Time(s) dispatched: Quick_30,Short_60,Long_120 . Product(s) dispatched: Capacity Performance DR Additional Comments: SZ_AEP_MARION_1269364670	AEP_MARION
06.14.2022 15:50	06.14.2022 22:00	A Pre-Emergency Load Mgmt Reduction Action has been issued. Load reduction start times can be found by clicking on the hyperlink(s) in the Regions column. Load reductions should continue until released by PJM. Reductions are mandatory based on product requirements. CSPs should review DR Hub for specific registration details. Lead Time(s) dispatched: Long_120,Short_60,Quick_30 . Product(s) dispatched:	AEP_MARION

System Operations Subcommittee

PJM Operations Summary

June 2022 Operations

		Capacity_Performance_DR Additional Comments: This is for the AEP_MARION subzone of AEP only.	
--	--	--	--

Emergency Load Management Reduction Action (3 Events)

Effective Start Time	Effective End Time	Message	Region
06.16.2022 12:30	06.16.2022 17:00	An Emergency Load Mgmt Reduction Action and a NERC level EEA2 have been issued. Load reduction start times can be found by clicking on the hyperlink(s) in the Regions column. Load reductions should continue until released by PJM. Reductions are mandatory based on product requirements. CSPs should review DR Hub for specific registration details. Lead Time(s) dispatched: Quick_30,Long_120 . Product(s) dispatched: Capacity Performance DR Additional Comments: SZ_AEP_MARION_1269364670	AEP_MARION
06.15.2022 10:50	06.15.2022 22:00	An Emergency Load Mgmt Reduction Action and a NERC level EEA2 have been issued. Load reduction start times can be found by clicking on the hyperlink(s) in the Regions column. Load reductions should continue until released by PJM. Reductions are mandatory based on product requirements. CSPs should review DR Hub for specific registration details. Lead Time(s) dispatched: Quick_30,Long_120 . Product(s) dispatched: Capacity Performance DR Additional Comments: SZ_AEP_MARION_1269364670	AEP_MARION
06.14.2022 15:50	06.14.2022 22:00	An Emergency Load Mgmt Reduction Action and a NERC level EEA2 have been issued. Load reduction start times can be found by clicking on the hyperlink(s) in the Regions column. Load reductions should continue until released by PJM. Reductions are mandatory based on product requirements. CSPs should review DR Hub for specific registration details. Lead Time(s) dispatched: Long_120,Short_60,Quick_30 . Product(s) dispatched: Capacity_Performance_DR Additional Comments: This is for the AEP_MARION subzone of AEP only.	AEP_MARION

Maximum Generation Emergency/Load Management Alert (1 Events)

Effective Start Time	Effective End Time	Message	Region
06.14.2022 15:15	06.14.2022 22:00	A Maximum Generation Emergency/Load Management Alert and an EEA1 have been issued for 06.14.2022 . Maximum Generation Emergency has been called into the operating capacity. Per M-13, Generation Dispatchers should provide PJM with an estimate of the amount of time they need to return to service any generator on a Planned Outage. This 'Early Return Time' should be updated via eDART, and will not affect the Planned Outage estimated end date. Additional Comments: Maximum Emergency Generation has not been called into the Capacity. This is to serve as an alert for Load Management in the AEP zone only.	AEP

TLR (1 Events)

System Operations Subcommittee

PJM Operations Summary

June 2022 Operations

Effective Start Time	Effective End Time	Message	Region
06.13.2022 20:00	06.13.2022 20:00	A TLR Level 3 has been issued for control of flowgate 27750, Peach Bottom - Conastone 5012 500kV Additional Comments: A TLR Level 3B has been issued for control of flowgate 27750, Peach Bottom-Conastone 5012 500kV	PJM-RTO

Voltage Reduction Warning (0 Event(s))

Voltage Reduction (0 Event(s))

Manual Load Dump Event (0 Event(s))

Manual Load Dump Warning (0 Event(s))

Max Emergency Gen Alert (0 Event(s))

Max Emergency Generation (0 Event(s))

Min Gen Alert (0 Event(s))

Min Gen Declaration (0 Event(s))

Local Min Generation Event (0 Event(s))

Conservative Operations (0 Event(s))

Cold Weather Alert (0 Event(s))

High System Voltage (0 Event(s))

Hot Weather Alert (0 Event(s))

HLV Schedule Warning (0 Event(s))

HLV Schedule Action (0 Event(s))

Primary Reserve Warning (0 Event(s))

Manual Load Dump Warning (0 Event(s))

Emergency Energy Request (0 Event(s))

Geomagnetic Disturbance (0 Event(s))