

Soak Time Analysis

Modeling Generation Senior Task Force March 12, 2020



Analysis Methodology

- Select a subset of units, representing various sizes, ages and technology types from around the RTO (18 Steam, 18 CC).
- Use five years of history to get an adequate sample size of starts/soaks.
- Pull data from breaker close to Eco Min and determine the total MWh produced for each soak period.
- Remove "Bad" starts
 - Records that appear to be unit trips
 - Records where insufficient data existed to determine the end of the soak period



Methodology cont.

- Categorize starts as Hot, Warm, or Cold based on the time since the previous shut-down.
- Only consider units that have more than 20 starts for a particular temperature state.
- By unit and temperature state, average the total MWh produced for all soaks.
- Determine the % variation of each soak to the average.
- On a unit-by-unit basis determine how frequently a soak produces MWh +-10%, 25%, 50%, 75%, 90%, 100% of the average.

Simplified Example

| Unit A - Cold Starts | | | | | | | |
|----------------------|-----------|-------------------|--|--|--|--|--|
| Start | Total MWh | Diff from Average | | | | | |
| Start #1 | 20 | 72% | | | | | |
| Start #2 | 30 | 58% | | | | | |
| Start #3 | 40 | 44% | | | | | |
| Start #4 | 50 | 31% | | | | | |
| Start #5 | 60 | 17% | | | | | |
| Start #6 | 70 | 3% | | | | | |
| Start #7 | 80 | 11% | | | | | |
| Start #8 | 100 | 39% | | | | | |
| Start #9 | 120 | 67% | | | | | |
| Start #10 | 150 | 108% | | | | | |
| Avg | 72 | 0% | | | | | |
| Std Dev | 39 | | | | | | |

| 1111 | Cold Starts | Unit A | Unit B | Unit C | Average |
|------|-------------------------|--------|--------|--------|---------|
| | Percent within 10% | 10% | 20% | 0% | 10% |
| | Percent within 25% | 30% | 30% | 0% | 20% |
| | Percent within 50% | 60% | 50% | 30% | 47% |
| | Percent within 75% | 90% | 60% | 40% | 63% |
| | Percent within 90% | 90% | 80% | 80% | 83% |
| | Percent within 100% | 90% | 100% | 90% | 93% |
| | Percent not within 100% | 10% | 0% | 10% | 7% |

Jpjm[®]

Jpjm[®]

Analysis Results

| Percent of Starts with Total MWh within X% of the Average Total MWh produced for all Starts | | | | | | | | | |
|---|-------------------|-----|-----|------------|-----|-----|------------|-------|------------------|
| Unit Type | Temperature State | 10% | 25% | 50% | 75% | 90% | 100% | >100% | Std. Dev/Average |
| CC | Cold | 23% | 50% | 78% | 96% | 97% | 98% | 2% | 66% |
| | Warm | 17% | 40% | 79% | 94% | 98% | 99% | 1% | 63% |
| | Hot | 12% | 33% | 64% | 84% | 91% | 92% | 8% | 63% |
| | Cold | 13% | 39% | 71% | 85% | 89% | 93% | 7% | 83% |
| Steam | Warm | | | | | | | | |
| | Hot | 13% | 30% | 60% | 83% | 89% | 91% | 9% | 77% |