




PJM Dispatch – Deploying Synchronized Reserves

- Two Generation Dispatcher (GD) on shift 24 x 7
 - Coordinate generation moves with transmission
 - Handle ~ 500 phone calls in a 24 hour period
- Area Control Error (ACE) GD
 - SCED case approvals
 - Calling/ releasing units
 - ACE monitoring & adjusting supply to meet demand
- Ancillary Service Optimizer (ASO) GD
 - Ensures reserve & regulation objective is met
 - Assign/De-assign regulation and synchronize reserves
 - Assist ACE GD with monitoring and calling units



- Critical task by the PJM Generation Dispatcher
- PJM will correct for the sudden loss of generation within the PJM Balancing Area
- PJM Generation Dispatcher will make several checks before activating Synchronize Reserves
 - Time of day relative to the load with respect to its rate of change expected
 - Scheduled Generation coming on/off
 - Interchange Schedule changes
 - Regulation available
 - Frequency deviation
 - Tie Schedule deviation



Sudden loss of generation


- NERC Standard BAL-002
- Disturbance Control Standard (DCS)

ACE must return either to

- Zero or
- Its pre-disturbance level


Within fifteen minutes following the start of the disturbance

A Reportable Balancing Contingency Event is the lesser of 900 MWs in the Eastern Interconnection or 80% of the Most Severe Single Contingency




- Sustained Low ACE
 - Usually occurs when there is a sudden unexpected increase in system load, or during significant Morning/Evening pickups
 - Generation slow to respond
 - Combination of events where reserves are needed to maintain PJM ACE within its BAAL (NERC Standard BAL-001-2)
 - PJM frequency bias $\sim 135 \text{ MWs} / .01 \text{ Hz}$ (for a time correction, PJM ACE moves by 270 MWs at the start/ end due to this bias)


- 07:49 Unit Tripped loaded at 1310 MWs
- 07:50 Synchronized reserves activated
- 07:53 ACE returned to Zero
- 08:01 Synchronized reserves ended



Regulation at full raise
 Load was still increasing
 ~6,000 MWS until the morning peak
 Frequency Decaying
 07:06 Synchronized reserves activated
 07:12 Synchronized reserves ended



Rapid Decrease in Generation Causes Frequency Drop



ACE, Hz & Total Generation, 13:30 – 14:00

