

Bay Shore - Davis-Besse - Lake Ave

General Information

| | |
|---|--|
| Proposing entity name | Proprietary business information. |
| Does the entity who is submitting this proposal intend to be the Designated Entity for this proposed project? | Proprietary business information. |
| Company proposal ID | Proprietary business information. |
| PJM Proposal ID | 294 |
| Project title | Bay Shore - Davis-Besse - Lake Ave |
| Project description | 1) Construct a new, single circuit 345kV line from Davis-Besse to Lake Ave via a combination of brownfield and greenfield construction. Greenfield portion will be double-circuit capable towers. 2) Install second circuit on open tower position along the existing Bayshore - Davis-Besse line. 3) Expand the existing Bayshore substation to terminate new line. 4) Expand the existing Lake Ave substation to terminate new line. 5) Expand the existing Davis Besse 345kV substation to terminate two new lines. |
| Email | Proprietary business information. |
| Project in-service date | 06/2030 |
| Tie-line impact | No |
| Interregional project | No |
| Is the proposer offering a binding cap on capital costs? | Yes |
| Additional benefits | Proprietary business information. |

Project Components

1. 3R-1) Lake Ave substation expansion
2. 3A-1) Bay Shore - Davis-Besse 345kV line
3. 3T-1) Davis-Besse substation expansion

- 4. 3Q-1) Bay Shore substation expansion
- 5. 3S-2) Davis-Besse to Lake Ave (Brownfield portion)
- 6. 3S-5) Davis-Besse to Lake Ave 345kV (greenfield portion)

Substation Upgrade Component

| | |
|--------------------------|--|
| Component title | 3R-1) Lake Ave substation expansion |
| Project description | Proprietary business information. |
| Substation name | Lake Ave |
| Substation zone | ATSI |
| Substation upgrade scope | Expand the existing Lake Ave 345kV yard by adding one 345kV bay and one line position. |

Transformer Information

| | |
|---|--|
| None | |
| New equipment description | Add two (2) new 345kV, 5000A, 63kAIC breakers and one (1) breaker and a half (BAAH) bay. |
| Substation assumptions | Assumes expansion of buswork to the south, fully accommodated within utility property as displayed in Attachments 2 and 3. |
| Real-estate description | The substation fenceline requires expansion but work can be contained in utility property. |
| Construction responsibility | Proprietary business information. |
| Benefits/Comments | Proprietary business information. |
| Component Cost Details - In Current Year \$ | |
| Engineering & design | Proprietary business information. |
| Permitting / routing / siting | Proprietary business information. |
| ROW / land acquisition | Proprietary business information. |
| Materials & equipment | Proprietary business information. |
| Construction & commissioning | Proprietary business information. |

| | | |
|---|---|-----------|
| Construction management | Proprietary business information. | |
| Overheads & miscellaneous costs | Proprietary business information. | |
| Contingency | Proprietary business information. | |
| Total component cost | \$6,000,000.00 | |
| Component cost (in-service year) | \$6,958,161.00 | |
| Transmission Line Upgrade Component | | |
| Component title | 3A-1) Bay Shore - Davis-Besse 345kV line | |
| Project description | Proprietary business information. | |
| Impacted transmission line | Bayshore to Davis Besse | |
| Point A | Bay Shore | |
| Point B | Davis-Besse | |
| Point C | | |
| Terrain description | New line will be entirely contained within existing ROW. Terrain is very flat with elevations ranging from ~595ft to ~570ft and consists of mostly agricultural land. | |
| Existing Line Physical Characteristics | | |
| Operating voltage | 345 | |
| Conductor size and type | No existing conductor. Proposing to install new circuit using spare position on existing structure. | |
| Hardware plan description | Existing hardware not impacted by new circuit. New circuit will require new insulators and shield wire/OPGW per transmission owner requirements and design. | |
| Tower line characteristics | Majority of existing line is a single circuit on double-circuit 345kV lattice towers. There are two short portions (2 miles in total) where the structures are single circuit h-frames. | |
| Proposed Line Characteristics | | |
| | Designed | Operating |

| | | |
|---|---|-------------------|
| Voltage (kV) | 345.000000 | 345.000000 |
| | Normal ratings | Emergency ratings |
| Summer (MVA) | 1411.000000 | 1683.000000 |
| Winter (MVA) | 1723.000000 | 1925.000000 |
| Conductor size and type | 2 Horizontal Bundle Cardinal ACSS MA3 | |
| Shield wire size and type | Incumbent / Transmission Owner to select preferred shield wire | |
| Rebuild line length | 20.9 | |
| Rebuild portion description | Utilize spare tower position to install second circuit. | |
| Right of way | It appears new circuit can be fully contained within existing ROW by utilizing existing towers. | |
| Construction responsibility | Proprietary business information. | |
| Benefits/Comments | Proprietary business information. | |
| Component Cost Details - In Current Year \$ | | |
| Engineering & design | Proprietary business information. | |
| Permitting / routing / siting | Proprietary business information. | |
| ROW / land acquisition | Proprietary business information. | |
| Materials & equipment | Proprietary business information. | |
| Construction & commissioning | Proprietary business information. | |
| Construction management | Proprietary business information. | |
| Overheads & miscellaneous costs | Proprietary business information. | |
| Contingency | Proprietary business information. | |
| Total component cost | \$10,500,000.00 | |
| Component cost (in-service year) | \$12,176,781.00 | |

Substation Upgrade Component

| | |
|--------------------------|---|
| Component title | 3T-1) Davis-Besse substation expansion |
| Project description | Proprietary business information. |
| Substation name | Davis-Besse |
| Substation zone | ATSI |
| Substation upgrade scope | Expand the existing Davis Besse 345kV yard by adding one 345kV bay and two line positions. Expansion will require reconfiguration of existing terminals, please see Attachment 2 (Single Line Diagram) and Attachment 3 (General Arrangement) |

Transformer Information

| | |
|---|---|
| None | |
| New equipment description | Add three (3) new 345kV, 5000A, 63kAIC breakers and one (1) breaker and a half (BAAH) bay. Relocate existing 345kV breaker to adjacent bay. |
| Substation assumptions | Assumes use of empty bay for one termination and an expansion of the buswork to the south to accommodate second termination. |
| Real-estate description | The substation fenceline may require expansion but work can be contained in utility property. |
| Construction responsibility | Proprietary business information. |
| Benefits/Comments | Proprietary business information. |
| Component Cost Details - In Current Year \$ | |
| Engineering & design | Proprietary business information. |
| Permitting / routing / siting | Proprietary business information. |
| ROW / land acquisition | Proprietary business information. |
| Materials & equipment | Proprietary business information. |
| Construction & commissioning | Proprietary business information. |
| Construction management | Proprietary business information. |

| | |
|--|--|
| Overheads & miscellaneous costs | Proprietary business information. |
| Contingency | Proprietary business information. |
| Total component cost | \$8,000,000.00 |
| Component cost (in-service year) | \$9,277,547.00 |
| Substation Upgrade Component | |
| Component title | 3Q-1) Bay Shore substation expansion |
| Project description | Proprietary business information. |
| Substation name | Bay Shore |
| Substation zone | ATSI |
| Substation upgrade scope | Expand the existing 345kV Ring by adding an additional breaker and line position. |
| Transformer Information | |
| None | |
| New equipment description | Add one (1) 345kV, 5000A, 63kAIC breaker to existing ring configuration. |
| Substation assumptions | Assumes use of open position in northeast portion of substation, as displayed in Attachments 2 and 3. |
| Real-estate description | Based on publicly available parcel data and imagery, upgrades are expected to fit fully within existing fenceline on incumbent owned property. |
| Construction responsibility | Proprietary business information. |
| Benefits/Comments | Proprietary business information. |
| Component Cost Details - In Current Year \$ | |
| Engineering & design | Proprietary business information. |
| Permitting / routing / siting | Proprietary business information. |
| ROW / land acquisition | Proprietary business information. |

| | |
|---|---|
| Materials & equipment | Proprietary business information. |
| Construction & commissioning | Proprietary business information. |
| Construction management | Proprietary business information. |
| Overheads & miscellaneous costs | Proprietary business information. |
| Contingency | Proprietary business information. |
| Total component cost | \$1,500,000.00 |
| Component cost (in-service year) | \$1,739,540.00 |
| Transmission Line Upgrade Component | |
| Component title | 3S-2) Davis-Besse to Lake Ave (Brownfield portion) |
| Project description | Proprietary business information. |
| Impacted transmission line | Davis-Besse - Lemoyne |
| Point A | Davis-Besse |
| Point B | Handoff north of Toussaint |
| Point C | |
| Terrain description | New line will be entirely contained within existing ROW. Terrain is very flat with elevations ranging from ~595ft to ~580ft and consists of mostly agricultural land. |
| Existing Line Physical Characteristics | |
| Operating voltage | 345 |
| Conductor size and type | No existing conductor. Proposing to install new circuit using spare position on existing structure. |
| Hardware plan description | Existing hardware not impacted by new circuit. New circuit will require new insulators and shield wire/OPGW per transmission owner requirements and design. |
| Tower line characteristics | Existing structures appear to be double-circuit capable lattice towers with only a single circuit installed. |

Proposed Line Characteristics

| | Designed | Operating |
|---|--|-------------------|
| Voltage (kV) | 345.000000 | 345.000000 |
| | Normal ratings | Emergency ratings |
| Summer (MVA) | 1411.000000 | 1683.000000 |
| Winter (MVA) | 1723.000000 | 1925.000000 |
| Conductor size and type | 2 Horizontal Bundle Cardinal ACSS MA3 | |
| Shield wire size and type | Incumbent / Transmission Owner to select preferred shield wire | |
| Rebuild line length | 6 | |
| Rebuild portion description | Utilize spare tower position to install new circuit on Davis-Besse to Lemoyne transmission structures. | |
| Right of way | It appears new circuit can be fully contained within existing ROW by utilizing existing towers. | |
| Construction responsibility | Proprietary business information. | |
| Benefits/Comments | Proprietary business information. | |
| Component Cost Details - In Current Year \$ | | |
| Engineering & design | Proprietary business information. | |
| Permitting / routing / siting | Proprietary business information. | |
| ROW / land acquisition | Proprietary business information. | |
| Materials & equipment | Proprietary business information. | |
| Construction & commissioning | Proprietary business information. | |
| Construction management | Proprietary business information. | |
| Overheads & miscellaneous costs | Proprietary business information. | |

Contingency Proprietary business information.

Total component cost \$3,585,000.00

Component cost (in-service year) \$4,157,501.00

Greenfield Transmission Line Component

Component title 3S-5) Davis-Besse to Lake Ave 345kV (greenfield portion)

Project description Proprietary business information.

Point A handoff north of Toussaint

Point B Lake Ave

Point C

| | Normal ratings | Emergency ratings |
|--|----------------|-------------------|
|--|----------------|-------------------|

| | | |
|--------------|-------------|-------------|
| Summer (MVA) | 1411.000000 | 1683.000000 |
|--------------|-------------|-------------|

| | | |
|--------------|-------------|-------------|
| Winter (MVA) | 1723.000000 | 1925.000000 |
|--------------|-------------|-------------|

Conductor size and type 2 Horizontal Bundle Cardinal ACSS MA3

Nominal voltage AC

Nominal voltage 345

Line construction type Overhead

General route description Route departs from the existing Davis-Besse - Lemoyne 345kV corridor north of the Toussaint substation. The route proceeds south until reaching the Ohio Turnpike, at which point it continues east towards Lake Ave. The route follows the Ohio Turnpike and existing transmission corridors where feasible. See Attachment 11.3S5 for further details.

Terrain description

A detailed inspection of the USGS topographic map reveals relatively consistent, flat lands, with elevation within the Project ranging from a high of 854 ft above sea level to a low of 573 ft above sea level. The Project is located across 3 Level IV ecoregions including Clayey, High Lime Till Plains, Marblehead Drift/Limestone Plain, and Erie Lake Plain. In the Clayey, High Lime Till Plains ecoregion, soils are less productive and more artificially drained than adjacent ecoregions and support fewer swampy areas. The Marblehead Drift/Limestone Plain ecoregion has areas of thin glacial drift and limestone-dolomite ridges and islands. Streams often flow on carbonate bedrock; their character is different from the clayey channels of adjacent ecoregions. Scattered carbonate ridges supported distinctive mixed oak forests and prairies, marl plains had prairies, and the Lake Erie and Sandusky Bay shoreline often supported fens. The Erie Lake Plain ecoregion is a nearly level coastal strip of lacustrine deposits punctuated by beach ridges and swales. Its lake-modified climate sets it apart from other nearby ecoregions and its annual growing season is often several weeks longer than inland areas. According to the NLCD, the Project area (including a 0.5-mi corridor along the proposed line) largely consists of cultivated cropland (~64.6% of the total land cover) followed by deciduous (~14.8%), developed land (open space, low, medium, and high intensity; 9.6%), and hay/pasture (4.1%). The remaining land cover (2.4%) is composed of evergreen forest, mixed forest, herbaceous, shrub/scrub, open water, and barren land.

Right-of-way width by segment

The majority of the route, approximately 93%, will have a ROW width of 150 ft. Approximately 7% of the route will have a ROW width of 100 ft in more congested areas. The proposed right of way will be an expansion of an existing transmission line corridor for approximately 38% of the route length, the remainder will be greenfield ROW.

Electrical transmission infrastructure crossings

See Attachment 4 (Google Earth .kmz file) for crossing locations.

Civil infrastructure/major waterway facility crossing plan

See Attachment 5 (Crossing Plan) and Attachment 4 (Google Earth .kmz file).

| | |
|---|--|
| Environmental impacts | <p>Environmental constraints were evaluated within a 0.25-mi buffer of the project and are manageable through avoidance, minimization, and mitigation strategies incorporated at the onset of the routing/siting process. The proposed corridor crosses numerous aquatic resources, including wetlands, lakes/ponds, and streams but most features could be spanned & avoided with minimal impacts. According to FEMA, multiple 100-year floodplains are crossed by the corridor. This represent total amount of features crossed by the corridor & impacts from the Project would be significantly less. Major watercourses crossed by the Project include the Sandusky, Portage, Sandusky, Huron, and Vermillion Rivers, some of which will require agency authorizations for navigable water crossings. No fatal flaws have been identified for the Project. Multiple previously recorded archaeological sites, cemeteries, & architectural resources were recorded within the corridor. However, no historic districts are crossed by the proposed corridor. Ten federally listed species (2 endangered, 5 threatened, 1 proposed, 1 candidate, and 1 Experimental population) have known ranges within the proposed corridor. No critical habitat for any federally listed species intersects the route. If suitable habitat is identified or regulations change, agency coordination & species-specific surveys will occur. The project intends to follow suggested tree removal windows & general time of year restrictions to avoid/minimize impacts to species such as federally listed bats and migratory birds, among others. Industry standard construction BMPs & avoidance and minimization measures will be used to prevent unanticipated impacts to natural resources to the maximum extent practicable. There are no environmental concerns with the proposed project that cannot be addressed through agency coordination, mitigation, & an in-depth routing/siting process. Please refer to Attachment 8 for additional information</p> |
| Tower characteristics | <p>The proposed structures will be double circuit capable 345kV steel monopoles in a vertical conductor configuration. See structure drawing set included in Attachment 10.</p> |
| Construction responsibility | <p>Proprietary business information.</p> |
| Benefits/Comments | <p>Proprietary business information.</p> |
| Component Cost Details - In Current Year \$ | |
| Engineering & design | <p>Proprietary business information.</p> |
| Permitting / routing / siting | <p>Proprietary business information.</p> |
| ROW / land acquisition | <p>Proprietary business information.</p> |
| Materials & equipment | <p>Proprietary business information.</p> |
| Construction & commissioning | <p>Proprietary business information.</p> |
| Construction management | <p>Proprietary business information.</p> |

Overheads & miscellaneous costs

Proprietary business information.

Contingency

Proprietary business information.

Total component cost

\$227,715,886.58

Component cost (in-service year)

\$264,080,615.00

Congestion Drivers

None

Existing Flowgates

| FG # | Fr Bus No. | From Bus Name | To Bus No. | To Bus Name | CKT | Voltage | TO Zone | Analysis type | Status |
|-----------------|------------|---------------|------------|-------------|-----|---------|---------|-----------------------|----------|
| 2024W1-N1-ST62 | 314991 | 8VALLEY SC | 314926 | 8VALLEY | 1 | 500/500 | 345/345 | Summer Thermal | Included |
| 2024W1-N11-ST25 | 221050 | FRED.RD7 | 221054 | CHESTN7A | 1 | 115 | 232 | Summer N-1-1 Thermal | Excluded |
| 2024W1-32GD-S19 | 238569 | 02BEAVER | 239725 | 02LAKEAVE | 2 | 345 | 202 | 2032 Summer Gen Deliv | Included |
| 2024W1-N1-ST100 | 238549 | 02AVERY | 239108 | 02SHNROK | 1 | 138/138 | 202/202 | Summer Thermal | Included |
| 2024W1-GD-S864 | 238768 | 02GRNFLD | 238974 | 02N DEPT | 1 | 138 | 202 | Summer Gen Deliv | Included |
| 2024W1-GD-S81 | 243560 | 05ROBERT | 243529 | 05KENNY | 1 | 138 | 205 | Summer Gen Deliv | Excluded |
| 2024W1-GD-S851 | 238981 | 02NASA | 238570 | 02BEAVER | 1 | 138 | 202 | Summer Gen Deliv | Included |
| 2024W1-GD-S366 | 235479 | 01JUNCTN | 235467 | 01FRNCHM | 1 | 138 | 201 | Summer Gen Deliv | Included |
| 2024W1-GD-S852 | 238981 | 02NASA | 238570 | 02BEAVER | 1 | 138 | 202 | Summer Gen Deliv | Included |
| 2024W1-GD-S42 | 235490 | 01MORGAN | 235453 | 01CHERYR | 1 | 138 | 201 | Summer Gen Deliv | Included |
| 2024W1-32GD-S23 | 238654 | 02DAV-BE | 241877 | AC2-103 TAP | 1 | 345 | 202 | 2032 Summer Gen Deliv | Included |
| 2024W1-N1-ST93 | 314929 | 8FRONT ROYAL | 314916 | 8MORRSVL | 1 | 500/500 | 345/345 | Summer Thermal | Included |
| 2024W1-GD-S43 | 235490 | 01MORGAN | 235453 | 01CHERYR | 1 | 138 | 201 | Summer Gen Deliv | Included |
| 2024W1-GD-S477 | 243347 | 05TIDD 3-4 | 235311 | 01CARNEG | 1 | 138 | 201/205 | Summer Gen Deliv | Excluded |
| 2024W1-32GD-S22 | 238654 | 02DAV-BE | 241877 | AC2-103 TAP | 1 | 345 | 202 | 2032 Summer Gen Deliv | Included |
| 2024W1-GD-S353 | 238569 | 02BEAVER | 239725 | 02LAKEAVE | 2 | 345 | 202 | Summer Gen Deliv | Included |
| 2024W1-GD-S461 | 290623 | 05KAMMER_RG | 242925 | 05KAMMER | Z1 | 765 | 205 | Summer Gen Deliv | Excluded |
| 2024W1-32GD-S21 | 238654 | 02DAV-BE | 241877 | AC2-103 TAP | 1 | 345 | 202 | 2032 Summer Gen Deliv | Included |

| FG # | Fr Bus No. | From Bus Name | To Bus No. | To Bus Name | CKT | Voltage | TO Zone | Analysis type | Status |
|-----------------|------------|---------------|------------|-------------|-----|---------|---------|-----------------------|----------|
| 2024W1-32GD-S20 | 238654 | 02DAV-BE | 239289 | 02HAYES | 1 | 345 | 202 | 2032 Summer Gen Deliv | Included |
| 2024W1-GD-S850 | 238874 | 02LAKVEW | 238768 | 02GRNFLD | 1 | 138 | 202 | Summer Gen Deliv | Included |
| 2024W1-32GD-S26 | 239289 | 02HAYES | 238569 | 02BEAVER | 1 | 345 | 202 | 2032 Summer Gen Deliv | Included |
| 2024W1-GD-S848 | 238768 | 02GRNFLD | 238981 | 02NASA | 1 | 138 | 202 | Summer Gen Deliv | Included |
| 2024W1-GD-S463 | 290623 | 05KAMMER_RG | 242925 | 05KAMMER | Z1 | 765 | 205 | Summer Gen Deliv | Excluded |
| 2024W1-32GD-S25 | 238654 | 02DAV-BE | 241877 | AC2-103 TAP | 1 | 345 | 202 | 2032 Summer Gen Deliv | Included |
| 2024W1-GD-S849 | 238768 | 02GRNFLD | 238981 | 02NASA | 1 | 138 | 202 | Summer Gen Deliv | Included |
| 2024W1-32GD-S24 | 238654 | 02DAV-BE | 241877 | AC2-103 TAP | 1 | 345 | 202 | 2032 Summer Gen Deliv | Included |
| 2024W1-N1-ST73 | 238768 | 02GRNFLD | 238974 | 02N DEPT | 1 | 138/138 | 202/202 | Summer Thermal | Included |
| 2024W1-GD-S464 | 290623 | 05KAMMER_RG | 242925 | 05KAMMER | Z1 | 765 | 205 | Summer Gen Deliv | Excluded |
| 2024W1-GD-LL8 | 238768 | 02GRNFLD | 238981 | 02NASA | 1 | 138 | 202 | Light Load Gen Deliv | Included |
| 2024W1-GD-S895 | 243347 | 05TIDD 3-4 | 235311 | 01CARNEG | 1 | 138 | 201/205 | Summer Gen Deliv | Excluded |
| 2024W1-N1-ST33 | 238768 | 02GRNFLD | 238981 | 02NASA | 1 | 138/138 | 202/202 | Summer Thermal | Included |
| 2024W1-GD-LL12 | 238590 | 02BRWELL | 238728 | 02FORD | 1 | 138 | 202 | Light Load Gen Deliv | Included |
| 2024W1-N1-ST34 | 238768 | 02GRNFLD | 238981 | 02NASA | 1 | 138/138 | 202/202 | Summer Thermal | Included |
| 2024W1-GD-LL9 | 238981 | 02NASA | 238570 | 02BEAVER | 1 | 138 | 202 | Light Load Gen Deliv | Included |
| 2024W1-GD-LL10 | 238974 | 02N DEPT | 238590 | 02BRWELL | 1 | 138 | 202 | Light Load Gen Deliv | Included |
| 2024W1-N1-ST76 | 238768 | 02GRNFLD | 238974 | 02N DEPT | 1 | 138/138 | 202/202 | Summer Thermal | Included |
| 2024W1-N1-ST103 | 239290 | 02HAYES | 238549 | 02AVERY | 1 | 138/138 | 202/202 | Summer Thermal | Included |
| 2024W1-GD-S400 | 241877 | AC2-103 TAP | 238569 | 02BEAVER | 1 | 345 | 202 | Summer Gen Deliv | Excluded |
| 2024W1-GD-S497 | 314435 | 6SAPONY | 314282 | 6CARSON | 1 | 230 | 345 | Summer Gen Deliv | Included |
| 2024W1-GD-LL5 | 238768 | 02GRNFLD | 238981 | 02NASA | 1 | 138 | 202 | Light Load Gen Deliv | Included |
| 2024W1-N1-ST104 | 239290 | 02HAYES | 238549 | 02AVERY | 1 | 138/138 | 202/202 | Summer Thermal | Included |
| 2024W1-GD-S856 | 238974 | 02N DEPT | 238590 | 02BRWELL | 1 | 138 | 202 | Summer Gen Deliv | Included |
| 2024W1-N1-ST101 | 238549 | 02AVERY | 239108 | 02SHNROK | 1 | 138/138 | 202/202 | Summer Thermal | Included |
| 2024W1-GD-S853 | 238974 | 02N DEPT | 238590 | 02BRWELL | 1 | 138 | 202 | Summer Gen Deliv | Included |
| 2024W1-GD-S495 | 314901 | 8BATH CO | 314991 | 8VALLEY SC | 1 | 500 | 345 | Summer Gen Deliv | Included |
| 2024W1-GD-S793 | 243560 | 05ROBERT | 243529 | 05KENNY | 1 | 138 | 205 | Summer Gen Deliv | Excluded |

| FG # | Fr Bus No. | From Bus Name | To Bus No. | To Bus Name | CKT | Voltage | TO Zone | Analysis type | Status |
|------------------|------------|---------------|------------|-------------|-----|---------|---------|-----------------------|----------|
| 2024W1-GD-S858 | 238590 | 02BRWELL | 238728 | 02FORD | 1 | 138 | 202 | Summer Gen Deliv | Included |
| 2024W1-N1-ST38 | 238874 | 02LAKVEW | 238768 | 02GRNFLD | 1 | 138/138 | 202/202 | Summer Thermal | Included |
| 2024W1-N1-ST39 | 238981 | 02NASA | 238570 | 02BEAVER | 1 | 138/138 | 202/202 | Summer Thermal | Included |
| 2024W1-GD-S885 | 238570 | 02BEAVER | 238845 | 02JONSON | 1 | 138 | 202 | Summer Gen Deliv | Included |
| 2024W1-32GD-S41 | 290608 | 05MARYSVL_RS | 242928 | 05MARYSV | Z1 | 765 | 205 | N/A | Excluded |
| 2024W1-N1-ST120 | 314901 | 8BATH CO | 314991 | 8VALLEY SC | 1 | 500/500 | 345/345 | Summer Thermal | Included |
| 2024W1-GD-S866 | 238549 | 02AVERY | 239108 | 02SHNROK | 1 | 138 | 202 | Summer Gen Deliv | Included |
| 2024W1-GD-S489 | 243131 | 05TILTON | 235428 | 01WINDSR | 1 | 138 | 201/205 | Summer Gen Deliv | Excluded |
| 2024W1-GD-S503 | 290608 | 05MARYSVL_RS | 242928 | 05MARYSV | Z1 | 765 | 205 | Summer Gen Deliv | Excluded |
| 2024W1-N1-ST37 | 238981 | 02NASA | 238570 | 02BEAVER | 1 | 138/138 | 202/202 | Summer Thermal | Included |
| 2024W1-GD-S370 | 235467 | 01FRNCHM | 235592 | 01HAMPS45 | 1 | 138 | 201 | Summer Gen Deliv | Included |
| 2024W1-GD-S865 | 238549 | 02AVERY | 239108 | 02SHNROK | 1 | 138 | 202 | Summer Gen Deliv | Included |
| 2024W1-GD-S498 | 314901 | 8BATH CO | 314991 | 8VALLEY SC | 1 | 500 | 345 | Summer Gen Deliv | Included |
| 2024W1-32GD-S44 | 242516 | 05MOUNTN | 242920 | 05BELMON | 1 | 765 | 205 | 2032 Summer Gen Deliv | Included |
| 2024W1-GD-S369 | 235599 | 01HAMPS64 | 235471 | 01GORE | 1 | 138 | 201 | Summer Gen Deliv | Included |
| 2024W1-GD-S897 | 239030 | 02OTTAWA | 238874 | 02LAKVEW | 1 | 138 | 202 | Summer Gen Deliv | Included |
| 2024W1-GD-LL29 | 238768 | 02GRNFLD | 238974 | 02N DEPT | 1 | 138 | 202 | Light Load Gen Deliv | Included |
| 2024W1-GD-LL30 | 238590 | 02BRWELL | 238728 | 02FORD | 1 | 138 | 202 | Light Load Gen Deliv | Included |
| 2024W1-GD-LL27 | 238974 | 02N DEPT | 238590 | 02BRWELL | 1 | 138 | 202 | Light Load Gen Deliv | Included |
| 2024W1-N1-ST49 | 238974 | 02N DEPT | 238590 | 02BRWELL | 1 | 138/138 | 202/202 | Summer Thermal | Included |
| 2024W1-GD-LL33 | 239030 | 02OTTAWA | 238874 | 02LAKVEW | 1 | 138 | 202 | Light Load Gen Deliv | Included |
| 2024W1-N1-ST55 | 238590 | 02BRWELL | 238728 | 02FORD | 1 | 138/138 | 202/202 | Summer Thermal | Included |
| 2024W1-32GD-S52 | 314902 | 8CARSON | 314914 | 8MDLTHAN | 1 | 500 | 345 | 2032 Summer Gen Deliv | Included |
| 2024W1-N1-ST56 | 238590 | 02BRWELL | 238728 | 02FORD | 1 | 138/138 | 202/202 | Summer Thermal | Included |
| 2024W1-GD-S861 | 238768 | 02GRNFLD | 238974 | 02N DEPT | 1 | 138 | 202 | Summer Gen Deliv | Included |
| 2024W1-GD-S347 | 235490 | 01MORGAN | 235453 | 01CHERYR | 1 | 138 | 201 | Summer Gen Deliv | Included |
| 2024W1-32GD-S128 | 241877 | AC2-103 TAP | 238569 | 02BEAVER | 1 | 345 | 202 | N/A | Excluded |
| 2024W1-GD-LL31 | 238874 | 02LAKVEW | 238768 | 02GRNFLD | 1 | 138 | 202 | Light Load Gen Deliv | Included |

| FG # | Fr Bus No. | From Bus Name | To Bus No. | To Bus Name | CKT | Voltage | TO Zone | Analysis type | Status |
|----------------|------------|---------------|------------|-------------|-----|---------|---------|----------------------|----------|
| 2024W1-GD-LL32 | 238768 | 02GRNFLD | 238974 | 02N DEPT | 1 | 138 | 202 | Light Load Gen Deliv | Included |
| 2024W1-N1-ST48 | 238974 | 02N DEPT | 238590 | 02BRWELL | 1 | 138/138 | 202/202 | Summer Thermal | Included |
| 2024W1-GD-S872 | 239290 | 02HAYES | 238549 | 02AVERY | 1 | 138 | 202 | Summer Gen Deliv | Included |
| 2024W1-GD-S868 | 239290 | 02HAYES | 238549 | 02AVERY | 1 | 138 | 202 | Summer Gen Deliv | Included |
| 2024W1-GD-S485 | 243070 | 05OHIOCT | 243094 | 05SCOSHC | 1 | 138 | 205 | Summer Gen Deliv | Excluded |

New Flowgates

Proprietary business information.

Financial Information

Capital spend start date 01/2025

Construction start date 03/2029

Project Duration (In Months) 65

Cost Containment Commitment

Cost cap (in current year) Proprietary business information.

Cost cap (in-service year) Proprietary business information.

Components covered by cost containment

1. 3S-5) Davis-Besse to Lake Ave 345kV (greenfield portion) - Proposer

Cost elements covered by cost containment

Engineering & design Yes

Permitting / routing / siting Yes

ROW / land acquisition Yes

| | |
|---|-----------------------------------|
| Materials & equipment | Yes |
| Construction & commissioning | Yes |
| Construction management | Yes |
| Overheads & miscellaneous costs | Yes |
| Taxes | Yes |
| AFUDC | No |
| Escalation | No |
| Additional Information | Proprietary business information. |
| Is the proposer offering a binding cap on ROE? | Yes |
| Would this ROE cap apply to the determination of AFUDC? | No |
| Would the proposer seek to increase the proposed ROE if FERC finds that a higher ROE would not be unreasonable? | No |
| Is the proposer offering a Debt to Equity Ratio cap? | Proprietary business information. |
| Additional cost containment measures not covered above | Proprietary business information. |

Additional Comments

None